

Notice of request for more information

Environmental Permitting (England and
Wales) Regulations 2016

Notice requiring further information

To: Company Secretary
Project Red Recycling Ltd
Earthmover's House
Unit 16 Llantrisant Business Park
Llantrisant
Pontyclun
CF72 8LF

Tom Prichard tom@tomprichardcontracting.co.uk
Gareth Danter-Hill gareth@environmentalfocus.co.uk

Application number: PAN-002375

Natural Resources Wales, in exercise of its powers under paragraph 4 of Part 1 of Schedule 5 of the above Regulations, requires you to provide the information detailed in the attached schedule. The information is required in order to determine your application for a permit, dated **26/03/18**.

The information requested should be sent to the following address by **18th June 2018**

Information should be sent to:

Permitting Service (Cardiff)
Natural Resources Wales
Cambria House
29 Newport Road
Cardiff
CF24 0TP
Ella Williams: Ella.williams@cyfoethnaturiolcymru.gov.uk

Name	Date
Ella Williams	04/06/18

Authorised on behalf of Natural Resources Wales

Schedule

1. Fire Prevention and Mitigation Plan (FPMP)

Please provide answers to the below action points as a revised FPMP

If granted, you will need to have a fire prevention plan in line with our current guidance and operate it in line with our current guidance. We have assessed the FPMP (Third version submitted, received 03/05/18) submitted with this application (in response to the Schedule 5 notice sent 25/04/18) against the current guidance [Fire Prevention & Mitigation Plan Guidance – Waste Management Guidance Note 16 \(Document Version 2.0\)](#) (from here on referred to as “the guidance” in this section).

1.1 Water supplies

You have stated that there are not enough water supplies on site to suppress the largest stack on site. The largest stack is 1600l therefore the estimated minimum water supplies required would be 1,919,880 litres.

The plan you have provided shows that there is watercourse nearby.

Action:

- a) Please clarify if there is any access point to the watercourse that the FRS could use in the event of a fire and mark on the site plan, and what the distance and drop is to the watercourse.

1.2 Enclosing stacks using bays and walls

You have clarified there will be 5 bays with concrete walls. The guidance states that the walls need to be of sufficient height, thickness and construction to offer fire resistance period of at least 120 minutes.

Action:

- a) Please provide the specification for the walls to demonstrate that they are suitable.

1.3 Reviewing and Monitoring your FPMP

The FPMP states that there will be a scheduled review of the FPMP every 12 months. The guidance states that it needs to be reviewed regularly to reflect any changes that our business experiences.

Action:

- a) Please state the key triggers for unscheduled reviews, and what parts of the FPMP would need reviewing.

Ffôn/Tel 0300 065 3154

Ffacs/Fax 0300 065 3001

Ebost/Email ella.williams@cyfoethnaturiolcymru.gov.uk

ella.williams@naturalresourceswales.gov.uk

Gwasanaeth Trwyddedu (Caerdydd), Cyfoeth Naturiol Cymru, Tŷ Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP

Permitting Service (Cardiff), Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website www.cyfoethnaturiolcymru.gov.uk

www.naturalresourceswales.gov.uk

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg

Correspondence welcomed in Welsh and English