



Test Report



This test report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This test report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

OXIDES OF NITROGEN (AS NO₂) AND CARBON MONOXIDE COMPLIANCE TESTING AT SOUTH HOOK LNG TERMINAL ON BEHALF OF INTERTEK LIMITED

Permit Number: **XP3538LD**

Operator Name: **South Hook LNG (on behalf of Intertek Limited)**

Installation Name: **South Hook LNG Terminal**

Dates of Monitoring Visit: **13th - 14th August 2018**

Contract Reference: **E08040221**

Client Contact: **Adrian Walsh**

Client Organisation: **Intertek Limited**

Address: **Unit 14 - Waterston Trading Estate
Main Road, Waterston
Milford Haven
SA73 3SL**


Monitoring Organisation: **National Physical Laboratory**


Address: **Hampton Road
Teddington
Middlesex
TW11 0LW**

Date of Report: **16th August 2018**

Report Author: **Matthew Ellison**

Reference: XP3538LD/INTERTEK/SHLNG/AUG2018/SCV/PPC/Q3/V1

Report Approver: Kevin Blakley
MCERTS Registration: MM-03-317
Level & TEs Held: Level 2, TE1, TE2, TE3 & TE4
Signature: 

NPL Authorised Signatory
Name: Mr R Robinson (for NPLML)
Signature: 

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

CONTENTS PAGE

Part One: Executive Summary	PAGE
1.1 Monitoring Objectives	3
1.2.1 SCV 1A (Phase One) Monitoring Results	4
1.2.2 SCV 2A (Phase Two) Monitoring Results	5
1.2.3 SCV 2F (Phase Two) Monitoring Results	6
1.3 Operating Information	7
1.4 Monitoring Deviations	8
1.5 Conclusions	8
1.6 References	8
 Part Two: Supporting Information	
 Appendix One	
2.1.1 Emissions Testing Personnel Details	10
2.1.2 Emissions Testing Procedures	10
2.1.3 Equipment Checklist Reference	11
2.1.4 Data Capture Location Reference	11
 Appendix Two	
2.2.1 Stack Diagram	13
2.2.2 Flow Criteria Measurements	15
2.2.3 One Minute Averaged Gaseous Emissions Data	22
2.2.4 Gaseous Emissions Graphical Data	26
2.2.5 Gas Calibration Log	30
2.2.6 Uncertainty Calculations	34
2.2.7 Calculations Used in Reporting Results	47

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

1.1 Monitoring Objectives

NPL were awarded a contract by Intertek Limited to carry out emissions compliance testing at South Hook LNG plant near Milford Haven, Pembrokeshire. The scope of work includes carrying out emissions monitoring on the SCV flue stacks phases one and two.

There are a total of fifteen SCV units on the South Hook site that require monitoring, eight on phase one and seven on phase two. Three units were measured for oxides of nitrogen and carbon monoxide.

In addition, oxygen measurements were taken to allow a correction to reference conditions. Water vapour and flow measurements were also taken to determine the moisture content and velocity of the flue gas.

NPL carried out the monitoring visit between the 13th and 14th August 2018. The report documents the results obtained.

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

1.2.1 SCV A (Phase One) Monitoring Results

Client: Intertek
Site: South Hook LNG
Emission Point: SCV A (Phase One)

Field	Units	Oxides of Nitrogen (as NO ₂)	Carbon Monoxide	Oxygen	Moisture
Emission Limit Value	mg/m ³ , Reference Conditions	107	N/A	N/A	N/A
Periodic Monitoring Result	Reference Conditions	105.8	272	12.3	1.6
Uncertainty (95% Confidence Level)	Reference Conditions	21.9	39	0.6	N/A
	Units	mg/m ³	mg/m ³	%Vol/Vol	%Vol/Vol
Average Stack Flow	m ³ /s at Reference Conditions	4.1			
Reference Conditions		273K, 101.3 kPa, 3% Oxygen on a dry gas basis			
Date	dd/mm/yyyy	13/08/2018			
Sample Period	From hh:mm	13:55			
	To hh:mm	14:55			
Monitoring Method		BS EN 14792	BS EN 15058	BS EN 14789	BS EN 14790
Accreditation		UKAS & MCERTS	UKAS & MCERTS	UKAS & MCERTS	UKAS & MCERTS
Process Status	Load (Tonnes/Hour)	80			
Burner Demand	Burner Demand (%)	19			

1.2.2 SCV A (Phase Two) Monitoring Results

Client: Intertek
Site: South Hook LNG
Emission Point: SCV A (Phase Two)

Field	Units	Oxides of Nitrogen (as NO ₂)	Carbon Monoxide	Oxygen	Moisture
Emission Limit Value	mg/m ³ , Reference Conditions	107	N/A	N/A	N/A
Periodic Monitoring Result	Reference Conditions	36.6	718	12.3	1.8
Uncertainty (95% Confidence Level)	Reference Conditions	15.2	72	0.4	N/A
	Units	mg/m ³	mg/m ³	%Vol/Vol	%Vol/Vol
Average Stack Flow	m ³ /s at Reference Conditions	3.3			
Reference Conditions		273K, 101.3 kPa, 3% Oxygen on a dry gas basis			
Date	dd/mm/yyyy	14/08/2018			
Sample Period	From hh:mm	12:00			
	To hh:mm	13:00			
Monitoring Method		BS EN 14792	BS EN 15058	BS EN 14789	BS EN 14790
Accreditation		UKAS & MCERTS	UKAS & MCERTS	UKAS & MCERTS	UKAS & MCERTS
Process Status	Load (Tonnes/Hour)	80			
Process Status	Burner Demand (%)	20			

1.2.3 SCV F (Phase Two) Monitoring Results

Client: Intertek
Site: South Hook LNG
Emission Point: SCV F (Phase Two)

Field	Units	Oxides of Nitrogen (as NO ₂)	Carbon Monoxide	Oxygen	Moisture
Emission Limit Value	mg/m ³ , Reference Conditions	107	N/A	N/A	N/A
Periodic Monitoring Result	Reference Conditions	42.4	515	12.9	1.8
Uncertainty (95% Confidence Level)	Reference Conditions	16.4	52	0.4	N/A
	Units	mg/m ³	mg/m ³	%Vol/Vol	%Vol/Vol
Average Stack Flow	m ³ /s at Reference Conditions	3.3			
Reference Conditions		273K, 101.3 kPa, 3% Oxygen on a dry gas basis			
Date	dd/mm/yyyy	13/08/2018			
Sample Period	From hh:mm	16:45			
	To hh:mm	17:45			
Monitoring Method		BS EN 14792	BS EN 15058	BS EN 14789	BS EN 14790
Accreditation		UKAS & MCERTS	UKAS & MCERTS	UKAS & MCERTS	UKAS & MCERTS
Process Status	Load (Tonnes/Hour)	80			
Process Status	Burner Demand (%)	20			

NATIONAL PHYSICAL LABORATORY

Continuation Sheet

1.3 Operating Information

South Hook LNG Terminal, situated in Pembrokeshire South West Wales, is a regasification plant for natural gas. The LNG is transported in specially designed vessels to Milford Haven where it is then transferred into storage tanks, where it awaits reheating and distribution into the UK National Grid.

A total of fifteen SCVs have been built across two phases. Each one has at least two five inch ports installed, as set out in BS EN 13284-1. The ports are located approximately thirteen metres from the base of the stack and can be accessed by ladders that lead to a permanent platform. The sampling platform has lighting, toe boards and handrails. There is sufficient parking on the roadway at the base of the stacks for the mobile laboratory and provision of 240v 16A power supply outlets.

Continuous or Batch Process?	Each SCV operates on a batch process. The number of SCVs operating and the load at which they are set depend upon the required site output.				
What part of the batch process was sampled? (If applicable)	The periodic monitoring is carried out once an SCV has been brought online to the operators required load and has stabilised. This loading remains constant through the one hour test.				
What fuel was used during monitoring? (If applicable)	A small amount of LNG is used as fuel to heat a volume of water. This heat exchange warms up the LNG allowing it to be passed out into the National Grid system.				
What feedstock was used during monitoring? (If applicable)	N/A				
What was the load during monitoring?	Emission Point	Load (Ton/hr)	Burner Demand (%)		
	SCV 1A	80	19		
	SCV 2A	80	20		
	SCV 2F	80	20		
What abatement systems are present? Were they in operation?	Each SCV uses water injection to abate NOx emissions. The system was in operation during the periodic monitoring of each SCV.				
Periodic monitoring results and corresponding CEM values	Emission Point	Substance Monitored	CEM Result	Periodic Monitoring Result	Units
	SCV 2A	Oxides of Nitrogen	45.5	36.6	mg/Nm ³
	SCV 2A	Oxygen	12.1	12.3	% Vol

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

1.4 Monitoring Deviations

Were all substances in the monitoring objectives monitored? If not why?	All substances set out in the objective were monitored.
Were all substances monitored in accordance to the relevant method? If not why?	All substances set out in the monitoring objectives were measured in accordance to the relevant standards.
Were there any other issues relevant to the monitoring results?	No.

1.5 Conclusions

NPL carried out the emissions monitoring at South Hook LNG over a period of one week. Three SCVs were monitored for the required determinands.

The client is aware of BS EN 15259 and the requirement to carry out homogeneity testing. These tests were carried out on SCVs 1H and 2A, both units passed.

Reference - XP3538LD/INTERTEK/SHLNG/JULY2011/SCV/HOMOGENEITY.

1.6 References

1. STA – Risk Assessment Guide: Industrial-emission monitoring.
2. Environmental Agency - Manual Stack emission monitoring performance standard for Organisations.
3. Environmental Agency – M1 Technical Guidance Note – Sampling requirements for stack emission monitoring.
4. Environmental Agency – M2 Technical Guidance Note – Monitoring of stack emissions to air.
5. Environment Agency - MID 14792 - Stationary source emissions - Determination of mass concentration of nitrogen oxides (NOx) - Reference Method: Chemiluminescence.
6. Environment Agency - MID 15259 - Stationary source emissions - Requirements for the measurement sections and sites and for the measurement objective, plan and report.
7. Guidance on Assessing Measurement Uncertainty in Stack Emissions Monitoring, by Pullen J and Robinson R, Source Testing Association, Quality Guidance Note QGN1.

APPENDIX ONE

2.1.1 Emissions Testing Personnel Details

Name	Role	MCERTS Number	Certification Level & Expiry Dates					
			Level 1	Level 2	TE1	TE2	TE3	TE4
Matthew Ellison	Team Leader	MM-05-682	N/A	Sep-2023	Sep-2023	Sep-2023	Dec-2023	Sep-2023
Bob Lipscombe	Site Assistant	MM-07-879	Apr-2023	N/A	N/A	N/A	N/A	N/A

2.1.2 Emissions Testing Procedures

	Instrumental Methods			Manual Methods		
Determinand	NOx	CO	O ₂	H ₂ O	Stack Flow	Temperature
SRM Standard	BS EN 14792	BS EN 15058	BS EN 14789	BS EN 14790	BS ISO 16911	BS ISO 16911
Instrument	Horiba PG-250	Horiba PG-250	Horiba PG-250	N/A	Pitot	Type K Thermocouple
Instrument Serial No.	AS0450	AS0450	AS0450	N/A	AS0638	AS0638
Principle	Chemiluminescence	NDIR	Zirconia	Water vapour table	Flow	Temperature
Operational Range	0 - 250 ppm	0 - 500 ppm	0 - 25%	N/A	N/A	N/A
Certified Range	0 - 125 mg/m ³	0 - 95 mg/m ³	0 - 25%	N/A	N/A	N/A
Uncertainty	10%	6%	6%	20%	N/A	N/A
NPL Procedure	QPAS B 538	QPAS B 538	QPAS B 538	QPAS B 540	QPAS B 567	QPAS B 567
UKAS Accreditation	YES	YES	YES	YES	YES	YES

The sample gas was extracted from the stack via a chemically inert heated line and drawn through a conditioning unit. All moisture in the gas sample was removed and cooled down to 4°C before it was pumped down another line to the NPL Mobile Source Emissions Laboratory and analysed using a Horiba PG-250. The entire sampling system had been leak tested before testing was carried out to ensure no dilution of the sample gas.

NATIONAL PHYSICAL LABORATORY

Continuation Sheet

The conventional analyser zero and span settings were checked before and after each test run using zero grade nitrogen (ex BOC), a suitable gas mixture (BOC beta gas standard), traceable to national reference standards and a gas dilution system. The certified accuracies of the gas standards are listed below: -

Component	Sample Location	Cylinder ID	Certified Amount	Certified Uncertainty
Carbon Monoxide	Phase 1 & 2 SCVs	146117	153.2 ppm	1%
Nitrogen Oxide		146117	152.8 ppm	1%
Oxygen		172344	14.86%	1%

These measurement uncertainties are expressed at a 95% level of confidence.

The ranges of the Horiba PG-250 SRM analyser used for the testing and the values used to calibrate the instrument before and after the testing are listed below: -

Gaseous Components	Horiba Ranges	Calibrated Values
Carbon Monoxide	0 - 200 ppm	153.2 ppm
Oxides of Nitrogen (as NO ₂)	0 - 250 ppm	152.8 ppm
Oxygen	0 - 20%	14.86%

A leak test was conducted before testing to confirm hydraulic integrity of the gaseous sampling system. This was conducted by sending nitrogen down the entire sample line and ensuring a zero reading was obtained.

The electrical volt/millivolt outputs from the PG-250 gas analyser was collected by data logger software on a PC and downloaded to digital media at the end of each day. Under the program used during the tests, the software records and stores individual readings either every 1 or 10 seconds. From this data, the logger can perform a series of calculations to output 1 minute averaged measurement on a volume/volume or mass/volume basis. After each 1 minute average has been established the data buffer is reset and the process repeats.

2.1.3 Equipment Checklist Reference

See workfile INTK41AUG18/Equipment Checklist.


2.1.4 Data Capture Location Reference

All data collected using the NPL computer system on site is backed up at the end of each day onto a memory stick. When the team returns to site this information is then uploaded onto the NPL servers and stored in the relevant location for that job. The link below is where the South Hook emissions data is stored:

P:\Stack Emissions Team\South Hook LNG - Intertek\INTK41AUG18\7. Monitoring Record Sheets

APPENDIX TWO

2.2.1 - Stack Diagram



Position	1	2	3	4	5	6	7	8	9	10
% of Diameter	3.2	8.2	14.6	22.6	34.2	65.8	77.4	85.4	91.8	96.8
Insertion, m	0.05	0.12	0.22	0.33	0.51	0.97	1.15	1.26	1.36	1.43
Insertion plus offset, m	0.15	0.22	0.32	0.43	0.61	1.07	1.25	1.36	1.46	1.53

Notes - The circular stack diameter was measured as 1.48 metres, whilst the port offset (distance between the edge of the stack to the end of the port) was measured as 23 centimetres. Access to the top of the stack was by a series of three ladders. Each one had a resting platform in-between with a self closing gate installed. The main platform itself is a permanent structure with toe boards, railings and self closing gate.

2.2.2 - Flow Criteria Measurements


Continuation Sheet

[illegible]

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

SAMPLING LINE: North										
Traverse Point	Distance into duct (m)	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Δp Average mm H2O	Δp Pa	Stack Temp Ts °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	√Δp
1	1.42	2.40	2.40	2.40	2.40	23.53	14.2	5.10	8	1.55
2	1.26	2.60	2.60	2.60	2.60	25.49	14.1	5.31	6	1.61
3	1.04	2.40	2.40	2.40	2.40	23.53	13.9	5.10	5	1.55
4	0.44	1.90	1.90	1.90	1.90	18.63	13.8	4.54	4	1.38
5	0.22	1.90	1.90	1.90	1.90	18.63	14.0	4.54	6	1.38
6	0.06	1.90	1.90	1.90	1.90	18.63	14.3	4.54	6	1.38
SAMPLING LINE: West										
Traverse Point	Distance into duct (m)	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Δp Average mm H2O	Δp Pa	Stack Temp Ts °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	√Δp
1	1.42	1.40	1.40	1.40	1.40	13.72	14.4	3.90	6	1.18
2	1.26	2.00	2.00	2.00	2.00	19.61	14.2	4.66	6	1.41
3	1.04	2.10	2.10	2.10	2.10	20.59	14.0	4.77	6	1.45
4	0.44	2.60	2.60	2.60	2.60	25.49	14.0	5.31	7	1.61
5	0.22	2.80	2.80	2.80	2.80	27.45	14.2	5.51	6	1.67
6	0.06	2.60	2.60	2.60	2.60	25.49	14.8	5.32	7	1.61
Average values		2.2	2.2	2.2	2.2	21.7	14.2	4.9	6.1	1.5
Duct / Stack Flow Characteristics:										
Stack Velocity at stack gas T & P and a wet gas basis						Flow Criteria Measurements				
Stack flow @ STP, O ₂ (ref) and on a dry gas basis						4.88	ms ⁻¹	Is the Flow Ratio 3:1 or less?		
Stack flow @ stack gas T & P and on a dry gas basis						4.07	m ³ s ⁻¹	Any local negative flow?		
Stack flow @ stack gas T & P and on a wet gas basis						8.39	m ³ s ⁻¹	Flow <15° of duct axis?		
Stack flow @ STP and on a wet gas basis						8.05	m ³ s ⁻¹	Minimum Δp detected > 0.5 mmH2O		
Stack flow @ STP, O ₂ (ref) and on a wet gas basis						4.14	m ³ s ⁻¹	YES		

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Monitoring Objective	Traverse	Site:	South Hook LNG	Stack ID:	SCV 2A			
Date	14/08/2018	Site Team:	MRE/RPL	Time of Survey:	14:00			
Diagram of Sample Location:								
								
Tape Measure ID	AS0589							
Laser Measurement Device ID	N/A							
Traverse Pilot Tube Type	S-Type							
Traverse Pilot Tube ID	AS0466							
Prior Assembly Visual Inspection	Pass							
Pre Test Leak Check <2.5 mm H2O	Pass							
Traverse Manometer Type	Digital							
Traverse Manometer ID	AS0638							
Traverse Manometer Range	240							
Traverse Temp. Readout ID	AS0638							
Traverse Thermocouple ID	AS0451a							
Static Pressure	Δp (mmH2O)							
	7.50							
Swirl Test Conducted	Pass	Comments/Deviations:						
Protractor ID	Yes							
Post-Test Blockage Test (L-Type only)	AS0626							
Post Test Leak Check <2.5 mm H2O	Pass							
Prior Assembly Visual Inspection	Pass							
Conditions	Value	Units	Duct Dimensions					
Stack pressure	766.78	mmHg	Port ID	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Port Depth
Ref O ₂ Value	3	%	A					
Moisture Content	1.78	%	B					
CO	260	ppm	C					
CO ₂	4.7	%	D					
N ₂	83.07	%	Circular Duct					
O ₂	12.20	%	Line ID	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Duct Diameter
Dry Molecular wt	29.24		A					
Stack Molecular wt	29.04		B					
Duct Diameter	1.48	m	Rectangular Duct					
Duct Depth		m	Line ID	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Duct Depth
Duct Width		m	A					
Area of stack	1.72	m ²	B					
Pbar	1021.3	mbar	C					
Pbar	766	mmHg	D					
Pilot tube coeft	0.83		Outside Side Division					
Reference Temp	273	K	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Duct Width	
Reference Pressure	760	mmHg	Static Measurement					
Ambient Temperature	18	°C	Measurement Line					
			Δp (mmH2O)					
			Reading 1					
			Reading 2					
			Reading 3					
			Reading 4					
			Reading 5					
			Reading 6					
			Reading 7					
			Reading 8					
			Reading 9					
			Reading 10					
			Reading 11					
			Reading 12					
			Reading 13					
			Reading 14					
			Reading 15					
			Reading 16					
			Reading 17					
			Reading 18					
			Reading 19					
			Reading 20					
			Reading 21					
			Reading 22					
			Reading 23					
			Reading 24					
			Reading 25					
			Reading 26					
			Reading 27					
			Reading 28					
			Reading 29					
			Reading 30					
			Reading 31					
			Reading 32					
			Reading 33					
			Reading 34					
			Reading 35					
			Reading 36					
			Reading 37					
			Reading 38					
			Reading 39					
			Reading 40					
			Reading 41					
			Reading 42					
			Reading 43					
			Reading 44					
			Reading 45					
			Reading 46					
			Reading 47					
			Reading 48					
			Reading 49					
			Reading 50					
			Reading 51					
			Reading 52					
			Reading 53					
			Reading 54					
			Reading 55					
			Reading 56					
			Reading 57					
			Reading 58					
			Reading 59					
			Reading 60					
			Reading 61					
			Reading 62					
			Reading 63					
			Reading 64					
			Reading 65					
			Reading 66					
			Reading 67					
			Reading 68					
			Reading 69					
			Reading 70					
			Reading 71					
			Reading 72					
			Reading 73					
			Reading 74					
			Reading 75					
			Reading 76					
			Reading 77					
			Reading 78					
			Reading 79					
			Reading 80					
			Reading 81					
			Reading 82					
			Reading 83					
			Reading 84					
			Reading 85					
			Reading 86					
			Reading 87					
			Reading 88					
			Reading 89					
			Reading 90					
			Reading 91					
			Reading 92					
			Reading 93					
			Reading 94					
			Reading 95					
			Reading 96					
			Reading 97					
			Reading 98					
			Reading 99					
			Reading 100					

SAMPLING LINE: North										
Traverse Point	Distance into duct (m)	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Average mm H2O	Δp Pa	Stack Temp Ts °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	√Δp
1	1.42	1.70	1.70	1.70	1.70	16.67	15.8	4.31	4	1.30
2	1.26	1.50	1.50	1.50	1.50	14.70	15.8	4.05	4	1.22
3	1.04	1.80	1.80	1.80	1.80	17.65	15.7	4.43	3	1.34
4	0.44	1.60	1.60	1.60	1.60	15.68	15.6	4.18	3	1.26
5	0.22	1.90	1.90	1.90	1.90	18.63	15.7	4.56	3	1.38
6	0.06	1.80	1.80	1.80	1.80	17.65	15.8	4.43	4	1.34
SAMPLING LINE: West										
Traverse Point	Distance into duct (m)	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Average mm H2O	Δp Pa	Stack Temp Ts °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	√Δp
1	1.42	1.40	1.40	1.40	1.40	13.72	15.8	3.91	5	1.18
2	1.26	1.30	1.30	1.30	1.30	12.74	15.7	3.77	4	1.14
3	1.04	1.20	1.20	1.20	1.20	11.76	15.6	3.62	5	1.10
4	0.44	1.80	1.80	1.80	1.80	17.65	15.8	4.43	5	1.34
5	0.22	1.90	1.90	1.90	1.90	18.63	15.8	4.56	4	1.38
6	0.06	2.30	2.30	2.30	2.30	22.55	15.9	5.01	4	1.52
Average values		1.7	1.7	1.7	1.7	16.5	15.8	4.3	4.0	1.3
Duct / Stack Flow Characteristics:										
Stack Velocity at stack gas T & P and a wet gas basis					Average		Units			
Stack flow @ STP, O ₂ (ref) and on a dry gas basis					4.27		m ³ s ⁻¹			
Stack flow @ STP, O ₂ (ref) and on a dry gas basis					3.35		m ³ s ⁻¹			
Stack flow @ stack gas T & P and on a wet gas basis					7.35		m ³ s ⁻¹			
Stack flow @ stack gas T & P and on a dry gas basis					7.22		m ³ s ⁻¹			
Stack flow @ STP and on a wet gas basis					7.01		m ³ s ⁻¹			
Stack flow @ STP, O ₂ (ref) and on a wet gas basis					3.41		m ³ s ⁻¹			
					Is the Flow Ratio 3:1 or less?		1.4			
					Any local negative flow?		NO			
					Flow <15° of duct axis?		YES			
					Minimum Δp detected > 0.5 mmH2O		YES			

NATIONAL PHYSICAL LABORATORY

Continuation Sheet

Monitoring Objective		Traverse	Site:	South Hook LNG	Stack ID:	SCV 2F			
Date	14/08/2018		Site Team:	MRE/RPL	Time of Survey:	16:15			
Diagram of Sample Location:									
Type Measure ID	AS0569								
Laser Measurement Device ID	N/A								
Traverse Pilot Type	S-Type								
Traverse Pilot Tube ID	AS0466								
Prior Assembly visual inspection (Dra)	Pass								
Pre Test Leak Check <1.5 mm H2O	Pass								
Traverse Manometer Type	Digital								
Traverse Manometer ID	AS0638								
Traverse Manometer Range	240								
Traverse Temp. Readout ID	AS0638								
Traverse Thermocouple ID	AS0451a								
Static Pressure	Δp (mmH2O)								
	Value	Units							
	8.50	mmHg							
Swirl Test Conducted	Pass								
	Yes								
	AS0626								
Protractor ID	AS0626								
Post-Test Blockage Test (L-Type only)									
Post Test Leak Check <1.5 mm H2O	Pass								
Prior Assembly visual inspection (Dra)	Pass								
Conditions		Value	Units	Duct Dimensions					
Stack pressure		767.23	mmHg	Port ID	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Port Depth
Ref O ₂ Value		3	%	A					
Moisture Content		1.79	%	B					
CO		175	ppm	C					
CO ₂		4.3	%	D					
N ₂		82.68	%	Circular Duct					
O ₂		13.00	%	Line ID	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Duct Diameter
Dry Molecular wt		29.21		A					
Stack Molecular wt		29.01		B					
Duct Diameter		1.48	m	Rectangular Duct					
Duct Depth			m	Line ID	Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Duct Depth
Duct Width			m	A					
Area of stack		1.72	m ²	B					
Pbar		1021.8	mbar	C					
Pbar		767	mmHg	D					
Pilot tube coeff		0.83		Outside Side Division					
Reference Temp		273	K		Reading 1 (m)	Reading 2 (m)	Reading 3 (m)	Average	Duct Width
Reference Pressure		760	mmHg						
Ambient Temperature		19	° C						
				Static Measurement					
				Measurement Line					
				Δp (mmH2O)					
				Reading 1					
				Reading 2					
				Reading 3					
				Reading 4					
				Reading 5					
				Reading 6					
				Reading 7					
				Reading 8					
				Reading 9					
				Reading 10					
				Reading 11					
				Reading 12					
				Reading 13					
				Reading 14					
				Reading 15					
				Reading 16					
				Reading 17					
				Reading 18					
				Reading 19					
				Reading 20					
				Reading 21					
				Reading 22					
				Reading 23					
				Reading 24					
				Reading 25					
				Reading 26					
				Reading 27					
				Reading 28					
				Reading 29					
				Reading 30					
				Reading 31					
				Reading 32					
				Reading 33					
				Reading 34					
				Reading 35					
				Reading 36					
				Reading 37					
				Reading 38					
				Reading 39					
				Reading 40					
				Reading 41					
				Reading 42					
				Reading 43					
				Reading 44					
				Reading 45					
				Reading 46					
				Reading 47					
				Reading 48					
				Reading 49					
				Reading 50					
				Reading 51					
				Reading 52					
				Reading 53					
				Reading 54					
				Reading 55					
				Reading 56					
				Reading 57					
				Reading 58					
				Reading 59					
				Reading 60					
				Reading 61					
				Reading 62					
				Reading 63					
				Reading 64					
				Reading 65					
				Reading 66					
				Reading 67					
				Reading 68					
				Reading 69					
				Reading 70					
				Reading 71					
				Reading 72					
				Reading 73					
				Reading 74					
				Reading 75					
				Reading 76					
				Reading 77					
				Reading 78					
				Reading 79					
				Reading 80					
				Reading 81					
				Reading 82					
				Reading 83					
				Reading 84					
				Reading 85					
				Reading 86					
				Reading 87					
				Reading 88					
				Reading 89					
				Reading 90					
				Reading 91					
				Reading 92					
				Reading 93					
				Reading 94					
				Reading 95					
				Reading 96					
				Reading 97					
				Reading 98					
				Reading 99					
				Reading 100					
				Reading 101					
				Reading 102					
				Reading 103					
				Reading 104					
				Reading 105					
				Reading 106					
				Reading 107					
				Reading 108					
				Reading 109					
				Reading 110					
				Reading 111					
				Reading 112					
				Reading 113					
				Reading 114					
				Reading 115					
				Reading 116					
				Reading 117					
				Reading 118					
				Reading 119					
				Reading 120					
				Reading 121					
				Reading 122					
				Reading 123					
				Reading 124					
				Reading 125					
				Reading 126					
				Reading 127					
				Reading 128					
				Reading 129					
				Reading 130					
				Reading 131					
				Reading 132					
				Reading 133					
				Reading 134					
				Reading 135					
				Reading 136					
				Reading 137					
				Reading 138					
				Reading 139					
				Reading 140					
				Reading 141					
				Reading 142					
				Reading 143					
				Reading 144					
				Reading 145					
				Reading 146					
				Reading 147					
				Reading 148					
				Reading 149					
				Reading 150					
				Reading 151					
				Reading 152					
				Reading 153					
				Reading 154					
				Reading 155					
				Reading 156					
				Reading 157					
				Reading 158					
				Reading 159					
				Reading 160					
				Reading 161					
				Reading 162					
				Reading 163					
				Reading 164					
				Reading 165					
				Reading 166					
				Reading 167					
				Reading 168					
				Reading 169					
				Reading 170					
				Reading 171					
				Reading 172					
				Reading 173					
				Reading 174					
				Reading 175					
				Reading 176					
				Reading 177					
				Reading 178					
				Reading 179					
				Reading 180					
				Reading 181					
				Reading 182					
				Reading 183					
				Reading 184					
				Reading 185					
				Reading 186					
				Reading 187					
				Reading 188					
				Reading 189					
				Reading 190					
				Reading 191					
				Reading 192					
				Reading 193					
				Reading 194					
				Reading 195					
				Reading 196					
				Reading 197					
				Reading 198					
				Reading 199					
				Reading 200					
				Reading 201					
				Reading 202					
				Reading 203					
				Reading 204					
				Reading 205					
				Reading 206					
				Reading 207					
				Reading 208					
				Reading 209					
				Reading 210					
				Reading 211					
				Reading 212					
				Reading 213					
				Reading 214					
				Reading 215					
				Reading 216					
				Reading 217					
				Reading 218					
				Reading 219					
				Reading 220					
				Reading 221					
				Reading 222					
				Reading 223					
				Reading 224					
				Reading 225					
				Reading 226					
				Reading 227					
				Reading 228					
				Reading 229					
				Reading 230					
				Reading 231					
				Reading 232					
				Reading 233					
				Reading 234					
				Reading 235					
				Reading 236					
				Reading 237					
				Reading 238					
				Reading 239					
				Reading 240					
				Reading 241					
				Reading 242					
				Reading 243					
				Reading 244					
				Reading 245					
				Reading 246					
				Reading 247					
				Reading 248					
				Reading 249					
				Reading 250					
				Reading 251					
				Reading 252					
				Reading 253					
				Reading 254					
				Reading 255					
				Reading 256					
				Reading 257					
				Reading 258					
				Reading 259					
				Reading 260					
				Reading 261					
				Reading 262					
				Reading 263					
				Reading 264					
				Reading 265					
				Reading 266					
				Reading 267					
				Reading 268					
				Reading 269					
				Reading 270					
				Reading 271					
				Reading 272					
				Reading 273					
				Reading 274					
				Reading 275					
				Reading 276					
				Reading 277					
				Reading 278					
				Reading 279					
				Reading 280					
				Reading 281					
				Reading 282					
				Reading 283					
				Reading 284					
				Reading 285					
				Reading 286					
				Reading 287					
				Reading 288					
				Reading 289					
				Reading 290					
				Reading 291					
				Reading 292					
				Reading 293					
				Reading 294					
				Reading 295					
				Reading 296					
				Reading 297					
				Reading 298					
				Reading 299					
				Reading 300					
				Reading 301					
				Reading 302					
				Reading 303					
				Reading 304					
				Reading 305					
				Reading 306					
				Reading 307					
				Reading 308					
				Reading 309					
				Reading 310					
				Reading 311					
				Reading 312					
				Reading 313					
				Reading 314					
				Reading 315					
				Reading 316					
				Reading 317					

SAMPLING LINE: North										
Traverse Point	Distance into duct (m)	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Δp Average mm H2O	Δp Pa	Stack Temp Ts °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	√Δp
1	1.42	1.70	1.70	1.70	1.70	16.67	15.8	4.31	6	1.30
2	1.26	2.00	2.00	2.00	2.00	19.61	15.6	4.67	5	1.41
3	1.04	1.90	1.90	1.90	1.90	18.63	15.5	4.56	5	1.38
4	0.44	2.10	2.10	2.10	2.10	20.59	15.4	4.79	6	1.45
5	0.22	1.60	1.60	1.60	1.60	15.68	15.9	4.18	7	1.26
6	0.06	1.60	1.60	1.60	1.60	15.68	16.0	4.18	8	1.26
SAMPLING LINE: West										
Traverse Point	Distance into duct (m)	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Ap Spot Reading mm H2O	Δp Average mm H2O	Δp Pa	Stack Temp Ts °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	√Δp
1	1.42	1.40	1.40	1.40	1.40	13.72	16.0	3.91	7	1.18
2	1.26	1.50	1.50	1.50	1.50	14.70	16.0	4.05	8	1.22
3	1.04	1.90	1.90	1.90	1.90	18.63	15.8	4.56	5	1.38
4	0.44	2.30	2.30	2.30	2.30	22.55	15.9	5.02	7	1.52
5	0.22	2.60	2.60	2.60	2.60	25.49	16.4	5.34	4	1.61
6	0.06	2.60	2.60	2.60	2.60	25.49	16.5	5.34	8	1.61
Average values		1.9	1.9	1.9	1.9	19.0	15.9	4.6	6.3	1.4
Duct / Stack Flow Characteristics:					Flow Criteria Measurements					
Stack Velocity at stack gas T & P and a wet gas basis					Average		Units		1.4	
Stack flow @ STP, O ₂ (ref) and on a dry gas basis					4.58		ms ⁻¹		Is the Flow Ratio 3:1 or less?	
Stack flow @ stack gas T & P and on a dry gas basis					3.25		m ³ s ⁻¹		:1	
Stack flow @ stack gas T & P and on a wet gas basis					7.87		m ³ s ⁻¹		NO	
Stack flow @ stack gas T & P and on a dry gas basis					7.73		m ³ s ⁻¹		YES	
Stack flow @ STP and on a wet gas basis					7.51		m ³ s ⁻¹		YES	
Stack flow @ STP, O ₂ (ref) and on a wet gas basis					3.31		m ³ s ⁻¹		YES	

2.2.3 - One Minute Averaged Gaseous Emissions Data

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Minute Averaged Gaseous Data from South Hook LNG 13th August 2018			
SCV A - Phase One			
Referenced to 273K, 101.3kPa and 3% Oxygen on a Dry Basis			
Time (hh:mm)	Carbon Monoxide (mg/Nm ³)	Oxides of Nitrogen (mg/Nm ³)	Oxygen (%)
13:55	495	54.1	11.8
13:56	504	53.2	11.8
13:57	499	52.6	12.0
13:58	496	63.9	12.2
13:59	138	136.1	12.4
14:00	129	139.4	12.6
14:01	147	138.3	12.8
14:02	143	139.6	12.9
14:03	151	139.2	12.9
14:04	147	139.9	12.9
14:05	136	142.5	12.8
14:06	137	141.8	12.8
14:07	129	143.7	12.8
14:08	115	146.8	12.6
14:09	96	147.6	12.3
14:10	84	148.8	12.1
14:11	216	108.0	12.0
14:12	454	58.3	11.9
14:13	478	55.6	11.9
14:14	490	54.2	11.9
14:15	488	53.6	11.9
14:16	491	52.8	11.9
14:17	506	52.1	12.0
14:18	428	74.4	12.2
14:19	128	135.2	12.4
14:20	127	138.7	12.6
14:21	127	139.3	12.8
14:22	140	140.3	12.8
14:23	138	140.8	12.9
14:24	141	140.7	12.9
14:25	145	141.0	12.9
14:26	141	141.6	12.9
14:27	140	142.4	12.8
14:28	106	146.7	12.4
14:29	95	147.1	12.2
14:30	106	136.8	12.0
14:31	419	61.5	11.8
14:32	457	56.8	11.8
14:33	465	56.2	11.7
14:34	479	53.7	11.7
14:35	480	54.0	11.8
14:36	484	53.0	11.8
14:37	494	51.7	12.0
14:38	324	98.3	12.3
14:39	118	136.9	12.5
14:40	133	137.5	12.7
14:41	137	138.6	12.9
14:42	152	137.7	13.0
14:43	150	138.4	13.0
14:44	151	138.0	13.0
14:45	148	139.1	13.0
14:46	143	140.5	12.9
14:47	113	143.7	12.5
14:48	93	145.4	12.3
14:49	159	119.9	11.8
14:50	470	58.3	11.8
14:51	474	55.4	11.7
14:52	472	54.0	11.7
14:53	485	53.4	11.7
14:54	479	52.8	11.8
14:55	491	52.0	11.8
Min Value	84	51.7	11.7
Max Value	506	148.8	13.0
Average	272	105.8	12.3

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


Minute Averaged Gaseous Data from South Hook LNG 14th August 2018			
SCV A - Phase Two			
Referenced to 273K, 101.3kPa and 3% Oxygen on a Dry Basis			
Time (hh:mm)	Carbon Monoxide (mg/Nm ³)	Oxides of Nitrogen (mg/Nm ³)	Oxygen (%)
12:00	775	36.6	12.3
12:01	788	36.3	12.3
12:02	795	36.6	12.3
12:03	767	36.6	12.3
12:04	755	36.7	12.2
12:05	737	36.3	12.3
12:06	736	36.7	12.3
12:07	714	36.5	12.3
12:08	709	36.9	12.3
12:09	695	36.7	12.3
12:10	671	37.1	12.2
12:11	674	37.0	12.2
12:12	681	36.7	12.2
12:13	658	37.1	12.2
12:14	662	37.0	12.2
12:15	677	36.8	12.3
12:16	664	37.1	12.3
12:17	698	36.8	12.3
12:18	708	36.5	12.3
12:19	717	36.6	12.3
12:20	717	36.7	12.4
12:21	724	36.9	12.3
12:22	723	36.5	12.3
12:23	730	36.7	12.3
12:24	737	36.8	12.2
12:25	719	36.6	12.2
12:26	719	36.9	12.2
12:27	705	36.7	12.2
12:28	705	36.6	12.3
12:29	734	36.4	12.3
12:30	723	36.4	12.3
12:31	738	36.0	12.3
12:32	735	36.2	12.3
12:33	738	36.4	12.3
12:34	738	36.0	12.3
12:35	722	36.5	12.3
12:36	725	36.4	12.3
12:37	710	36.8	12.3
12:38	698	36.9	12.3
12:39	706	36.8	12.3
12:40	715	36.4	12.3
12:41	718	36.4	12.3
12:42	723	36.3	12.3
12:43	717	36.3	12.4
12:44	731	36.1	12.4
12:45	729	36.4	12.3
12:46	710	36.6	12.3
12:47	714	36.6	12.3
12:48	727	36.4	12.3
12:49	712	36.6	12.3
12:50	716	36.7	12.3
12:51	731	36.4	12.3
12:52	731	36.4	12.4
12:53	733	36.4	12.4
12:54	729	36.7	12.3
12:55	717	36.6	12.3
12:56	707	36.6	12.3
12:57	710	37.0	12.3
12:58	713	36.6	12.3
12:59	708	36.8	12.3
13:00	698	37.0	12.3
Min Value	658	36.0	12.2
Max Value	795	37.1	12.4
Average	718	36.6	12.3

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


Minute Averaged Gaseous Data from South Hook LNG 13th August 2018			
SCV F - Phase Two			
Referenced to 273K, 101.3kPa and 3% Oxygen on a Dry Basis			
Time (hh:mm)	Carbon Monoxide (mg/Nm ³)	Oxides of Nitrogen (mg/Nm ³)	Oxygen (%)
16:45	517	42.9	12.9
16:46	509	43.3	12.8
16:47	513	43.3	12.8
16:48	504	43.2	12.7
16:49	502	43.1	12.8
16:50	505	43.2	12.8
16:51	494	43.6	12.8
16:52	501	43.2	12.8
16:53	495	43.4	12.8
16:54	488	43.3	12.8
16:55	482	43.4	12.8
16:56	488	43.1	12.8
16:57	495	43.2	12.9
16:58	512	42.8	12.9
16:59	513	42.6	13.0
17:00	512	42.7	13.0
17:01	507	43.0	13.0
17:02	514	42.7	13.0
17:03	515	42.8	12.9
17:04	534	41.8	12.9
17:05	533	41.7	13.0
17:06	522	42.2	12.9
17:07	535	41.6	12.9
17:08	546	41.1	12.9
17:09	542	41.4	12.9
17:10	539	41.5	12.9
17:11	548	41.4	13.0
17:12	528	42.1	12.9
17:13	515	42.4	12.9
17:14	516	42.5	12.8
17:15	524	42.3	12.8
17:16	504	42.5	12.8
17:17	512	42.6	12.8
17:18	502	43.0	12.8
17:19	509	42.7	12.8
17:20	490	43.1	12.7
17:21	498	42.7	12.7
17:22	491	42.9	12.8
17:23	483	43.0	12.8
17:24	504	42.1	12.8
17:25	516	41.3	12.8
17:26	522	41.5	12.8
17:27	514	41.5	12.8
17:28	513	41.6	12.8
17:29	524	41.5	12.9
17:30	516	41.8	12.9
17:31	517	41.9	12.9
17:32	505	42.3	12.9
17:33	514	42.5	12.9
17:34	515	42.2	12.9
17:35	509	42.7	12.9
17:36	517	42.4	12.9
17:37	536	42.1	13.0
17:38	551	42.1	13.0
17:39	532	42.3	12.9
17:40	529	42.6	12.8
17:41	518	42.9	12.8
17:42	516	42.6	12.8
17:43	518	42.7	12.8
17:44	545	41.4	12.8
17:45	543	41.1	12.8
Min Value	482	41.1	12.7
Max Value	551	43.6	13.0
Average	515	42.4	12.9

2.2.4 - Gaseous Emissions Graphical Data


SCV 1A One Minute Averaged Gaseous Emissions Data - 13th August 2018
(273.15K, 101.325kPa, 3% O₂, on a Dry Gas basis) using the NPL Conventional Analysis Package



SCV 2A One Minute Averaged Gaseous Emissions Data - 14th August 2018
(273.15K, 101.325kPa, 3% O₂, on a Dry Gas basis) using the NPL Conventional Analysis Package



SCV 2F One Minute Averaged Gaseous Emissions Data - 13th August 2018
(273.15K, 101.325kPa, 3% O₂, on a Dry Gas basis) using the NPL Conventional Analysis Package



2.2.5 - Gas Calibration Log

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

GAS CALIBRATION MEASUREMENTS

Client:	Intertek Ltd	Date:	13/08/2018	GAS CALIBRATION LOG - ANALYSER ADJUSTMENT			
Site:	South Hook LNG	Job Number:	INTG18AUG18	CBSS auto ranges			
Stock ID:	SCV 1A	Initial N ₂ pressure bar:	180	Testo ranges			
Reference oxygen %:	3	Leak check method:	Cylinder method	Testo ranges			
GAS CALIBRATION LOG - ANALYSER ADJUSTMENT							
Gas Cylinder ID:		CO	NO	NOx	O ₂	CO ₂	
Initial Reg. Pressure bar		146.17	146.17		172.344	172.344	
Analyser type / Analyser ID		150	150		140	140	
Cylinder Concentration:		PG250	AS0450		PG250	AS0450	
Span Value:		153.2 ppm	152.8 ppm	ppm	14.86 % Vol	15.24 % Vol	
Analyser Range: 0 -		200 ppm	250 ppm	ppm	14.86 % Vol	15.24 % Vol	
Time			11:47		25 % Vol	20 % Vol	
Check Zero		ppm	0.0 ppm	ppm	0.53 % Vol	-0.17 % Vol	
Reading		2	0		13	4	
Initial Gain							
Time			11:49				
Adjust Zero		ppm	0.0 ppm	ppm	0.00 % Vol	0.00 % Vol	
Reading		2	0		-1	1	
Final Gain							
Time			12:01		11:54	11:54	
Check Span		ppm	166.7 ppm	ppm	15.10 % Vol	16.50 % Vol	
Reading		1.217	1.091		0.878	0.986	
Initial Gain							
Time			12:03		11:56	11:56	
Adjust Span		ppm	153.0 ppm	ppm	14.86 % Vol	15.24 % Vol	
Reading		1.112	0.999		0.864	0.952	
Final Gain							
Time			12:06				
Check Zero		ppm	0.4 ppm	ppm	-0.06 % Vol	0.02 % Vol	
Reading		0.4	0.6		-0.06 % Vol	0.0 % Vol	
Zero Drift		0.0 ppm	Accept <2% of range	ppm	Accept <2% of range	Accept <2% of range	
Acceptance							
GAS CALIBRATION LOG - SAMPLING SYSTEM CHECK - FLOW METHOD							
Expected Flow:		CO	NO	NOx	O ₂		
Time		l/min	l/min	l/min	l/min		
Leak check		l/min	l/min	l/min	l/min		
Pass/fail							
GAS CALIBRATION LOG - SAMPLING SYSTEM CHECK - CYLINDER METHOD							
Span Value:		SO ₂	CO	NO	NOx	O ₂	
Time		0.0 ppm	153.2 ppm	152.8 ppm	0.0 ppm	14.9 % Vol	
Reading					12:10	15.2 % Vol	
Check Zero		ppm	-0.5 ppm	0.1 ppm	ppm	0.02 % Vol	
Pass/fail		PASS	PASS	PASS	PASS	PASS	
Time			12:14	12:14	12:19	12:19	
Check Span		ppm	151.4 ppm	152.8 ppm	ppm	15.20 % Vol	
Response Time/s		55 sec	62 sec	62 sec	60 sec	60 sec	
Pass/fail		PASS	PASS	PASS	PASS	PASS	
GAS CALIBRATION LOG - DRIFT CHECK (direct to analyser)							
Span Value:		SO ₂	CO	NO	NOx	O ₂	
Time		0.0 ppm	153.2 ppm	152.8 ppm	0.0 ppm	14.86 % Vol	
Check Zero		ppm	0.8 ppm	0.0 ppm	ppm	0.04 % Vol	
Reg. Pressure (N ₂)					170		
Time			15:22	15:22	15:26	15:26	
Check Span		ppm	147.2 ppm	157.4 ppm	ppm	15.21 % Vol	
Reg. Pressure			145	145	135	135	
Zero Drift (%)		0.5	0.0	0.0	1.7	0.3	
Span Drift (%)		3.8	3.0	3.0	1.5	0.2	
Acceptance zero		Accept	Accept	Accept	Accept	Accept	
Acceptance span		Correct for drift	Correct for drift	Correct for drift	Accept	Accept	

CALIBRATION TO BE CARRIED OUT BY OR UNDER THE SUPERVISION OF MCERTS QUALIFIED PERSONNEL WITH LEVEL TWO AND TEA

Name:	Matthew Ellison	Personnel Present:	MRE/RPL
MCERTS ID:	MM-05-482		

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

GAS CALIBRATION MEASUREMENTS

Client:	Intertek Ltd	Date:	14/08/2018	GAS CALIBRATION LOG - ANALYSER ADJUSTMENT									
Site:	South Hook LNG	Job Number:	INTK14AUG18	CHSS auto ranges									
Stack ID:	SCV 2A	Initial N ₂ pressure bar:	160	Testo ranges									
Reference oxygen %:	3	Leak check method:	Cylinder method	0-5000									
				SO ₂	CO	NO	NOx	O ₂	CO ₂	CO	NOx	N ₂ O	
				146117	146117	146117	146117	130	130	130	130		
				140	140	140	140	130	130	130	130		
				PG250	AS0450	PG250	AS0450	PG250	AS0450	PG250	AS0450		
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				152.2	152.2	152.8	152.8	14.86	14.86	15.24	15.24	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				152.2	152.2	152.8	152.8	14.86	14.86	15.24	15.24	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				200	200	250	250	25	25	20	20	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				11:12	11:12	11:12	11:12	0.25	0.25	-0.05	-0.05	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0.8	0.8	0	0	-6	2	2	2	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				-1	-1	0	0	0.00	0.00	0.00	0.00	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0	0	0	0	0	1	1	1	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				11:17	11:17	11:17	11:17	11:25	11:25	11:25	11:25	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				159.1	159.1	155.8	155.8	14.92	14.92	15.86	15.86	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				11:50	11:50	1:019	1:019	0.865	0.967	0.967	0.967	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				11:19	11:19	11:19	11:19	11:27	11:27	11:27	11:27	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				152.9	152.9	152.8	152.8	14.86	15.24	15.24	15.24	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				1:108	1:108	0.998	0.998	0.862	0.951	0.951	0.951	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				11:29	11:29	11:29	11:29	0.00	0.00	0.08	0.08	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				1.6	1.6	0.1	0.1	0.00	0.1	0.1	0.1	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0.0	0.0	0.1	0.1	0.00	0.1	0.1	0.1	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	0.0	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				11:32	11:32	11:32	11:32	0.08	0.03	0.03	0.03	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0.6	0.6	0.1	0.1	0.08	0.03	0.03	0.03	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	ppm	
				11:35	11:35	11:35	11:35	11:40	11:40	11:40	11:40	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				151.1	151.1	152.3	152.3	14.84	15.07	15.07	15.07	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				60 sec	60 sec	63 sec	63 sec	63 sec	63 sec	63 sec	63 sec	sec	
				PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	sec	
				11:32	11:32	11:32	11:32	15.2	15.2	15.2	15.2	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0.0	0.0	152.8	152.8	14.9	15.2	15.2	15.2	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				153.2	153.2	152.8	152.8	14.9	15.2	15.2	15.2	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0.6	0.6	0.1	0.1	0.08	0.03	0.03	0.03	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	ppm	
				11:35	11:35	11:35	11:35	11:40	11:40	11:40	11:40	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				151.1	151.1	152.3	152.3	14.84	15.07	15.07	15.07	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				60 sec	60 sec	63 sec	63 sec	63 sec	63 sec	63 sec	63 sec	sec	
				PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	sec	
				11:32	11:32	11:32	11:32	15.2	15.2	15.2	15.2	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				0.0	0.0	152.8	152.8	14.86	15.24	15.24	15.24	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				1.5	1.5	0.0	0.0	-0.10	0.03	0.03	0.03	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				13:10	13:10	13:10	13:10	13:15	13:15	13:15	13:15	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				135	135	135	135	1.25	1.25	1.25	1.25	ppm	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				1.8	1.8	0.0	0.0	0.7	0.2	0.2	0.2	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				1.8	1.8	0.1	0.1	0.5	0.3	0.3	0.3	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19	15.19	ppm C ₂ H ₆	
				ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	ppm	
				150.1	150.1	152.7	152.7	14.79	15.19	15.19			

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

GAS CALIBRATION MEASUREMENTS

Client:	Intertek Ltd	Date:	13/08/2018												
Site:	South Hook LNG	Job Number:	INTG18AUG18												
Stock ID:	SCV 2F	Initial N ₂ pressure bar:	170												
Reference oxygen %:	3	Leak check method:	Cylinder method												
GAS CALIBRATION LOG - ANALYSER ADJUSTMENT															
Gas Cylinder ID:		SO ₂	CO	NO	NOx	O ₂	CO ₂	CO	ppm	NONOX (ppm)	N ₂ O (ppm)				
Initial Reg. Pressure bar		146.17	145	145		172344	172344			0-100	0-15				
Analyser type / Analyser ID		PG250	AS0450	PG250	AS0450	PG250	AS0450	PG250	AS0450						
Cylinder Concentration:		153.2 ppm	153.2 ppm	153.8 ppm	14.86 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	ppm C ₂ H ₆	ppm				
Span Value:		153.2 ppm	153.2 ppm	152.8 ppm	14.86 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	ppm C ₂ H ₆	ppm				
Analyser Range: 0 -		200 ppm	200 ppm	250 ppm	25 % Vol	20 % Vol	20 % Vol	20 % Vol	20 % Vol	ppm C ₂ H ₆	ppm				
Time															
Check Zero		Reading	-2.6 ppm	0.0 ppm	ppm	-0.20 % Vol	0.04 % Vol	0.04 % Vol	0.04 % Vol	ppm C ₂ H ₆	ppm				
Initial Gain		2	0	0		-1	1								
Time															
Adjust Zero		Reading	0.0 ppm	0.0 ppm	ppm	0.00 % Vol	0.00 % Vol	0.00 % Vol	0.00 % Vol	ppm C ₂ H ₆	ppm				
Final Gain		-1	0	0		-6	2								
Time															
Check Span		Reading	15.58	15.58	ppm	15.52	15.52	15.52	15.52	ppm C ₂ H ₆	ppm				
Initial Gain		148.1 ppm	149.8 ppm	149.8 ppm	14.83 % Vol	14.69 % Vol	14.69 % Vol	14.69 % Vol	14.69 % Vol	ppm C ₂ H ₆	ppm				
Final Gain		1.112	0.999	0.999	0.864	0.864	0.864	0.864	0.864						
Time															
Adjust Span		Reading	16.00	16.00	ppm	15.54	15.54	15.54	15.54	ppm C ₂ H ₆	ppm				
Initial Gain		153.2 ppm	152.8 ppm	152.8 ppm	14.86 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	ppm C ₂ H ₆	ppm				
Final Gain		1.150	1.019	1.019	0.865	0.865	0.865	0.865	0.865						
Time															
Check Zero		Reading	3.8 ppm	0.6 ppm	ppm	-0.06 % Vol	0.01 % Vol	0.01 % Vol	0.01 % Vol	ppm C ₂ H ₆	ppm				
Zero Drift		3.8 ppm	0.6 ppm	0.0 ppm	ppm	-0.06 % Vol	0.0 % Vol	0.0 % Vol	0.0 % Vol	ppm C ₂ H ₆	0.0 ppm				
Acceptance			Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range	Accept <2% of range						
GAS CALIBRATION LOG - SAMPLING SYSTEM CHECK - FLOW METHOD															
Expected Flow:		CO	NO	NOx	O ₂										
Time		ppm	ppm	ppm	ppm										
Leak check		ppm	ppm	ppm	ppm										
Pass/fail															
GAS CALIBRATION LOG - SAMPLING SYSTEM CHECK - CYLINDER METHOD															
Span Value:		SO ₂	CO	NO	NOx	O ₂	CO ₂	CO	ppm	YOCs	N ₂ O				
Time		0.0 ppm	153.2 ppm	152.8 ppm	0.0 ppm	14.9 % Vol	15.2 % Vol	15.2 % Vol	15.2 % Vol	0.0 ppm C ₂ H ₆	0.0 ppm				
Check Zero		Reading	2.8 ppm	0.1 ppm	ppm	-0.10 % Vol	0.00 % Vol	0.00 % Vol	0.00 % Vol	ppm C ₂ H ₆	ppm				
Pass/fail		PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS						
Time															
Check Span		Reading	16.12	16.12	ppm	14.83 % Vol	15.29 % Vol	15.29 % Vol	15.29 % Vol	ppm C ₂ H ₆	ppm				
Response Time:sec		60 sec	60 sec	60 sec	sec	64 sec	64 sec	64 sec	64 sec	sec	sec				
Pass/fail		PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS						
GAS CALIBRATION LOG - DRIFT CHECK (direct to analyser)															
Span Value:		SO ₂	CO	NO	NOx	O ₂	CO ₂	CO	ppm	YOCs	N ₂ O				
Time		0.0 ppm	153.2 ppm	152.8 ppm	0.0 ppm	14.86 % Vol	15.24 % Vol	15.24 % Vol	15.24 % Vol	0.0 ppm C ₂ H ₆	0.0 ppm				
Check Zero		Reading	2.8 ppm	0.0 ppm	ppm	-0.03 % Vol	0.03 % Vol	0.03 % Vol	0.03 % Vol	ppm C ₂ H ₆	ppm				
Reg Pressure (N ₂)						160									
Time															
Check Span		Reading	17.53	17.53	ppm	14.83 % Vol	15.25 % Vol	15.25 % Vol	15.25 % Vol	ppm C ₂ H ₆	ppm				
Reg Pressure		140	140	140	ppm	130	130	130	130						
Zero Drift (6s)		1.8	1.8	0.0	ppm	0.2	0.2	0.2	0.2	ppm C ₂ H ₆	ppm				
Span Drift (6s)		1.2	1.2	0.3	ppm	0.1	0.1	0.1	0.1	ppm C ₂ H ₆	ppm				
Acceptance zero		Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept				
Acceptance span		Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept	Accept				

CALIBRATION TO BE CARRIED OUT BY OR UNDER THE SUPERVISION OF MCERTS QUALIFIED PERSONNEL WITH LEVEL TWO AND TEA

Name:	Matthew Ellison	Personnel Present:	
MCERTS ID:	MM-05-682		NRE/RPL

2.2.6 - Uncertainty Calculations

SCV 1A Uncertainty Calculations

Uncertainty calculation for Gaseous Measurement NOx EN14792 - PG-250 (AS0450)- SRM Version
v3.6
Feb-15

Limit value	107	mg/m ³ (corrected) NOx	Cal gas conc	313.70	mg/m ³ (NO ₂)
Measured concentration	50.95	mg/m ³ (101.3kPa, 273K)	Full Scale	513.25	mg/m ³ (NO ₂)
Measured concentration	105.80	mg/m ³ (Corrected)			
NO/NO2 ratio	100.00		Gas	NO	
			Full Scale	250	ppm
			Cal gas conc	152.8	ppm
			Conversion	2.053	

Performance characteristics	Value	Specification
Response time	65	seconds
Logger sampling interval	60	seconds
Measurement period	60	minutes
Number of readings in measurement	60	
Repeatability at zero	0.02	% full scale
Repeatability at span level	0.02	% full scale
Deviation from linearity(lack of fit)	0.47	% full scale
Zero drift	0	mg/m ³
Span drift	0	mg/m ³
volume or pressure flow dependence	0.36	% full scale
atmospheric pressure dependence	-0.16	% full scale /2kPa
ambient temperature dependence	-2.43	% full scale/10K
Cross sensitivity	0.5	% full scale
dependence on voltage	-0.1	% full scale/10V
losses in the line (leak)	0	% Value
Converter efficiency	95.1	%
Uncertainty of calibration gas	1	% value

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	U ₀	use rep at span
Standard deviation of repeatability at span level	U _s	for mean
Lack of fit	U _{li}	for mean
Drift	U _{dr}	
volume or pressure flow dependence	U _{vol}	
atmospheric pressure dependence	U _{atm}	
ambient temperature dependence	U _{temp}	
Cross sensitivity	U _{cross}	
dependence on voltage	U _{volt}	
losses in the line (leak)	U _{leak}	
Uncertainty of calibration gas	U _{cal}	
converter efficiency	U _{conv}	
Uncertainty in factor	uf	

Measurement uncertainty			
Combined uncertainty	k =	2	3.85
Expanded uncertainty			7.69
Uncertainty corrected to std conds			21.86
Expanded uncertainty	expressed with a level of confidence of 95%		21.86 mg.m ⁻³
Expanded uncertainty	expressed with a level of confidence of 95%		20.66 % value
Expanded uncertainty	expressed with a level of confidence of 95%		7.19 % ELV

Correction for reference conditions				
	102, %	Moisture, %	Pressure, kPa	Temperature, K
ref		3.00	101.30	273.00
measured	12.33	0.00	101.30	273.00
Uncert		0.61	0.00	0.00
Factors	2.08	1.00	1.00	1.00
Uncertainty in factor	0.15	0.01	0.00	0.00
Correction Factor	2.08	1uf	0.15	0.15

Effect of drift	0.00 mg/m3
-----------------	------------

	ranges	min	max	value at calib
flow	0.4	0.4		0.4 l/min
pressure	102.2	102.3		102.22 kPa
temp	290	294		290 K
Voltage	93	121		110 V

Uncertainty calculation for gaseous measurement of CO under BS EN 15058:2017 - AS0450 (PG-250)
v4.2 Sep-17

Limit value	N/A	mg/m ³ (corrected)	Cal gas conc	191.50 mg.m ⁻³
Measured concentration	131.07	mg/m ³ (101.3kPa, 273K)	Full Scale	250.00 mg/m ³
Measured concentration	272.15	mg/m ³ (Corrected)	Gas	CO
			Full Scale	200 ppm
			Cal gas conc	153.2 ppm
			Conversion	1.25

Correction for reference conditions				
	ref	O2, %	Moisture, %	Pressure, kPa
	measured	12.33	3.00	101.30
	Uncert	0.61	0.00	101.30
Factors		2.08	1.00	0.00
Uncertainty in factor		0.15	0.01	0.00
Correction factor		2.08	uf	0.15

Performance characteristics	Value	specification
Response time	60	seconds
Logger sampling interval	60	seconds
Measurement period	60	minutes
Number of readings in measurement	60	
Repeatability at zero	0.09	% full scale
Repeatability at span level	0.08	% full scale
Deviation from linearity(lack of fit)	0.71	% full scale
Zero drift	0	mg/m ³
Span drift	0	mg/m ³
Influence of sample flow	-0.27	% full scale
Influence of atmospheric pressure	0.09	% full scale /2kPa
Influence of ambient temperature at zero	1.48	% full scale/10K
Influence of ambient temperature at span	-1.33	% full scale/10K
Gross sensitivity	0.1	% full scale
Influence of voltage	0.33	% full scale/10V
Losses in the line (leak)	0	% value
Uncertainty of calibration gas	1	% value

Effect of drift	0.00 mg/m ³
-----------------	------------------------

	ranges	min	max	value at calib
flow	0.4	0.4	0.4	0.4 l/min
pressure	102.2	102.3	102.22	kPa
spare				
temp	290	294	290	K
Voltage	93	121	110	V

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	U ₀	for mean
Standard deviation of repeatability at span level	U _s	for mean
Lack of fit	U _{lin}	
Drift	U _{dr}	
Influence of sample flow	U _{spres}	
Influence of atmospheric pressure	U _{mpres}	
Influence of ambient temperature zero	U _{temp0}	
Influence of ambient temperature span	U _{temp1}	
Gross sensitivity	U _{nsert}	
Influence of voltage	U _{vol}	
Losses in the line (leak)	U _{leak}	
Uncertainty of calibration gas	U _{cal}	
Uncertainty in factor	uf	19.20

Measurement uncertainty			
Combined uncertainty	k =	2	1.70
Expanded uncertainty			3.39
Uncertainty corrected to sid conds			39.03
Expanded uncertainty expressed with a level of confidence of 95%			39.03 mg.m ³
Expanded uncertainty expressed with a level of confidence of 95%			14.34 % value
Expanded uncertainty expressed with a level of confidence of 95%			N/A % ELV

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for Gaseous Measurement O2 EN14789 - PG-250 AS0450 SRM
v3.0 Feb-15

Limit value	N/A	Cal gas conc	14.86 % vol
Measured concentration	12.33 % vol	Full Scale	25.00 % vol

Performance characteristics	Value	specification
Response time	65 seconds	≤200 seconds
Logger sampling interval	60 seconds	
Measurement period	61 minutes	
Number of readings in measurement	61	
Repeatability at zero	0.01 % range	≤±0.2 % range
Repeatability at span level	0.02 % range	≤±0.4 % range
Deviation from linearity(lack of fit)	0.2 % vol	<0.3 % vol
Zero drift	0.25 % vol	<5% span value
Span drift	0.22 % vol	<5% span value
volume or pressure flow dependence	0.08 % range	<1% range
atmospheric pressure dependence	0.91 % full scale /kPa	≤±1.5 % range/kPa
ambient temperature dependence	0.19 % vol/10K	≤±0.3 % vol/10K
Cross Sensitivity	0.2 % vol	≤±0.2 % vol
dependence on voltage	0.05 % vol/10V	≤±0.1% vol/10V
losses in the line (leak)	0 % value	≤± 2% of value
Uncertainty of calibration gas	1 % value	≤± 2% of value

Effect of drift	0.43 % vol
-----------------	------------

	ranges min	max	value at calib
flow pressure	0.4	0.4	0.4 l/min
temp	102.2	102.3	102.22 kPa
	290	294	290 K
Voltage	93	121	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity	% vol
Standard deviation of repeatability at zero	u _{io}	for mean	use rep at span
Standard deviation of repeatability at span level	u _{rs}	for mean	0.00
Lack of fit	u _{fit}		0.12
Drift	u _{odr}		0.25
volume or pressure flow dependence	u _{apress}		0.00
atmospheric pressure dependence	u _{apress}		0.01
ambient temperature dependence	u _{temp}		0.04
Cross Sensitivity	u _{interf}		0.11
Dependence on voltage	u _{volt}		0.04
losses in the line (leak)	u _{leak}		0.00
Uncertainty of calibration gas	u _{cal}		0.07

Measurement uncertainty			% vol
Combined uncertainty	0.31		% vol
Expanded uncertainty	0.62		% vol
	k = 2		
Expanded uncertainty	expressed with a level of confidence of 95%	0.62 % vol	
Expanded uncertainty	expressed with a level of confidence of 95%	5.04 % value	

SCV 2A Uncertainty Calculations

Uncertainty calculation for Gaseous Measurement NOx EN14792 - PG-250 (AS0450)- SRM Version
v3.6
Feb-15

Limit value	107 mg/m ³ (corrected) NOx	Cal gas conc	313.70 mg.m ⁻³ (NO ₂)
Measured concentration	17.72 mg/m ³ (101.3kPa, 273K)	Full Scale	513.25 mg/m ³ (NO ₂)
Measured concentration	36.61 mg/m ³ (Corrected)		
NO/NO2 ratio	100.00	Gas	NO
		Full Scale	250 ppm
		Cal gas conc	152.8 ppm
		Conversion	2.053

Performance characteristics	Value	specification
Response time	65 seconds	≤200
Logger sampling interval	60 seconds	
Measurement period	61 minutes	
Number of readings in measurement	61	
Repeatability at zero	0.02 % full scale	≤±1 % range
Repeatability at span level	0.02 % full scale	≤±2 % range
Deviation from linearity(lack of fit)	0.47 % full scale	≤±2 % range
Zero drift	0	
Span drift	0.21 mg/m ³	≤-5% span value
volume or pressure flow dependence	0.36 % full scale	
atmospheric pressure dependence	-0.16 % full scale /2kPa	≤±3 % range/2kPa
ambient pressure dependence	-2.43 % full scale/10K	≤±3 % range/10K
ambient temperature dependence	0.5 % full scale	≤-4 % range
Cross sensitivity	-0.1 % full scale/10V	≤±2% range/10V
dependence on voltage	0 % value	≤± 2% of value
losses in the line (leak)	95.1 %	≥95%
Converter efficiency	1	≤± 2% of value
Uncertainty of calibration gas		

Performance characteristic	Uncertainty	Value of uncertainty quantity	mg/m3
Standard deviation of repeatability at zero	U ₀	for mean	use rep at span
Standard deviation of repeatability at span level	U _{rs}	for mean	0.01
Lack of fit	U _{lin}		1.39
Drift	U _{dr}		0.01
volume or pressure flow dependence	U _{press}		0.00
atmospheric pressure dependence	U _{press}		-0.02
ambient pressure dependence	U _{temp}		-2.88
Cross sensitivity	U _{temp}		1.48
Dependence on voltage	U _{leak}		-0.44
losses in the line (leak)	U _{leak}		0.00
Uncertainty of calibration gas	U _{cal}		0.10
converter efficiency	U _{conv}		0.50
Uncertainty in factor	uf		1.73

Measurement uncertainty			mg/m ³
Combined uncertainty		3.59	mg/m ³
Expanded uncertainty	k = 2	7.18	mg/m ³
Uncertainty corrected to std conds		15.24	mg/m ³
Expanded uncertainty	expressed with a level of confidence of 95%	15.24 mg.m ⁻³	
Expanded uncertainty	expressed with a level of confidence of 95%	41.62 % value	
Expanded uncertainty	expressed with a level of confidence of 95%	6.71 % ELV	

Correction for reference conditions				
	02, %	Moisture, %	Pressure, kPa	Temperature, K
ref	3.00	0.00	101.30	273.00
measured	12.29	0.00	101.30	273.00
Uncert	0.41	1.00	0.00	0.00
Factors	2.07		1.00	1.00
Uncertainty in factor	0.10	0.01	0.00	0.00
Correction Factor	2.07	uf	0.10	

Effect of drift	0.01 mg/m3
-----------------	------------

	ranges	max	value at calib
flow	0.4	0.4	0.4 l/min
pressure	102.2	102.3	102.22 kPa
temp	290	294	290 K
Voltage	93	121	110 V

Uncertainty calculation for gaseous measurement of CO under BS EN 15058:2017 - AS0450 (PG-250)
v4.2 Sep-17

Limit value	N/A	mg/m ³ (corrected)	Cal gas conc	191.50	mg·m ⁻³
Measured concentration	347.49	mg/m ³ (101.3kPa, 273K)	Full Scale	250.00	mg/m ³
Measured concentration	718.23	mg/m ³ (Corrected)	Gas	CO	
			Full Scale	200	ppm
			Cal gas conc	153.2	ppm
			Conversion	1.25	

Correction for reference conditions				
	ref	O ₂ , %	Moisture, %	Pressure, kPa
	measured	12.29	0.00	101.30
	Uncert	0.41	1.00	0.00
Factors		2.07	1.00	1.00
Uncertainty in factor		0.10	0.01	0.00
Correction Factor		2.07	uf	0.10

Performance characteristics	Value	specification
Response time	60	seconds
Logger sampling interval	60	seconds
Measurement period	60	minutes
Number of readings in measurement	60	
Repeatability at zero	0.09	% full scale
Repeatability at span level	0.08	% full scale
Deviation from linearity(lack of fit)	0.71	% full scale
Zero drift	2.01	mg/m ³
Span drift	3.75	mg/m ³
Influence of sample flow	-0.27	% full scale
Influence of atmospheric pressure	0.09	% full scale /2kPa
Influence of ambient temperature at zero	1.48	% full scale/10K
Influence of ambient temperature at span	-1.33	% full scale/10K
Cross sensitivity	0.1	% full scale
Influence of voltage	0.33	% full scale/10V
Losses in the line (leak)	0	% value
Uncertainty of calibration gas	1	% value

Effect of drift	8.81	mg/m ³
-----------------	------	-------------------

	ranges	max	value at calib
flow	min	0.4	0.4 l/min
pressure		102.2	102.22 kPa
spare			
temp		290	290 K
Voltage		93	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	U ₀	for mean
Standard deviation of repeatability at span level	U _s	for mean
Lack of fit	U _{li}	
Drift	U _{dr}	
Influence of sample flow	U _{spres}	
Influence of atmospheric pressure	U _{spres}	
Influence of ambient temperature zero	U _{temp0}	
Influence of ambient temperature span	U _{temp1}	
Cross sensitivity	U _{inter1}	
Influence of voltage	U _{vol}	
Losses in the line (leak)	U _{leak}	
Uncertainty of calibration gas	U _{cal}	
Uncertainty in factor	uf	33.99

Measurement uncertainty			
Combined uncertainty	5.88	mg/m ³	
Expanded uncertainty	11.35	mg/m ³	
	2		
Uncertainty corrected to std conds	71.92	mg/m ³	
Expanded uncertainty	expressed with a level of confidence of 95%	71.92	mg·m ⁻³
Expanded uncertainty	expressed with a level of confidence of 95%	10.01	% value
Expanded uncertainty	expressed with a level of confidence of 95%	N/A	% ELV

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for Gaseous Measurement O2 EN14789 - PG-250 AS0450 SRM

v3.0 Feb-15

Limit value	N/A	Cal gas conc	14.86 % vol
Measured concentration	12.29 % vol	Full Scale	25.00 % vol

Performance characteristics		Value	specification
Response time		65 seconds	≤200 seconds
Logger sampling interval		60 seconds	
Measurement period		61 minutes	
Number of readings in measurement		61	
Repeatability at zero		0.01 % range	≤±0.2 % range
Repeatability at span level		0.02 % range	≤±0.4 % range
Deviation from linearity(lack of fit)		0.2 % vol	<0.3 % vol
Zero drift		0.1 % vol	<5% span value
Span drift		0.07 % vol	<5% span value
volume or pressure flow dependence		0.08 % range	<1% range
atmospheric pressure dependence		0.91 % full scale /kPa	≤±1.5 % range/kPa
ambient temperature dependence		0.19 % vol/10K	≤±0.3 % vol/10K
Gross Sensitivity		0.2 % vol	≤±0.2 % vol
dependence on voltage		0.05 % vol/10V	≤±0.1% vol/10V
losses in the line (leak)		0 % value	≤± 2% of value
Uncertainty of calibration gas		1 % value	≤± 2% of value

Effect of drift	0.16 % vol
-----------------	------------

ranges		min	max	value at calib
flow pressure temp		0.4	0.4	0.4 l/min
		102.2	102.3	102.22 kPa
		290	294	290 K
Voltage		93	121	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity	
		for mean	use rep at span
Standard deviation of repeatability at zero	U_{r0}		
Standard deviation of repeatability at span level	U_{rs}		0.00
Lack of fit	U_{fit}		0.12
Drift	U_{dr}		0.09
volume or pressure flow dependence	U_{agres}		0.00
atmospheric pressure dependence	U_{agres}		0.01
ambient temperature dependence	U_{temp}		0.04
Gross Sensitivity	$U_{sensitivity}$		0.11
Dependence on voltage	U_{volt}		0.04
losses in the line (leak)	U_{leak}		0.00
Uncertainty of calibration gas	U_{cal}		0.07

Measurement uncertainty				% vol
Combined uncertainty			0.21	% vol
Expanded uncertainty	k = 2		0.41	% vol
Expanded uncertainty	expressed with a level of confidence of 95%		0.41 % vol	
Expanded uncertainty	expressed with a level of confidence of 95%		3.36 % value	

SCV 2F Uncertainty Calculations

Uncertainty calculation for Gaseous Measurement NOx EN14792 - PG-250 (AS0450)- SRM Version
v3.6 Feb-15

Limit value	107 mg/m ³ (corrected) NOx	Cal gas conc	313.70 mg.m ⁻³ (NO ₂)
Measured concentration	19.20 mg/m ³ (101.3kPa, 273K)	Full Scale	513.25 mg/m ³ (NO ₂)
Measured concentration	42.43 mg/m ³ (Corrected)		
NO/NO ₂ ratio	100.00	Gas	NO
		Full Scale	250 ppm
		Cal gas conc	152.8 ppm
		Conversion	2.053

Performance characteristics	Value	specification
Response time	65 seconds	≤200 seconds
Logger sampling interval	60 seconds	
Measurement period	61 minutes	
Number of readings in measurement	61	
Repeatability at zero	0.02	≤±1 % range
Repeatability at span level	0.02	≤±2 % range
Deviation from linearity(lack of fit)	0.47	≤±2 % range
Zero drift	0	
Span drift	0.82	≤5% span value
volume or pressure flow dependence	0.36	
atmospheric pressure dependence	-0.16	≤±3 % range/2kPa
ambient temperature dependence	-2.43	≤±3 % range/10K
Cross sensitivity	0.5	≤4 % range
dependence on voltage	-0.1	≤±2% range/10V
losses in the line (leak)	0	≤± 2% of value
Converter efficiency	95.1	≥95%
Uncertainty of calibration gas	1	≤± 2% of value

Performance characteristic	Uncertainty	Value of uncertainty quantity	mg/m3
Standard deviation of repeatability at zero	U ₀	for mean	use rep at span
Standard deviation of repeatability at span level	U _{rs}	for mean	0.01
Lack of fit	U _{lin}		1.39
Drift	U _{dr}		0.03
volume or pressure flow dependence	U _{press}		0.00
atmospheric pressure dependence	U _{press}		-0.02
ambient temperature dependence	U _{temp}		-2.88
Cross sensitivity	U _{interi}		1.48
Dependence on voltage	U _{leak}		-0.44
losses in the line (leak)	U _{leak}		0.00
Uncertainty of calibration gas	U _{cal}		0.11
converter efficiency	U _{conv}		0.54
Uncertainty in factor	uf		1.99

Measurement uncertainty			
Combined uncertainty	k =	2	3.60 mg/m ³
Expanded uncertainty			7.19 mg/m ³
Uncertainty corrected to std conds			16.39 mg/m ³
Expanded uncertainty	expressed with a level of confidence of 95%		16.39 mg.m ⁻³
Expanded uncertainty	expressed with a level of confidence of 95%		38.61 % value
Expanded uncertainty	expressed with a level of confidence of 95%		6.72 % ELV

Correction for reference conditions				
	102.1 %	Moisture, %	Pressure, kPa	Temperature, K
	ref	3.00	0.00	101.30
	measured	12.85	0.00	101.30
	Uncert	0.38	1.00	0.00
		2.21	1.00	1.00
Factors				
Uncertainty in factor		0.10	0.01	0.00
Correction Factor		2.21 uf		0.10

Effect of drift	0.05 mg/m3
-----------------	------------

	ranges	min	max	value at calib
flow	0.4		0.4	0.4 l/min
pressure	102.2	102.3	102.22	102.22 kPa
temp	290	294	290	290 K
Voltage	93	121	110	110 V

Uncertainty calculation for gaseous measurement of CO under BS EN 15058:2017 - AS0450 (PG-250)
v4.2 Sep-17

Limit value	N/A	mg/m ³ (corrected)	Cal gas conc	191.50 mg.m ⁻³
Measured concentration	283.01	mg/m ³ (101.3kPa, 273K)	Full Scale	250.00 mg/m ³
Measured concentration	514.89	mg/m ³ (Corrected)		
			Gas	CO
			Full Scale	200 ppm
			Cal gas conc	153.2 ppm
			Conversion	1.25

Correction for reference conditions				
	ref	O ₂ , %	Moisture, %	Pressure, kPa
	measured	3.00	0.00	101.30
	Uncert	12.85	0.00	101.30
		0.38	1.00	0.00
Factors		2.21	1.00	1.00
Uncertainty in factor		0.10	0.01	0.00
Correction factor		2.21	uf	0.10

Performance characteristics	Value	specification
Response time	60 seconds	≤200
Logger sampling interval	60 seconds	
Measurement period	61 minutes	
Number of readings in measurement	61	
Repeatability at zero	0.09 % full scale	≤±2 % range
Repeatability at span level	0.08 % full scale	≤±2 % range
Deviation from linearity(lack of fit)	0.71 % full scale	≤±2 % range
Zero drift	3.75 mg/m ³	<-5% span value
Span drift	2.54 mg/m ³	<-5% span value
Influence of sample flow	-0.27 % full scale	≤±2 % range
Influence of atmospheric pressure	0.09 % full scale /2kPa	≤±2 % range
Influence of ambient temperature at zero	1.48 % full scale/10K	≤±5 % range
Influence of ambient temperature at span	-1.33 % full scale/10K	≤±5 % range
Gross sensitivity	0.1 % full scale	<-4 % range
Influence of voltage	0.33 % full scale/10V	≤±2 % range
Losses in the line (leak)	0 % value	≤±2% of value
Uncertainty of calibration gas	1 % value	≤±2% of value

Effect of drift	6.84 mg/m ³
-----------------	------------------------

	ranges	max	value at calib
flow	0.4	0.4	0.4 l/min
pressure	102.2	102.3	102.22 kPa
temp	290	294	290 K
Voltage	93	121	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	U ₀	for mean
Standard deviation of repeatability at span level	U _s	for mean
Lack of fit	U _{fit}	
Drift	U _{dr}	
Influence of sample flow	U _{press}	
Influence of atmospheric pressure	U _{temp}	
Influence of ambient temperature zero	U _{temp}	
Influence of ambient temperature span	U _{temp}	
Gross sensitivity	U _{inert}	
Influence of voltage	U _{leak}	
Losses in the line (leak)	U _{cal}	
Uncertainty of calibration gas		
Uncertainty in factor	uf	24.13

Measurement uncertainty			
Combined uncertainty	k =	2	4.44 mg/m ³
Expanded uncertainty			8.88 mg/m ³
Uncertainty corrected to std conds			52.10 mg/m ³
Expanded uncertainty expressed with a level of confidence of 95%			52.10 mg.m ⁻³
Expanded uncertainty expressed with a level of confidence of 95%			10.12 % value
Expanded uncertainty expressed with a level of confidence of 95%			N/A % ELV

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for Gaseous Measurement O2 EN14789 - PG-250 AS0450 SRM
v3.0 Feb-15

Limit value	N/A	Cal gas conc	14.86 % vol
Measured concentration	12.85 % vol	Full Scale	25.00 % vol

Performance characteristics		Value		specification	
Response time		64		seconds	≤200
Logger sampling interval		60		seconds	
Measurement period		61		minutes	
Number of readings in measurement		61			
Repeatability at zero		0.01		% range	≤±0.2 % range
Repeatability at span level		0.02		% range	≤±0.4 % range
Deviation from linearity(lack of fit)		0.2		% vol	<0.3 % vol
Zero drift		0.03		% vol	<5% span value
Span drift		0.03		% vol	<5% span value
volume or pressure flow dependence		0.08		% range	<1% range
atmospheric pressure dependence		0.91		% full scale /kPa	≤±1.5 % range/kPa
ambient temperature dependence		0.19		% vol/10K	≤±0.3 % vol/10K
Gross Sensitivity		0.2		% vol	≤±0.2 % vol
dependence on voltage		0.05		% vol/10V	≤±0.1% vol/10V
losses in the line (leak)		0		% value	≤± 2% of value
Uncertainty of calibration gas		1		% value	≤± 2% of value

Effect of drift	0.06 % vol
-----------------	------------

ranges		max		value at calib	
min		0.4		0.4	0.4 l/min
	flow pressure	102.2		102.3	102.22 kPa
	temp	290		294	290 K
	Voltage	93		121	110 V

Performance characteristic		Uncertainty	Value of uncertainty quantity		% vol use rep at span
Standard deviation of repeatability at zero	Standard deviation of repeatability at span level	u_0	for mean		
		u_{rs}	for mean		0.00
Lack of fit		u_{fit}			0.12
		u_{dr}			0.03
volume or pressure flow dependence	atmospheric pressure dependence	u_{apress}			0.00
		u_{apress}			0.01
		u_{temp}			0.04
		$u_{linearf}$			0.11
Cross Sensitivity	Dependence on voltage	u_{volt}			0.04
		u_{leak}			0.00
losses in the line (leak)					
Uncertainty of calibration gas		u_{cal}			0.07

Measurement uncertainty				
Combined uncertainty			0.19	% vol
Expanded uncertainty	k = 2		0.38	% vol
Expanded uncertainty	expressed with a level of confidence of 95%		0.38 % vol	
Expanded uncertainty	expressed with a level of confidence of 95%		2.94 % value	

2.2.7 - Calculations Used in Reporting Results

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Nozzle Selection

For isokinetic sampling, the pressure difference of the orifice meter must equal the pressure difference of the Pitot tube pressure multiplied by the K-factor. Where:

$$K = \text{Constant} \times C_p^2 \times D_n^4 \times DH_{@} \times \left(\frac{M_d}{M_s} \right) \left(\frac{1 - B_{wm}}{1 - B_{ws}} \right)^2 \left(\frac{T_m + 273}{T_s + 273} \right) \left(\frac{P_s}{P_m} \right)$$

$$DH = K \times D_p$$

Where:-

Constant: is a constant dependent on the units used to measure the nozzle (8.038×10^{-5} for mm)

D_n the nozzle diameter mm

$DH_{@}$ a constant dependent on the sampler control box orifice and gas meter

B_{ws} the percent water vapour in the emission as a fraction i.e. 12% = 0.12

B_{wm} the percentage water vapour in the air around the meter box often assumed to be zero

C_p Pitot tube coefficient dependent on the Pitot tube type

T_m the meter temperature in °C

T_s the stack temperature in °C

P_s the stack pressure

P_m the meter pressure

M_d dry gas molecular weight

M_s apparent stack gas molecular weight

DH pressure drop across the orifice (mm water)

DP differential Pitot pressure (mm water)

From this the correct nozzle size can be determined.

$$D_n = \sqrt{\left(\frac{\text{Constant} \cdot Q_m \cdot P_m}{(T_m + 273) C_p} \right) \left(\frac{1 - B_{wm}}{1 - B_{ws}} \right) \sqrt{\frac{(T_s + 273) M_s}{(P_s \cdot (\Delta P)_{avg})}}}$$

Where the Constant = 0.6071 Metric

Q_m = Orifice flow rate normally 21.2 actual lmin⁻¹

$$= K_m \sqrt{\frac{(T_m + 273) \Delta H}{P_m M_m}}$$

Where K_m = Orifice meter coefficient

$$K_m = Q_m \sqrt{\frac{P_m M_m}{\Delta H (T_m + 273)}} = \text{Const} \sqrt{\frac{1}{\Delta H_{@}}}$$

Where Const = 183.7 metric

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Moisture Determination Calculations

These calculations are based at 273K and 101.325kPa

To calculate moisture the following equation is used:

$$B_{ws} = \frac{0.001245 \times W_I \times 100}{(0.001245 \times W_I) + 0.359V_m \left(\frac{P_b + \frac{\Delta H_{avg}}{13.6}}{(T_m + 273)} \right)}$$

Particulate Concentration C_s in stack Gases

At 273K and 101.325kPa and dry gas

$$C_s = \frac{W_t}{V_m} \times \frac{T_m + 273}{273} \times \frac{760}{\left(P_b + \frac{\Delta H_{avg}}{13.6} \right)} \times 1000 \quad \text{mg/Nm}^3$$

Oxygen Concentration Correction C_{oxy} to Particulate concentration

$$C_{oxy} = C \times \frac{(20.9 - \%O_2 \text{ref})}{(20.9 - \%O_2 \text{Meas})} \quad \text{mg/Nm}^3$$

Dry Molecular Weight of gases

$$M_D = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%CO + \%N)$$

Stack Molecular Weight of gases

$$M_s = 0.18(B_{ws}) + \frac{M_d}{100}(100 - B_{ws})$$

Stack Gas Velocity

$$(V_s)_{avg} = 34.96 \times C_p \times \sqrt{(\Delta P)_{avg}} \sqrt{\frac{T_s + 273}{P_s M_s}} \quad \text{m/s}$$

Mass Emission Rate M_R

$$M_R = \frac{C_m \times (V_s)_{avg} \times A \times 3600}{10^6} \quad \text{kg/hr}$$

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

IsoKinicity

$$I = \frac{2.12 \times 10^8 \times V_m \times Y \times \left(P_b + \left(\frac{\Delta H_{avg}}{13.6} \right) \right) \left(\frac{273 + T_s}{273 + T_m} \right)}{\Theta P_s \pi D_n^2 (V_s)_{avg} (100 - B_{ws})} \%$$

W_I	= the weight change of the impingers during sampling in g
V_m	= volume of dry gas sample in litres at temperature of the meter box
B_{ws}	= the percent water vapour in the emission
Q	= length of time sampling in minutes
Y	= Gas Meter Calibration correction factor
V_s	= Velocity of stack gas m/s
C_M	= measured concentration of particulate matter (mg/m ³)
T_m	= average temperature at dry gas meter (°C)
P_b	= atmospheric pressure (mmHg)
$\%O_{2ref}$	= % oxygen at standard temperature & pressure
$\%O_{2Meas}$	= % oxygen measured on site
C_P	= Pitot tube coefficient
DP	= mean differential Pitot pressure drop (mm H ₂ O)
DH	= mean orifice pressure drop (mm H ₂ O)
D_s	= diameter of stack (m)
D_n	= Nozzle diameter (mm)
T_s	= stack temperature (°C)
M_d	= molecular weight of dry stack gas
B_w	= moisture fraction
P_s	= stack pressure (mmHg)
A	= duct c.s.a. (m ²)
M_s	= molecular weight of wet stack gas
M_d	= molecular weight of dry stack gas
W_t	= total weight of particulate matter (g)