

Dragon LNG Limited  
Dragon LNG  
Waterson  
Milford Haven  
Pembrokeshire  
SA73 1DR

Dear Mr Howells,

**Environmental Permitting (England and Wales) Regulations 2016**  
**Permit Number AP3136UA - Improvement Condition IC 9.9**

In response to Dragon's letter dated 8 March 2017, we have reviewed the request to extend the deadline for the IC9.9 response which states that:

The Operator shall implement and install physical improvements as detailed in the energy and efficiency improvement plan submitted to NRW in IC9.8 from the date approved by NRW, to maximise energy efficiency from the installation specifically at low or zero send out operating conditions, unless otherwise agreed in writing by NRW.

On the 22 of July 2016 Dragon identified in response to IC9.8, that the Large Combustion Plant (Cogen) was operating at an efficiency between 30 - 33% which is based on the operating data and specifically when the Cogen is on gas send out. In regards to Dragon's proposal to improve the efficiency, it has been proposed to introduce the re liquefaction plant, and to cease operation of the Cogen. Based on this proposal, NRW will agree to extend the response to IC 9.9 until 31 December 2017.

Following the submission of IC 9.9 NRW will review the emission limits on the Cogen.

If you have any questions about this letter, please phone me on 03000 653237 or email me at [gary.l.evans@naturalresourceswales.gov.uk](mailto:gary.l.evans@naturalresourceswales.gov.uk).

Yours faithfully,



Gary Evans  
**Technical Specialist**