

RECEIVED

17 APR 2014

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	BV3715IL
Name of operator	SCA Hygiene UK Ltd
Location of Facility	Chester Road, Oakenholt, Flintshire, CH6 5PU
Time and date of the detection	16 Apr 2014

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Date and time of the event	07 April 2014
Reference or description of the location of the event	Total Nitrogen tested to be 30mg/l (permit limit 16mg/l). Tested by external UKAS lab.
Description of where any release into the environment took place	W1 – continuous discharge.
Substances(s) potentially released	All other tests within permit consent limits
Best estimate of the quantity or rate of release of substances	1581 m3 effluent discharged between 06/04/2014 04:00 and 07/04/2014 04:00
Measures taken, or intended to be taken, to stop any emission	None
Description of the failure or accident.	Treated effluent out of consent with Total Nitrogen

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below

Emission point reference/ source	W1
Parameter(s)	16mg/l
Limit	16mg/l

OK FOR PUBLIC REGISTER

COPIED TO PUBLIC REGISTER

INITIALS

DATE

JB

29/4/14

JB

EDRM

Measured value and uncertainty	30mg/l
Date and time of monitoring	07 April 2014 (24 hour composite sample)
Measures taken, or intended to be taken, to stop the emission	None

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	None known / anticipated
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	



A. CORBETT

17.4.2014

QUALITY + ENV LEADER.