

Schedule 5 - Notification


These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part B - to be submitted as soon as practicable – Fire PM2 27.02.2015

Any more accurate information on the matters for notification under Part A.	A stray ember slowly crept its way along the cable tray to the corner of the building, and ignited paper dust.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	In the interim Increased cleaning has been implemented. Corrective action is to install fire breaks to stop the fires spreading throughout the machine hall. Also there is an action plan for the hoods to try and stop the stray embers. Dust extraction is due to be installed in the reel end section by the end of 2015.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Water used to extinguish the fire was contained on site and treated through the Effluent Treatment Plant
The dates of any unauthorised emissions from the facility in the preceding 24 months.	21.07.2013, 27.07.2013, 22.10.2013, 10.02.2014, 07.04.2014, 02.02.2015, 27.02.2015, 28.05.2015, 01.06.2015

Name*	Alana Corbett
Post	Quality / Environmental Leader
Signature	
Date	25 Aug 2015

* authorised to sign on behalf of the operator