

# REGISTER OF CONDITIONS

No. 109/61

AND OTHER TERMS  
 IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951  
 (AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)  
 AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

CAT. No. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
Sixth day of October, 1969	Making of a discharge of sewage effluent from the storm sewage overflow on the combined sewer serving the Lancaster Road, Pontypool redevelopment indicated on Drawing No. 1/1068/2 and the block plan submitted to the small unnamed stream a tributary of the Afon Lwyd.
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) PRECISE LOCATION OF OUTLET</p> <p style="text-align: center;">N/A</p> <p>(ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)</p> <p style="text-align: center;">N/A</p> <p>(iii) USE OF OUTLET</p> <p style="text-align: center;">N/A</p> <p>(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p> <p style="text-align: center;">N/A</p>	<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) NATURE AND COMPOSITION OF DISCHARGE</p> <p style="text-align: center;">The effluent discharged to the stream shall consist only of storm sewage.</p> <p>(ii) TEMPERATURE OF DISCHARGE</p> <p style="text-align: center;">N/A</p> <p>(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES</p> <p style="text-align: center;">P/T/O</p> <p>* (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES</p> <p style="text-align: center;">Unobstructed access to the outlet</p> <p>(v) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT</p> <p style="text-align: center;">Fifth day of January, 1972.</p>
<p>REMARKS-</p> <p>Name and Address of Applicant: Pontypool Urban District Town Hall, Council, Pontypool, Mon.</p> <p>Date of Application: 6th August, 1969.</p>	<p>REMARKS-</p> <p>Clerk's File Ref: C.236</p> <p>Minute relating to this Consent: D.29(iii)(5.9.69) D.19 (7.11.69)</p>

Scanned for DQ Project 2005

\* IF DISCHARGE NOT CONTROLLED UNDER S.7 OF 1951 ACT

Maximum Rate of Discharge:

The rate at which storm sewage effluent is discharged to the stream shall not exceed the rate by which the total flow in the sewer at the overflow is in excess of a rate of 150 gallons per head of the contributing population, i.e. 102,300 gallons per day. At other times, no discharge shall be made, all flows up to the rate equivalent mentioned passing the said overflow to the trunk sewer.