

**Oaktree Environmental Ltd**

Unit 5 Oasis Park,  
19 One Road,  
Winsford,  
Cheshire  
CW7 3RY

**F.A.O. Jan Edwards**

Our ref: 2341.ALJES.DO

Date: 16<sup>th</sup> March 2016

**By EMAIL**

Dear Jan,

**Re: Mona AD Plant – Pipe Bridge Foundations**


Please find attached drawing 2341-PH2-SK-01 which shows the proposed detail where the pipe bridge foundations will abut the containment base.

The pipe bridge bases within part of the containment area will be founded by excavating a strip of asphalt and underlying material and replacing with structural concrete. The pipe bridge supports will be anchored onto this. This approach will enable movement of plant and equipment which would be restricted by above ground foundations.

We are satisfied that the joint between the foundation and the asphalt containment base will be watertight if sealed in accordance with the proposed details and so will not affect the containment integrity.

Please could you seek the agreement of NRW to this proposal.

Yours sincerely,



Jonathan Sykes

**Associate Director**

On behalf of Caulmert Ltd



Certificate Number 9113  
ISO 9001, ISO 14001

**Caulmert Limited**

Registered Office: InTec, Parc Menai, Bangor, Gwynedd, LL57 4FG

Company Registered No. 06716319

Company Registered in Cardiff

