


Releases to Controlled Waters

Annual release summary for the year 2018

Operator: Port Talbot **Release Point:** W1
Location: Port Talbot **Permit:** BL7108

Substance	Annual Release (kg)	Limit (kg)
Suspended solids	1532291	2250000
Oil and grease	66873	360000
Free cyanide	162	2700
Ammoniacal nitrogen	443176	400000
Phenol	639	18000
Soluble lead	649	
Soluble chromium	26	
PAH's*	170	
Total iron	69211	
Soluble iron	9657	
Total aluminum	20810	
Total manganese	21665	
Total zinc	24758	
Soluble zinc	16392	

Signed on behalf of the Operator

..... 

Dated 30-Jan-2019

Form I&S Annual W1

Release summary for the month

Operator: Tata Steel UK Ltd

Release Point: W1 (LSO)

Permit: BL7108

Signed on behalf of the Operator

Dated 24-Jan-2019

Form I&S W1 Monthly

Releases to Controlled Waters

Release summary for the month

November-18

Operator: Tata Steel UK Ltd

Release Point:

W1 (LSO)

Location: Port Talbot

Permit:

BL7108

	S.Solids*	COD	BOD	Sulphides	Thiocyanate	Cyanide	PAH**	Phenols	A+N+N****	Iron	Lead	Zinc	Nickel	Chromium	Oil***	Date	Discharge	Discharge
	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)	Conc. (mg/l)		(m3/hr)	(m3)
Week 1	30.3	41		0.1	0.9	0.00	0.020	0.05	53	1.7	0.0	0.86	0.0	0.0	1.6	01-Nov-18	2926.6	70239.0
																02-Nov-18	3318.1	79634.0
																03-Nov-18	3771.1	90507.0
																04-Nov-18	2637.8	63307.0
																05-Nov-18	1939.2	46541.0
																06-Nov-18	2135.4	51249.0
Week 2	62.9	60		0.1	0.9	0.00	0.040	0.06	87	2.3	0.0	1.4	0.0	0.0	4.4	07-Nov-18	2857.8	68587.0
																08-Nov-18	3841.5	92195.0
																09-Nov-18	4114.6	98749.0
																10-Nov-18	4187.0	100489.0
																11-Nov-18	3228.5	77485.0
																12-Nov-18	3828.9	91894.0
Week 3	20.9	8		0.1	No data	0.00	0.000	0.05	45	0.6	0.0	0.6	0.0	0.0	2.5	13-Nov-18	4258.8	102212.0
																14-Nov-18	4500.4	108010.0
																15-Nov-18	5225.9	125421.0
																16-Nov-18	3370.0	80880.0
																17-Nov-18	3622.4	86938.0
																18-Nov-18	2984.9	71638.0
Week 4	38.9	24		0.1	No data	0.00	0.000	0.09	49	0.8	0.0	1.9	0.0	0.0	3.0	19-Nov-18	3305.6	79334.0
																20-Nov-18	3250.2	78006.0
																21-Nov-18	3006.7	72161.0
																22-Nov-18	3739.4	89745.0
																23-Nov-18	4184.9	100438.0
																24-Nov-18	4475.7	107418.0
Week 5																25-Nov-18	4020.0	96480.0
																26-Nov-18	4473.9	107374.0
																27-Nov-18	4233.4	101601.0
																28-Nov-18	5660.6	135854.0
																29-Nov-18	5941.6	142599.0
																30-Nov-18	7572.0	181729.0
Mean Weekly ave. limit																		
	20	220	20	0.1	4	0.1	0.05	0.5	50	5	0.5	2.0	0.5	0.5	5.0		3887.1 6000	93290.5 -

**Breaches of weekly average Ammonia+Nitrite+Nitrate limit reported via the following Part A - S5N_18_107A

Missing Data Will follow once received

Signed on behalf of the Operator

Dated

24-Jan-2019

Form I&S W1 Monthly

Release summary for the month

Operator: Tata Steel UK Ltd

Release Point:

W1 (LSO)

Permit:

BL7108

**Breaches of weekly average Ammonia+Nitrite+Nitrate limit reported via the following Part A - S5N_18_107A

Johnny.

Dated

24-Jan-2019

Form I&S W1 Monthly

Releases to Controlled Waters

Release summary for the quarter october to Dec-18

Operator: Tata Steel UK Ltd


Release Point: W1

Location: Port Talbot

Permit: BL7108

Parameter	Reporting Units	Oct	Month Nov	Dec	Limit
Phenol	Max load (kg/day)	0.0	19.3	90.3	350
	Mean load (kg/day)	0.0	2.4	11.4	
	Max conc. (mg/l)	0.0	0.2	0.4	
	Mean conc. (mg/l)	0.0	0.0	0.1	2
Soluble chromium	Max load (kg/day)	0.0	0.0	0.0	
	Mean load (kg/day)	0.0	0.0	0.0	
	Load (kg/mth)	0.00	0.00	0.00	200
	Max conc. (mg/l)	0.00	0.00	0.00	
	Mean conc. (mg/l)	0.00	0.00	0.00	0.2
Soluble lead	Max load (kg/day)	0.00	7.16	3.01	
	Mean load (kg/day)	0.00	0.24	0.10	
	Load (kg/mth)	0.0	7.2	3.0	300
	Max conc. (mg/l)	0.00	0.10	0.01	
	Mean conc. (mg/l)	0.00	0.00	0.00	0.3
Soluble iron	Max load (kg/day)	67.4	98.7	280.2	
	Mean load (kg/day)	4.1	9.4	18.1	
	Max conc. (mg/l)	0.7	1.0	1.3	
	Mean conc. (mg/l)	0.1	0.1	0.1	
Free cyanide	Max load (kg/day)	0.0	9.6	18.3	45
	Mean load (kg/day)	0.0	0.5	1.5	
	Max conc. (mg/l)	0.0	0.1	0.1	
	Mean conc. (mg/l)	0.00	0.01	0.01	0.2
PAH's	Load (kg/mth)	20.5	12.3	0.01	250
	Concentration (mg/l)	0.012	0.004	0.018	1

Signed on behalf of the Operator



Dated 18-Jan-2019

Form I&S W1 Quarterly

Releases to Controlled Waters

Release summary for the quarter october to Dec-18

Operator: Port Talbot


Release Point: W5

Location: Port Talbot

Permit: BL7108

Parameter	Reporting Units	oct	Month Nov	Dec	Limit
Dock Return Suspended solids	Max. monthly conc. of return (mg/l)	10.6	3.5	1.8	20 above background
	Max daily back- ground conc. (mg/l)	5.8	7.0	6.6	
	Mean background conc. (mg/l)	3.2	3.5	3.9	
Dock Flow*	Max daily flowrate (m3/day)	239976	0	0	350000
	Mean daily flowrate (m3/day)	82113	0	0	
	Max flowrate (m3/hour)	9999	0	0	16000
	Mean flowrate (m3/hour)	3413	0	0	
Abstracted flows (Afan docks feeder)	Max daily abstraction rate (m3/day)	29775	21103	18793	
	Mean daily abstraction rate (m3/day)	20850	17273	17532	
Dock Return Temperature	Max daily discharge temperature (C)	24	21	19	36
	Mean daily discharge temperature (C)	20	16	15	

Signed on behalf of the Operator



Dated 8-Jan-2019

Form I&S W5

Releases to Controlled Waters

Release summary for the quarter october to Dec

Operator: Port Talbot

Release Point: W3 (ABO)


Location: Port Talbot

Permit: BL7108

Parameter	Reporting Units	Oct	Month Nov	Dec	Limit
Suspended solids	Maximum daily* concentration (mg/)	149	67	68	200 (weekly)
	Mean daily concentration (mg/)	49	26	26	
Oil and grease	Maximum daily concentration (mg/)	19	20	17	20 (weekly)
	Mean daily concentration (mg/)	9	10	6	
Number of days of discharge in the month		22	22	31	

* Breaches now reported as weekly averages same as LSO

Signed on behalf of the Operator



Dated 8-Jan-2019

Form I&S W3

Releases to Controlled Waters

Release summary for the quarter october to Dec

Operator: Port Talbot

Release Point: W4


Location: Port Talbot

Permit: BL7108 / RP3730BV

Release Point W4: Spot sample results during storm discharge					
Parameter	Reporting Units	Oct	Month Nov	Dec	Limit
pH	Max daily	9.7	11.4	9.0	
	Mean daily	9.7	9.3	7.9	
	Min daily	0.0	0.0	0.0	
Suspended solids (mg/l)	Max daily conc.	17.0	100.0	217.0	
	Mean daily conc.	17.0	43.7	100.0	
Total iron (mg/l)	Max daily conc.	0.0	0.0	0.0	
	Mean daily conc.	0.0	0.0	0.0	
Soluble iron (mg/l)	Max daily conc.	0.0	0.0	0.0	
	Mean daily conc.	0.0	0.0	0.0	
Oil and grease (mg/l)	Max daily conc.	0.1	0.1	0.0	
	Mean daily conc.	0.1	0.1	0.1	
Number of days of discharge in the month (daily rainfall > 15 mm).		0	3	3	

Date of monthly sample	Suspended solids	pH	Total iron	Soluble iron	Oil and grease
04-Oct-18	17	9.7	0.01	0.01	0.05
10-Nov-18	100	9.3	0.01	0.00	0.10
10-Dec-18	10	7.8	0.40	0.10	0.10

Signed on behalf of the Operator

.....

Dated

29-Jan-2019

Form I&S W4