

RECEIVED

10 JUN 2013

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	EPR/BJ9703IM
Name of operator	Kimberly-Clark Limited
Location of Installation	Flint Paper Mill, Aber Road, Flint, Flintshire, CH6 5EX
Time and date of the detection	4 th June 2013 at 23:00am

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below

Emission point reference/ source	W2
Parameter(s)	Temperature
Limit	30°C
Measured value and uncertainty	31°C
Date and time of monitoring	Samples from tidal discharge (auto sampler) 4/6/13 at 23:00 hours
Measures taken, or intended to be taken, to stop the emission	Surface agitators were to be used at night for splash cooling; these are set on a timer to run from June to October to cope with the increased ambient temperatures. On investigation it was

OK FOR PUBLIC REGISTER

INITIALS

AS

DATE

17-6-13

COPIED TO PUBLIC REGISTER

JB

EDRM

		found that a fuse had blown on the control circuit and therefore the agitators were not functioning as they should have been.
Time periods for notification following detection of a breach of a limit		
Parameter		Notification period
Temperature		Without delay
(c) Notification requirements for the detection of any significant adverse environmental effect		
To be notified within 24 hours of detection		
Description of where the effect on the environment was detected		
Substances(s) detected		
Concentrations of substances detected		
Date of monitoring/sampling		

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	25/11/11, 7/12/11, 20/12, 21/12, 1/2/12, 12/2/12, 13/2/12, 27/6/12, 3/7/12 13/8/12, 19/8/12, 23/9/12, 19/11/12, 27/11/12, 7/2/13, 8/2/12, 4/3/13, 2/4/13, 27/5/13

Name*	Andrew Linkman
Post	Safety and Environmental Coordinator
Signature	
Date	10/6/13

* authorised to sign on behalf of Kimberley Clark