



Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	EPR/BJ9703IM
Name of operator	Kimberly-Clark Limited
Location of Installation	Flint Paper Mill, Aber Road, Flint, Flintshire, CH6 5EX
Time and date of the detection	17 th November at 11:16am

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection	
Date and time of the event	17 th November 2013
Reference or description of the location of the event	Aeration basin in the Effluent Treatment plant
Description of where any release into the environment took place	Spilled onto grave at the rear of the Aeration basin
Substances(s) potentially released	Aerobic material
Best estimate of the quantity or rate of release of substances	450kg
Measures taken, or intended to be taken, to stop any emission	Application of defoamer to reduce foaming in system. To continue every 8 hours. Gravel to be lifted washed in effluent yard and returned.
Description of the failure or accident.	Overflow of surface foam onto gravel.

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	W2
Parameter(s)	Suspended Solids
Limit	80mg/l
Measured value and uncertainty	88mg/l & 81mg/l
Date and time of monitoring	Samples from tidal discharge (auto sampler) 17 th November at 11:16 18 th November at 11:52
Measures taken, or intended to be taken, to stop the emission	Application of defoamer every 8 hours to settle the bed. Increased wastage of surplus activated sludge to the screw

OK FOR PUBLIC REGISTER	INITIALS JS	DATE 6/1/14
COPIED TO PUBLIC REGISTER	JB	E00m

	press.
Time periods for notification following detection of a breach of a limit	
Parameter	Notification period
Suspended solids	Without delay
(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	25/11/11, 7/12/11, 20/12, 21/12, 1/2/12, 12/2/12, 13/2/12, 27/6/12, 3/7/12 13/8/12, 19/8/12, 23/9/12, 19/11/12, 27/11/12, 7/2/13, 8/2/12, 4/3/13, 2/4/13, 27/5/13, 11/6/13,22/6/13, 5/7/13,25/10/13

Name*	Andrew Linkman
Post	Safety and Environmental Coordinator
Signature	
Date	18/11/13

* authorised to sign on behalf of Kimberley Clark

