

RELEASES INTO AIR

Operational Summary for the month Jan-2015

Operator: Tata Steel UK Ltd

Permit: BL7108 / RP3730BV

Location: Port Talbot Works

Release Point: A1

Day	% max throughput	% data capture	% EP availability	% UJT availability	Sinter Blend			Daily average	Particulate Matter (mg/m3)							
					Mean sulphur % w/w	Mean chloride % w/w	Mean reverts % w/w		4 hour rolling average				Hourly average			
									Maximum	Mean	Minimum	Standard deviation	Maximum	Mean	Minimum	Standard deviation
01-Jan-15	51	100%	100%	100%	0.034	0.025	11.28	93	155	95	16	43	241	93	11	66
02-Jan-15	59	100%	100%	100%	0.035	0.025	10.18	84	107	79	29	20	156	84	50	31
03-Jan-15	61	100%	100%	100%	0.035	0.025	10.18	75	109	77	42	19	196	75	30	34
04-Jan-15	65	100%	100%	100%	0.035	0.025	10.18	90	115	86	59	16	152	90	45	25
05-Jan-15	63	100%	100%	100%	0.035	0.025	10.18	90	165	96	14	40	225	90	0	63
06-Jan-15	50	100%	100%	100%	0.031	0.020	9.43	26	76	27	6	20	139	26	0	31
07-Jan-15	68	100%	100%	100%	0.031	0.020	9.43	32	93	33	3	28	207	32	2	43
08-Jan-15	28	100%	100%	100%	0.031	0.020	9.43	33	139	28	0	45	195	33	0	55
09-Jan-15	64	100%	100%	100%	0.031	0.020	9.43	41	77	45	16	21	96	41	13	25
10-Jan-15	60	100%	100%	100%	0.031	0.020	9.43	49	81	46	16	26	111	49	16	28
11-Jan-15	55	100%	100%	99%	0.032	0.029	6.59	34	63	36	19	12	69	34	15	15
12-Jan-15	59	100%	100%	97%	0.032	0.029	6.59	53	84	50	22	21	123	53	20	27
13-Jan-15	62	100%	100%	58%	0.032	0.029	6.59	66	130	68	39	24	187	66	0	41
14-Jan-15	48	100%	100%	60%	0.032	0.029	6.59	56	88	54	31	15	129	56	0	25
15-Jan-15	59	100%	100%	100%	0.032	0.029	6.59	69	117	70	47	21	216	69	14	41
16-Jan-15	65	100%	100%	100%	0.036	0.029	8.90	82	101	80	60	12	139	82	53	19
17-Jan-15	58	100%	100%	100%	0.036	0.029	8.90	49	81	52	35	13	91	49	28	15
18-Jan-15	42	100%	100%	100%	0.036	0.029	8.90	39	45	38	33	4	50	39	30	5
19-Jan-15	31	100%	100%	100%	0.036	0.029	8.90	50	152	48	0	41	258	50	0	59
20-Jan-15	42	100%	100%	100%	0.036	0.029	8.90	43	104	46	25	21	126	43	0	33
21-Jan-15	59	100%	100%	100%	0.036	0.029	8.90	66	108	65	30	20	146	66	0	36
22-Jan-15	68	100%	100%	100%	0.036	0.029	8.90	69	94	69	50	14	161	69	0	29
23-Jan-15	40	100%	100%	100%	0.04	0.034	11.09	43	94	42	0	27	178	43	0	38
24-Jan-15	67	100%	100%	100%	0.040	0.034	11.09	67	101	68	48	15	145	67	43	25
25-Jan-15	69	100%	100%	100%	0.040	0.034	11.09	65	111	66	41	22	139	65	39	30
26-Jan-15	32	100%	100%	100%	0.040	0.034	11.09	38	104	38	0	33	140	38	0	42
27-Jan-15	48	100%	100%	100%	0.040	0.034	11.09	53	95	52	3	23	178	53	0	39
28-Jan-15	68	100%	100%	100%	0.041	0.02	11.21	83	127	83	53	23	182	83	37	37
29-Jan-15	67	100%	100%	100%	0.041	0.02	11.21	89	156	89	60	27	191	89	52	39
30-Jan-15	58	100%	100%	99%	0.041	0.02	11.21	54	74	55	35	11	139	54	20	25
31-Jan-15	65	100%	100%	100%	0.041	0.02	11.21	47	65	46	38	8	90	46	34	11
Month ave	-	100%	100%	97%	0.04	0.03	9.5	59	-	59	-	-	-	59	-	-
Month max.	69	-	-	-	0.04	0.03	11.3	93	165	-	-	-	258	-	-	-
Limit	-	-	-	-	0.06	-	-	115	200	-	-	-	-	-	-	-

Signed on behalf of the Operator



Dated 26/02/2015

Form Sinter CEMS