

RELEASES INTO AIR

Operational Summary for the month Apr-2015

Operator: Tata Steel UK Ltd

Permit: BL7108 / RP3730BV

Location: Port Talbot Works

Release Point: A1

Day	% max throughput	% data capture	% EP availability	% UJT availability	Sinter Blend			Particulate Matter (mg/m3)								
								Daily average	4 hour rolling average				Hourly average			
					Mean sulphur % w/w	Mean chloride % w/w	Mean reverts % w/w		Maximum	Mean	Minimum	Standard deviation	Maximum	Mean	Minimum	Standard deviation
01-Apr-15	7	100%	100%	100%	0.027	0.025	10.78	6	38	4	0	10	54	6	0	17
02-Apr-15	5	100%	100%	94%	0.027	0.025	10.78	30	182	14	0	44	276	30	0	84
03-Apr-15	54	100%	100%	79%	0.03	0.021	10.79	98	185	110	38	41	206	98	3	53
04-Apr-15	64	100%	100%	100%	0.03	0.021	10.79	86	148	88	29	34	235	86	17	54
05-Apr-15	70	100%	100%	75%	0.03	0.021	10.79	54	93	53	28	22	131	54	9	28
06-Apr-15	71	100%	100%	99%	0.03	0.021	10.79	75	124	74	35	26	211	75	30	42
07-Apr-15	33	100%	100%	85%	0.03	0.021	10.79	49	119	51	0	38	166	49	0	49
08-Apr-15	20	100%	100%	100%	0.029	0.020	12.75	25	79	23	0	26	120	25	0	32
09-Apr-15	40	100%	100%	100%	0.029	0.020	12.75	27	50	28	15	9	58	27	14	9
10-Apr-15	26	100%	100%	100%	0.029	0.020	12.75	20	36	20	0	13	60	20	0	16
11-Apr-15	46	100%	100%	100%	0.029	0.020	12.75	39	64	39	26	12	83	39	25	15
12-Apr-15	58	100%	100%	100%	0.029	0.020	12.75	53	92	53	33	16	120	53	32	21
13-Apr-15	67	100%	100%	99%	0.029	0.020	12.75	56	85	54	26	20	113	56	21	27
14-Apr-15	64	100%	100%	100%	0.029	0.020	12.75	57	88	57	30	18	126	57	17	26
15-Apr-15	61	100%	100%	100%	0.031	0.016	18.11	52	77	54	33	14	89	52	12	20
16-Apr-15	61	100%	100%	100%	0.031	0.016	18.11	53	142	53	26	35	195	53	16	45
17-Apr-15	75	100%	100%	100%	0.031	0.016	18.11	63	143	62	29	34	257	63	24	52
18-Apr-15	68	100%	100%	100%	0.031	0.016	18.11	60	75	58	44	10	102	60	35	17
19-Apr-15	57	100%	100%	99%	0.03	NA	17.31	57	78	57	28	13	106	57	23	21
20-Apr-15	71	100%	100%	100%	0.03	NA	17.31	60	94	63	32	23	151	60	31	31
21-Apr-15	74	100%	100%	94%	0.03	NA	17.31	52	75	49	37	10	129	52	24	23
22-Apr-15	13	100%	100%	100%	0.03	NA	17.31	19	67	19	0	27	167	19	0	42
23-Apr-15	57	100%	100%	94%	0.03	NA	17.31	86	163	88	43	34	261	86	0	53
24-Apr-15	77	100%	100%	62%	0.033	0.012	18.83	76	119	76	60	19	198	76	57	29
25-Apr-15	73	100%	100%	1%	0.033	0.012	18.83	62	66	61	56	3	82	62	38	6
26-Apr-15	70	100%	100%	5%	0.033	0.012	18.83	77	116	77	58	18	167	77	56	24
27-Apr-15	74	100%	100%	3%	0.033	0.012	18.83	74	95	74	65	8	119	74	61	12
28-Apr-15	59	100%	100%	23%	0.033	0.014	19.63	66	95	65	5	26	134	66	0	34
29-Apr-15	78	100%	100%	69%	0.033	0.014	19.63	81	99	81	73	8	117	81	70	11
30-Apr-15	76	100%	100%	100%	0.033	0.014	19.63	86	107	86	72	9	154	86	65	18
Month ave	-	100%	100%	83%	0.03	0.02	15.3	57	-	56	-	-	-	57	-	-
Month max.	78	-	-	-	0.03	0.03	19.6	98	185	-	-	-	276	-	-	-
Limit	-	-	-	-	0.06	-	-	115	200	-	-	-	-	-	-	-

Signed on behalf of the Operator



Dated 26/05/2015

Form Sinter CEMS