

Releases to Controlled Waters

Release summary for the quarter Jan to Mar

Operator: Tata Steel UK Ltd

Release Point: W4

Location: Port Talbot

Permit: BL7108 / RP3730BV

Release Point W4: Spot sample results during storm discharge					
Parameter	Reporting Units	Jan	Month Feb	Mar	Limit
pH	Max daily	9.6	10.4	11.4	
	Mean daily	9.6	10.4	11.4	
	Min daily	0.0	0.0	0.0	
Suspended solids (mg/l)	Max daily conc.	42.0	38.7	46.8	
	Mean daily conc.	42.0	38.7	46.8	
Total iron (mg/l)	Max daily conc.	0.0	3.1	0.3	
	Mean daily conc.	0.0	3.1	0.3	
Soluble iron (mg/l)	Max daily conc.	0.0	0.1	0.0	
	Mean daily conc.	0.0	0.1	0.0	
Oil and grease (mg/l)	Max daily conc.	0.0	0.1	0.0	
	Mean daily conc.	0.1	0.1	0.1	
Number of days of discharge in the month (daily rainfall > 15 mm).		0	0	0	

Date of monthly sample	Suspended solids	pH	Total iron	Soluble iron	Oil and grease
03-Jan-17	42	9.6	0.02	0.01	0.05
28-Feb-17	39	10.4	3.06	0.05	0.05
13-Mar-17	47	11.4	0.33	0.01	0.05

Signed on behalf of the Operator



Dated

2-Jun-2017

Form I&S W4