

Permit Number: EA/EPR/BK3638IF/V002

Operator: Hydro Aluminium Limited

Facility: Wrexham Aluminium Works

Form Number: Water1

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2018 to 31/03/2018

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result	Test Method	Sample Date and Times	Uncertainty
W1	BOD	10 mg/l	Single sample	<1	TM045: MEWAM BOD5 2nd Ed, HMSO 1988 / Method 5210B, AWWA/APHA, 20th ed, 1999; SCA Blue Book 130	02/01/18, 09:15	±6.9%
W1	Suspended Solids	35 mg/l	Single sample	7.4	TM022: Method 2540D, AWWA/APHA, 20 th ed, 1999 / BS2690 Part 120 1981; BS EN 872	02/01/18, 09:15	±3%
W1	pH	6 – 9	Single sample	7.96	TM256: determination of pH in water using the GLPH Meter	02/01/18, 09:15	±0.02%
W1	COD	125 mg/l	Single sample	14.5	TM107: ISO6060:1989	02/01/18, 09:15	±1.2%
W1	Ammoniacal Nitrogen	5 mg /l	Single sample	0.235	TM099: BS2690 Part 7, 1968 / BS6068 Part 2.11, 1984	02/01/18, 09:15	±3.8%
W1	Aluminium	0.5 mg/l	Single sample	0.024	TM152: Method 3125B, AWWA/APHA, 20 th ed, 1999	02/01/18, 09:15	±3.8%
W1	Total Hydrocarbon Oil	2 mg/l	Single sample	<1	TM235: Determination of total petroleum hydrocarbons in waters by infrared spectroscopy	02/01/18, 09:15	±10.5%
W1	Temperature	25 °C	Single sample	8	Mercury thermometer	02/01/18, 09:15	Not known
W1	Flow	N/A	-	-	Not measured – agreed that water emission volumes can be calculated from cooling water bleed-off and casting pit emptying (CAR I/110329/BK3638).	-	-

SignedJoel Priest.....
(Authorised to sign as representative of Operator)

Date29/01/2018.....

Results have been corrected as per condition 3.1.4.