

## Part A

Permit Number	EA/EPRYP3937SH/V003
Name of Operator	Mekatek Limited
Location of Installation	Amex Park, Johnstown, Carmarthen, SA31 3NF
Location of the emission	W1
Time and date of the emission	31/05/2022

Substance(s) emitted	Media <i>eg air, groundwater</i>	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Total ammonium as N	Source emissions to water	AM daily spot sample identified a value of 29.7mg/l.	Identified at 06:00.
	Source emissions to water		

Measures taken, or intended to be taken, to stop the emission	Plant shut down procedure implemented without delay. Discharge stopped. Plant set on full re-circulation.
---	---

## Part B

Any more accurate information on the matters for notification under Part A.	Plant remains on full recirculation mode with no discharge until matter is looked into in more detail and / or investigations completed.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Investigation ongoing. Plant operating under normal conditions during the 24hours prior to exceedance being identified so investigation is being carried out to identify potential cause.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	To be confirmed.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	N/A

Name	Daniel Lewis
Post	Technical & Compliance

Signature	
Date	31/05/2022