

Toyota Motor Manufacturing (UK) Ltd

Burnaston
Derbyshire
East Midlands
DE1 9TA
United Kingdom

Tel 01332 282121
Fax 01332 282801
www.toyotauk.com

TOYOTA



Lara Cubley
Regulatory Officer
Natural Resources Wales
Chester Road
Buckley
Flintshire, CH7 3AJ

Ref: Environmental Permit EPR/BK6483IU/V003

Date: 03/10/2013

Dear Lara,

With reference to permit improvement condition 9.22 and our subsequent response on 24/04/2010, I attach the Quarter 3 report for monitoring of our Waste Water Treatment Plant emissions. The report compares sample analysis by Toyota and a UKAS accredited lab, using methods based on TGN M18.

If you have any queries, please do not hesitate to contact me.

Yours sincerely,

Keith Martin
Senior Engineer
Facilities and Environment

Enc: Reporting Form "Sewer2/280709A" (Q3)

MONITORING RETURNS N. WALES

	INITIALS	DATE
CHECKED vs AUTHORITY	L.C.	8.7.14
TRACING	JB	11.10.13
OK FOR PUBLIC REGISTER	L.C.	8.7.14
THE MONITORING RETURN	JB	EDM

Permit Number: EPR/BK6483IU/V003
Facility: Deeside engine Casting

Operator:
Form Number:

Toyota Motor Manufacturing (UK) Ltd
Sewer2 / 280709A

Reporting of emissions to sewer for Quarter:				Q3 June - September 2013		TMUK		UKAS Accredited Lab.		
Emission Point	Substance / Parameter	ELV	Reference Period	Sample Date	Test Method	Result	Test Method	Result	Uncertainty	
S1	pH	5 - 10	Daily Composite Sample	16/09/2013	Laboratory bench pH probe.	7.28	Based "The Measurement of Electrical Conductivity and Laboratory Determination of the pH Value of Natural, Treated and Wastewaters 1978".	7.2	0.14	
S1	Total Suspended Solids	200 mg/l	Daily Composite Sample	16/09/2013	Internal Method: Filter Paper + balance	42.0 mg/l	Based on "Suspended, Settleable and Total Dissolved Solids in Waters and Effluents 1980."	72mg/l	18.50%	
S1	COD	1500 mg/l	Daily Composite Sample	16/09/2013	Internal Titration Method	929.0 mg/l	Dichromate oxidation / digestion.	820.0 mg/l	17.70%	
S1	Total Hydrocarbon Oil	150 mg/l	Daily Composite Sample	16/09/2013	Internal Gravimetric Method	10.0 mg/l	Solvent extract of the sample / GCFID	0.51 mg/l	34.90%	
S1	Sulphate	1000 mg/l	Daily Composite Sample	16/09/2013	Internal Method AA Spectrophotometer	360.0 mg/l	Determination by ICPOES.	396.0 mg/l	16.00%	
S1	Copper	1 mg/l	Daily Composite Sample	16/09/2013	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.002 mg/l	21.60%	
S1	Zinc	2 mg/l	Daily Composite Sample	16/09/2013	Internal Method AA Spectrophotometer	0.24 mg/l	Determination by ICPMS	0.153 mg/l	15.40%	
S1	Lead	1 mg/l	Daily Composite Sample	16/09/2013	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	<0.001 mg/l	14.20%	
S1	Nickel	1 mg/l	Daily Composite Sample	16/09/2013	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.014 mg/l	22.70%	

Signed:

Date:

(authorised to sign on behalf of operator)

03/10/13