

Toyota Motor Manufacturing (UK) Ltd

Burnaston
Derbyshire
East Midlands
DE1 9TA
United Kingdom

Tel 01332 282121
Fax 01332 282801
www.toyotauk.com

TOYOTA



Lara Cubley
Regulatory Officer
Natural Resources Wales
Chester Road
Buckley
Flintshire, CH7 3AJ

Ref: Environmental Permit EPR/BK6483IU/V003

Date: 09/06/2015

Dear Lara,

With reference to permit improvement condition 9.22 and our subsequent response on 24/04/2010, I attach the Quarter 2 report for monitoring of our Waste Water Treatment Plant emissions. The report compares sample analysis by Toyota and a UKAS accredited lab, using methods based on TGN M18.

If you have any queries, please do not hesitate to contact me.

Yours sincerely,

Keith Martin
Senior Engineer
Facilities and Environment

Enc: Reporting Form "Sewer2/280709A" (Q2)

MONITORING RETURNS N. HAI MS

	INITIALS	DATE
CHECKED Vs AUTHORISATION	JF	23/6
TRACKING	JB	23.6.15
OK FOR PUBLIC REGISTER	JF	23/6
WASTE TO WASTE/REUSE		

Permit Number: EPR/BK6483IU/V003
Facility: Deeside engine Casting

Operator: Toyota Motor Manufacturing (UK) Ltd
Form Number: Sewer2 / 280709A

Reporting of emissions to sewer for Quarter:				Q2 Apr - Jun 2015		TMUK		UKAS Accredited Lab.	
Emission Point	Substance / Parameter	ELV	Reference Period	Sample Date	Test Method	Result	Test Method	Result	Uncertainty
S1	pH	5 - 10	Daily Composite Sample	04/06/2015	Laboratory bench pH probe.	7.52	Based "The Measurement of Electrical Conductivity and Laboratory Determination of the pH Value of Natural, Treated and Wastewaters 1978".	7.4	1%
S1	Total Suspended Solids	200 mg/l	Daily Composite Sample	04/06/2015	Internal Method: Filter Paper + balance	37.0 mg/l	Based on "Suspended, Settleable and Total Dissolved Solids in Waters and Effluents 1980."	33.0 mg/l	9.20%
S1	COD	1500 mg/l	Daily Composite Sample	04/06/2015	Internal Titration Method	817 mg/l	Dichromate oxidation / digestion.	650.0 mg/l	8.90%
S1	Total Hydrocarbon Oil	150 mg/l	Daily Composite Sample	04/06/2015	Internal Gravimetric Method	1.0 mg/l	Solvent extract of the sample / GC/FID	3.7 mg/l	17.40%
S1	Sulphate	1000 mg/l	Daily Composite Sample	04/06/2015	Internal Method AA Spectrophotometer	292 mg/l	Determination by ICPOES.	274 mg/l	6.40%
S1	Copper	1 mg/l	Daily Composite Sample	04/06/2015	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.008 mg/l	2.70%
S1	Zinc	2 mg/l	Daily Composite Sample	04/06/2015	Internal Method AA Spectrophotometer	0.32 mg/l	Determination by ICPMS	0.244 mg/l	5.70%
S1	Lead	1 mg/l	Daily Composite Sample	04/06/2015	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.003 mg/l	2.50%
S1	Nickel	1 mg/l	Daily Composite Sample	04/06/2015	Internal Method AA Spectrophotometer	0.1 mg/l	Determination by ICPMS	0.016 mg/l	2.20%

Signed:  Date: 07/06/15
(authorised to sign on behalf of operator)