

Permit Number: **EPR/BL1096IB**

Operator: **Castle Cement Limited**

Installation: **Padeswood Cement Works**

Form: M / W1

**Quarterly Reporting of Emissions to Surface Water – Emission Point W1  
for the period 01/10/2016 to 31/12/2016 (2016 Q4)**

<b>Emission Point</b>	<b>Parameter</b>	<b>Emission Limit Value</b>	<b>Result</b>	<b>Date of Measurement</b>	<b>Method</b>
<b>W1</b>	pH (minimum)	6	<b>7.34</b>	<b>Continuous</b>	<b>CEMS</b>
<b>W1</b>	pH (maximum)	9	<b>8.14</b>	<b>Continuous</b>	<b>CEMS</b>
<b>W1</b>	Temperature (maximum)	23 °C	<b>22</b>	<b>Continuous</b>	CEMS
<b>W1</b>	Total Suspended Solids (Maximum)	50 mg/l	<b>N/A</b>	<b>N/A</b>	BS EN 872
<b>W1</b>	Oil or Grease	None Present	None Present	<b>N/A</b>	Visual Check

Notes : No releases to the local water course were made from the emission point W1 during this period, therefore no results for TSS have been collected.

Signed .....Robert Keough.....  
(Authorised to sign as representative of Castle Cement Limited)

Date.....05/01/2017.....