



EPR Compliance Assessment Report

Report ID: BL1096IB/0195601

This form will report compliance with your permit as determined by an NRW officer

Site	PADESWOOD CEMENT WORKS			Permit Ref	BL1096IB		
Operator/ Permit holder	Castle Cement Limited						
Date	29/11/2013			Time in	09:00	Out	11:30
What parts of the permit were assessed	Various						
Assessment	Site Inspection	EPR Activity	Installation	X	Waste Op		Water Discharge
Recipient's name/position	Gary Young (Site Manager)						
Officer's name	Stuart Ross			Date issued	06/12/2013		

Section 1 - Compliance Assessment Summary

This is based on the requirements of the permit under the Environmental Permitting Regulations. A detailed explanation and any action you may need to take are given in the "Detailed Assessment of Compliance" (section 3). This summary details where we believe any non-compliance with the permit has occurred, the relevant condition and how the non-compliance has been categorised using our Compliance Classification Scheme (CCS). CCS scores can be consolidated or suspended, where appropriate, to reflect the impact of some non-compliances more accurately. For more details of our CCS scheme, contact your local office.

Permit Conditions and Compliance Summary

Condition(s) breached

a) Permitted activities	1. Specified by permit	N	
b) Infrastructure	1. Engineering for prevention & control of pollution	A	
	2. Closure & decommissioning	N	
	3. Site drainage engineering (clean & foul)	N	
	4. Containment of stored materials	N	
	5. Plant and equipment	A	
c) General management	1. Staff competency/ training	N	
	2. Management system & operating procedures	N	
	3. Materials acceptance	N	
	4. Storage handling, labelling, segregation	N	
d) Incident management	1. Site security	N	
	2. Accident, emergency & incident planning	N	
e) Emissions	1. Air	N	
	2. Land & Groundwater	N	
	3. Surface water	N	
	4. Sewer	N	
	5. Waste	N	
f) Amenity	1. Odour	N	
	2. Noise	N	
	3. Dust/fibres/particulates	N	
	4. Pests, birds & scavengers	N	
	5. Deposits on road	N	
g) Monitoring and records, maintenance and reporting	1. Monitoring of emissions & environment	N	
	2. Records of activity, site diary, journal & events	N	
	3. Maintenance records	N	
	4. Reporting & notification	A	
h) Resource efficiency	1. Efficient use of raw materials	N	
	2. Energy	N	

KEY: C1, C2, C3, C4 = CCS breach category (* suspended scores are marked with an asterisk),

A = Assessed (no evidence of non-compliance), N = Not assessed, NA = Not Applicable, O = Ongoing non-compliance – not scored

Number of breaches recorded

0

Total compliance score

(see section 5 for scoring scheme)

0

If the Total No Breaches is greater than zero, then please see Section 3 for details of our proposed enforcement response

OK FOR PUBLIC REGISTER

COPIED TO PUBLIC REGISTER

57C 18.01.14

JB EDRM

Section 2 – Compliance Assessment Report Detail

This section contains a report of our findings and will usually include information on:

- the part(s) of the permit that were assessed (e.g. maintenance, training, combustion plant, etc)
- where the type of assessment was 'Data Review' details of the report/results triggering the assessment
- any non-compliances identified
- any non-compliances with directly applicable legislation
- details of any multiple non-compliances
- information on the compliance score accrued inc. details of suspended or consolidated scores.
- details of advice given
- any other areas of concern
- all actions requested
- any examples of good practice.
- a reference to photos taken

This report should be clear, comprehensive, unambiguous and normally completed within 14 days of an assessment.

Comments

This Compliance Assessment Report covers a site visit on 28/11/13 and a site meeting on 29/11/13.

1. Plume Colouration

Sample analysis results for kiln inputs have been delayed - please forward the results to NRW as soon as possible.

Please provide SRF analysis to confirm compliance with table S2.1 by 13/11/13.

2. Noise

As stated in my previous CAR form and discussed during this visit, I require additional design detail / rationale for the noise reduction work detailed in your noise management plan. Please provide this along with the timescales for completing the proposed work. Please do so by 13/12/13.

3. Dust Control

The existing kiln jetting / blockage removal procedure is being revised to enhance (where possible) the process operating conditions to minimise the potential release of dust/fumes from the kiln.

Please forward a copy of the existing kiln jetting procedure (this was not received as stated in your most recent correspondence). Please provide a copy of your revised procedure by 18/12/13.

A CCTV camera has now been installed to show the kiln inlet area. Footage is screened continuously in the control room and is available for kiln operators to monitor dust/fume emissions from this area. It was stated that this area is illuminated at night so the camera remains effective 24hrs a day. Please ensure the use of the camera is integrated into your kiln operating procedure, particularly to monitor dust/fume emissions from this area and to inform kiln operators what action is required when emissions are visible, including during blockage removal work.

Dust releases should be logged and reviewed. Any significant releases must be notified to NRW as per normal requirements. Your implementation of the above will be reviewed during my next site inspection.

I note that a door is in the process of being fitted to the bypass duct chute / skip area as agreed in your recent correspondence - this will help minimise dust emissions from this area.

4. Notifications

Please provide the Part B notification for the HCL breach on 19/09/13 -(result of 11mg/m3) by 13/12/13.

Please provide the Part B notification for the cyclone 1 blockage / kiln system over pressurisation on 16/11/13 as soon as possible.

5. Site Tour

On 28/11/13 a brief site tour was completed around the preheater and kiln area - no significant issues noted. I am pleased to note that some areas of unmade ground have been cleared and are due to be concreted. This will aid site housekeeping.



EPR Compliance Assessment Report

Report ID: BL1096IB/0195601

This form will report compliance with your permit as determined by an NRW officer

Site	PADESWOOD CEMENT WORKS	Permit	BL1096IB
Operator/ Permit	Castle Cement Limited	Date	29/11/2013

Section 3- Enforcement Response

Only one of the boxes below should be ticked

You must take immediate action to rectify any non-compliance and prevent repetition.

Non-compliance with your permit conditions constitutes an offence and can result in criminal prosecutions and/or suspension or revocation of a permit. Please read the detailed assessment in Section 2 and the steps you need to take in Section 4 below.

Other than the provision of advice and guidance, at present we do not intend to take further enforcement action in respect of the non-compliance identified above. This does not preclude us from taking enforcement action if further relevant information comes to light or advice isn't followed.

In respect of the above non-compliance you have been issued with a warning. At present we do not intend to take further enforcement action. This does not preclude us from taking additional enforcement action if further relevant information comes to light or offences continue.

We will now consider what enforcement action is appropriate and notify you, referencing this form.

Section 4- Action(s)

Where non-compliance has been detected and an enforcement response has been selected above, this section summarises the steps you need to take to return to compliance and also provides timescales for this to be done.

Criteria Ref.	CCS Category	Action Required/Advised	Due Date
See Section 1 above			

Section 5 - Compliance notes for the Operator

To ensure you correct actual or potential non-compliance we may

- advise on corrective actions verbally or in writing
- require you to take specific actions in writing
- issue a notice
- require you to review your procedures or management system
- change some of the conditions of your permit
- decide to undertake a full review of your permit

Any breach of a permit condition is an offence and we may take legal action against you.

● We will normally provide advice and guidance to assist you to come back into compliance either after an offence is committed or where we consider that an offence is likely to be committed. This is without prejudice to any other enforcement response that we consider may be required.

● Enforcement action can include the issue of a formal caution, prosecution, the service of a notice and or suspension or revocation of the permit.

See our Enforcement and Civil Sanctions guidance for further information

This report does not relieve the site operator of the responsibility to

- ensure you comply with the conditions of the permit at all times and prevent pollution of the environment
- ensure you comply with other legislative provisions which may apply.

Non-compliance scores and categories

CCS category	Description	Score
C1	A non-compliance which could have a major environmental effect	60
C2	A non-compliance which could have a significant environmental effect	31
C3	A non-compliance which could have a minor environmental effect	4
C4	A non-compliance which has no potential environmental effect	0.1

Operational Risk Appraisal (Opra) - Compliance assessment findings may affect your Opra score and/or your charges. This score influences the resource we use to assess permit compliance.

Section 6 – General Information

Data protection notice

The information on this form will be processed by the Natural Resources Wales (NRW) to fulfill its regulatory and monitoring functions and to maintain the relevant public register(s). The NRW may also use and/or disclose it in connection with:

- offering/providing you with its literature/services relating to environmental matters
- consulting with the public, public bodies and other organisations (e.g. Health and Safety Executive, local authorities) on environmental issues
- carrying out statistical analysis, research and development on environmental issues
- providing public register information to enquirers
- investigating possible breaches of environmental law and taking any resulting action
- preventing breaches of environmental law
- assessing customer service satisfaction and improving its service
- Freedom of Information Act/Environmental Information Regulations request.

The NRW may pass it on to its agents/representatives to do these things on its behalf. You should ensure that any persons named on this form are informed of the contents of this data protection notice.

Disclosure of information

The NRW will provide a copy of this report to the public register(s). However, if you consider that any information contained in this report should not be released to the public register(s) on the grounds of commercial confidentiality, you must write to your local area office within twenty working days of receipt of this form indicating which information it concerns and why it should not be released, giving your reasons in full.

Customer charter

What can I do if I disagree with this compliance assessment report?

If you are unable to resolve the issue with your site officer, you should firstly discuss the matter with the officer's line managers. If you wish to raise your dispute further through our official Complaints and Commendations procedure, phone our general enquiry number 0300 065 3000 (Mon to Fri 08.00–18.00) and ask for the Customer Contact team or send an email to enquiries@naturalresourceswales.gov.uk. If you are still dissatisfied you can make a complaint to the Public Services Ombudsman for Wales. For advice on how to complain to the Ombudsman phone their helpline on 0845 607 0987.