

RECEIVED

25 JUL 2013

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	EPR/BL1096IB/V010
Name of operator	Castle Cement Limited
Location of Installation	Padeswood Works, Padeswood, Mold.
Time and date of the detection	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection

Date and time of the event	09:30
Reference or description of the location of the event	Kiln system over pressurisation.
Description of where any release into the environment took place	Cooler, CV01.
Substances(s) potentially released	Dust and fumes.
Best estimate of the quantity or rate of release of substances	Largely contained within buildings, 50-100kg dust to atmosphere.
Measures taken, or intended to be taken, to stop any emission	Kiln system shut down.
Description of the failure or accident.	Failure of temperature probe on Cyclone 5 caused the control loop to reduce fuels to calciner in order to bring the apparent temp back into control. This is induced a kiln flush.

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below

Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

OK FOR PUBLIC REGISTER

INITIALS

DATE

SR

15.8.13

COPIED TO PUBLIC REGISTER

JB


EORM

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

Name*	Victoria Smith
Post	Works Chemist
Signature	
Date	25 July 2013

* authorised to sign on behalf of Castle Cement Limited

