

Mr S Ross
Natural Resources Wales
Chester Road
Buckley
Flintshire
CH7 3AJ

Hanson Cement
Padeswood Works
Chester Road
Padeswood, Mold
Flintshire CH7 4HB
Tel: 01244 550330
Fax: 01244 552548

www.hanson.com/uk

Thursday, 01 December 2016

Dear Stuart

Re Part A Notifications 25-27th Nov 2016

On the 25,26 & 26th November we submitted Part As following indications that particulate emissions from CEMS monitoring point A8 (Main Stack) had breached out environmental permit. However, on reviewing the data we have found that the daily emissions during this period were actually below 10mg/Nm³.

The emissions on the 24th have also been revised, however they are still above the permit limit and a part B outlining further details of the investigation will be sent in due course.

The revised average daily emissions for each of the days are found in the table below.

Date	Initial indicated Emission (mgNm-3)	Actual Emission (mgNm-3)
24/11/2016	12.57	11.36
25/11/2016	10.76	9.52
26/11/2016	10.88	9.74
27/11/2016	10.86	9.67

This issue was identified following further investigation, and stemmed from incorrect use of calibration functions in relation to the particulates emission monitoring. This has now been rectified and will be reviewed on an ongoing basis. In addition to this all other calibration functions have been reviewed and are correct.

The work carried out on the main bag filter frame and stopping kiln production during this time demonstrates our dedication to controlling emissions. The average particulate emissions after these dates have been less than 4mg/Nm³.

Kind regards

Robert Keough
Quality and Environment Manager