

Parameters (mg l)	Permit Limit mg/l	Mean Result 2008	Mean Results 2009	Mean Results 2010	Mean Results 2011	Mean Results 2012	Mean Results 2013	Mean Results 2014	Mean Results 2015	Mean Results 2016
Total Suspended Solids	50	7.73	3.68	3.9	4.765	3.0	3.6	3.28	2.086	4.2125
Total Dissolved Solids	1200	752.73	521.73	977.45	1373.6	925	559	951.40	720.6	627
Oil & Grease	10	10.18	30.18	2.8	0.21	0.435	0.226	0.28	0.18	0.225
Copper	0.25	0.01	0.2	0.006	0.0053	0.0075	0.0054	0.1591	0.03	0.033235
Lead	0.1	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
Tin	0.1	0.0006	0.0006	0.002	0.0023	0.002	0.002	0.0	0.00	0.002
Zinc	0.5	0.006	0.06	0.009	0.0074	0.008	0.006	0.01	0.01	0.0075
Aluminium	1.5	1.02	0.47	0.33	0.9	0.1251	0.238	0.26	0.48	0.155
Mercury	0.08	0.00008	0.00008	0.00001	0.0034	0.000015	0.000055	0.00001	0.00001	0/0025075
Arsenic	0.1	0.0014	0.0017	0.0026	0.0018	.0015	.0019	0.0018	0.00145	0.001885
Nickel	0.5	0.00049	0.0017	0.002	0.0016	0.001	0.001	0.001	0.01	0.00125
Ammoniacal Nitrogen	1.5	1.007	0.31	0.15	1.19	1.23	0.255	0.0246	0.0346	0.04125
pH maximum	9	8.8	8.3	8.39	8.63	8.27	8.41	8.04	8.05	8.02
pH minimum	6	7.4	6.6	7.1	7.4	7.26	7.32	7.65		

Real Alloy, Swansea.