


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_293
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	3 rd May 07:25		

Any more accurate information on the matters for notification under Part A.	Additional information to that in the part A is to report the effects of the actions taken
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>Actions fall into 2 areas:</p> <ol style="list-style-type: none"> 1. Checked the operation of the bicarbonate injection abatement system – no problems found 2. Changed the constituents of the stone batch to the furnace – this had the desired effect by reducing the SO₂ emission concentration to below the ELV of 1350 mg/Nm³ at reference conditions <p>On 3/5 which had roughly a 50:50 split between batch types the daily average SO₂ was 1297 mg/Nm³. On 4/5 the daily average SO₂ was 1160 mg/Nm³ and to 11am today, 5/5, the average is 1183 mg/Nm³</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	12-14/5/20, 22-26/5/20, 22/6-2/7/20, 8/7/20, 16/8/20, 15/9/20, 6/10/20, 7/10/20, 16/2/21, 22/2/21, 27/2-3/3/21, 9/3/21, 17-28/3/21, 5/4/21, 7-11/4/21, 24-25/4/21, 26/4/21, 12/5/21, 14/5/21, 17/5/21, 22-27/5/21, 8-9/6/21, 11-13/6/21 18-23/6/21, 17/7/21, 27-28/7/21, 8/8/21, 21/8/21, 21/9/21, 10/10/21, 3/11/21, 17/11/21, 9/1/22, 22.2/22

Name*	Graham Jones
Post	Environment, Energy and Compliance Manager
Signature	
Date	5/5/2022

* authorised to sign on behalf of Knauf Insulation Ltd