SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER
Permit Number BL9941
South Caernarfon Creameries Limited
Release Summary for month to 31/07/2014

Releases of Rate

W12 Reporting Form					
Emission Point	Date	Daily result of Sampling for instantaneous flow rate Litres per second			Permit Limit Litres per second^{-1}
		Max	Min	Ave	
W1	01-07-14	8.76	2.79	6.86	9.72
W1	05-07-14	8.73	4.24	6.98	9.72
W1	03-07-14	8.79	2.82	6.50	9.72
W1	04-07-14	9.15	3.14	7.28	9.72
W1	05-07-14	9.01	3.28	7.18	9.72
W1	06-07-14	6.36	0.38	2.33	9.72
W1	07-07-14	8.52	0.71	5.64	9.72
W1	08-07-14	9.54	3.86	7.10	9.72
W1	09-07-14	8.74	4.21	7.07	9.72
W1	10-07-14	8.91	1.7	6.65	9.72
W1	11-07-14	8.50	0.86	5.96	9.72
W1	12-07-14	9.22	4.39	7.34	9.72
W1	13-07-14	8.26	0	1.57	9.72
W1	14-07-14	8.43	0.34	5.41	9.72
W1	15-07-14	8.42	2.64	6.68	9.72
W1	16-07-14	8.66	5.49	6.80	9.72
W1	17-07-14	8.40	3.84	6.94	9.72
W1	18-07-14	9.66	2.62	7.11	9.72
W	19-07-14	9.52	1.78	7.26	9.72
W1	20-07-14	6.93	0	2.39	9.72
W1	21-07-14	9.14	0.07	6.61	9.72
W1	22-07-14	9.49	0.17	6.16	9.72
W1	23-07-14	8.91	1.57	6.17	9.72
W1	24-07-14	9.37	4.02	7.10	9.72
W1	25-07-14	8.88	0.60	6./88	9.72
W1	26-07-14	9.08	2.33	6.53	9.72
W1	27-07-14	6.42	0	2.89	9.72
W1	28-07-14	8.50	5.61	7.16	9.72
W1	29-07-14	8.60	0.10	6.12	9.72
W1	30-07-14	8.57	3.66	6.90	9.72
W1	31-07-14	8.81	0.14	6.36	9.72

Signed on behalf of South Caernarfon Creameries Ltd _____

Dated: 08-08-14