

SCHEDULE 3 REPORTING FORMS EMISSIONS TO WATER

Permit Number BL9941


South Caernarfon Creameries Limited

Release Summary for month to 31/05/2015

Releases of Flow

W11 Reporting Form			
Emission Point	Date	Result of Sampling for Daily Volume of Flow m ³ per day ⁻¹	Permit Limit m ³ per day ⁻¹
W1	01-05-15	584	700
W1	02-05-15	599	700
W1	03-05-15	683	700
W1	04-05-15	667 Magflow	700
W1	05-05-15	616	700
W1	06-05-15	697	700
W1	07-05-15	588	700
W1	08-05-15	659 Magflow river in flood	700
W1	09-05-15	679 Magflow river in flood	700
W1	10-05-15	682	700
W1	11-05-15	682	700
W1	12-05-15	697	700
W1	13-05-15	640	700
W1	14-05-15	563	700
W1	15-05-15	595	700
W1	16-05-15	598	700
W1	17-05-15	599	700
W1	18-05-15	667 Magflow river in flood	700
W1	19-05-15	663 Magflow river in flood	710
W1	20-05-15	636 Magflow	700
W1	21-05-15	656	700
W1	22-05-15	584	700
W1	23-05-15	556	700
W1	24-05-15	569	700
W1	25-05-15	566	700
W1	26-05-15	560	700
W1	27-05-15	651	700
W1	28-05-15	549	700
W1	29-05-15	633 Magflow river in flood	700
W1	30-05-15	604	700
W1	31-05-15	595	700

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 03-06-15

SCHEDULE 3 REPORTING FORMS EMISSIONS TO WATER

Permit Number BL9941

South Caernarfon Creameries Limited

Release Summary for month to 31/05/2015

Releases of Rate

W12 Reporting Form					
Emission Point	Date	Daily result of Sampling for instantaneous flow rate Litres per second			Permit Limit Litres per second ¹
		Max	Min	Ave	
W1	01-05-15	8.82	0.14	6.76	9.72
W1	02-05-15	8.92	0.19	6.94	9.72
W1	03-05-15	9.65	6.39	7.90	9.72
W1	04-05-15	8.53	6.93	7.73	Magflow 9.72
W1	05-05-15	9.31	0.42	7.13	9.72
W1	06-05-15	9.43	6.32	8.07	9.72
W1	07-05-15	9.00	0.38	6.81	9.72
W1	08-05-15	8.60	6.92	7.76	Magflow 9.72
W1	09-05-15	8.19	6.78	7.48	Magflow 9.72
W1	10-05-15	8.95	6.49	7.89	9.72
W1	11-05-15	9.66	2.13	7.89	9.72
W1	12-05-15	9.31	6.82	8.07	9.72
W1	13-05-15	9.29	0.42	7.41	9.72
W1	14-05-15	9.16	0.19	6.52	9.72
W1	15-05-15	8.86	0.17	6.89	9.72
W1	16-05-15	9.11	0.22	6.93	9.72
W1	17-05-15	9.00	0.29	6.93	9.72
W1	18-05-15	8.55	6.90	7.72	Magflow 9.72
W	19-05-15	8.52	6.91	7.71	Magflow 9.72
W1	20-05-15	8.58	6.90	7.74	Magflow 9.72
W1	21-05-15	9.71	2.31	7.60	9.72
W1	22-05-15	8.93	0.20	6.76	9.72
W1	23-05-15	8.75	0.20	6.43	9.72
W1	24-05-15	9.06	0.25	6.59	9.72
W1	25-05-15	8.88	0.14	6.55	9.72
W1	26-05-15	8.71	0.17	6.48	9.72
W1	27-05-15	9.03	4.49	7.53	9.72
W1	28-05-15	9.26	0.17	6.36	9.72
W1	29-05-15	8.58	6.73	7.65	Magflow 9.72
W1	30-05-15	8.90	0.39	6.99	9.72
W1	31-05-15	9.59	0.7	6.88	9.72

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 03-06-15

**SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER**

**Permit Number BL9941
South Caernarfon Creameries Limited**

Release Summary for month to 31/05/2015

Releases of pH

W3 Reporting Form					
Emission Point	Week Commencing	Result of Sampling for pH Weekly readings			Permit Limit
		Max	Min	Ave	
W1	01-05-15	7.95	7.48	7.70	6 – 9
W1	08-05-15	7.70	7.43	7.55	6 – 9
W1	15-05-15	7.76	7.43	7.61	6 – 9
W1	22-05-15	7.58	7.24	7.40	6 – 9

Signed on behalf of South Caernarfon Creameries Ltd



Dated : 03-06-15

RF 15

SCHEDULE 3 REPORTING FORMS EMISSIONS TO WATER

Permit Number BL9941
South Caernarfon Creameries Limited

Release Summary for month to 31/05/2015

Releases of Temperature

W4 Reporting Form					
Emission Point	Week Commencing	Result of Sampling for Weekly Temperature °C			Permit Limit °C
		Max	Min	Ave	
W1	01-05-15	19.46	17.32	18.61	25
W1	08-05-15	19.96	17.64	18.73	25
W1	15-05-15	21.33	18.55	19.69	25
W1	22-05-15	22.14	19.50	21.17	25

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 03-06-15

RF 14

May-15	2.5mg/l ALUM	6mg/l AMMONIA	20mg/l BOD	520mg/l CHLOR	Not Set DO	Not Set Diss Iron	Not Set Tot Fe	Not Set Phos	1.5mg/l Ortho	30mg/l SS
06/05/2015	1.23	2.28	10.7	340	6.74	0.387	0.503	0.922	0.635	31.5
13/05/2015	0.278	3.77	5.62	343	4.95	0.367	0.539	0.285	0.146	12.5
20/05/2015	0.528	1.73	9.8	325	4.47	0.362	0.441	0.513	0.055	18
27/05/2015	0.316	6.81	6.17	339	6.76	0.294	0.345	0.313	0.251	11.5
Average	0.588	3.6475	8.0725	336.75	5.73	0.3525	0.457	0.50825	0.27175	18.375



 3/6/15