


**SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER**
Permit Number EPR/BL9941IC
South Caernarfon Creameries Limited
Release Summary for month to 30/04/2017

Releases of Flow

W11 Reporting Form			
Emission Point	Date	Result of Sampling for Daily Volume of Flow m ³ per day ⁻¹	Permit Limit m ³ per day ⁻¹
W1	01-04-17	657	700
W1	02-04-17	643	700
W1	03-04-17	603	700
W1	04-04-17	651	700
W1	05-04-17	577	700
W1	06-04-17	678	700
W1	07-04-17	590	700
W1	08-04-17	575	700
W1	09-04-17	475	700
W1	10-04-17	564	700
W1	11-04-17	531	700
W1	12-04-17	620	700
W1	13-04-17	601	700
W1	14-04-17	567	700
W1	15-04-17	532	700
W1	16-04-17	599	700
W11	17-04-17	576	700
W1	18-04-17	524	700
W1	19-04-17	498	710
W1	20-04-17	518	700
W1	21-04-17	458	700
W1	22-04-17	597	700
W1	23-04-17	609	700
W1	24-04-17	590	700
W1	25-04-17	530	700
W1	26-04-17	608	700
W1	27-04-17	599 Magflow	700
W1	28-04-17	591	700
W1	29-04-17	619	700
W1	30-04-17	569	700

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 26-05-17

**SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER**

**Permit Number EPR/BL9941IC
South Caernarfon Creameries Limited**

Release Summary for month to 30/04/2017

Releases of pH

W3 Reporting Form					
Emission Point	Week Commencing	Result of Sampling for pH Weekly readings			Permit Limit
		Max	Min	Ave	
W1	01-04-17	7.95	7.63	7.74	6-9
W1	08-014-17	8.34	8.00	8.17	6-9
W1	15-04-17	8.51	7.81	8.19	6-9
W1	22-04-17	8.38	7.48	8.04	6-9

Signed on behalf of South Caernarfon Creameries Ltd



Dated : 26-05-17

RF 15

**SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER**


**Permit Number EPR/BL9941IC
South Caernarfon Creameries Limited**

Release Summary for month to 30/04/2017

Releases of Temperature

W4 Reporting Form					
Emission Point	Week Commencing	Result of Sampling for Weekly Temperature °C			Permit Limit °C
		Max	Min	Ave	
W1	01-04-17	19.89	17.93	18.81	25
W1	08-04-17	19.79	18.81	19.30	25
W1	15-04-17	20.66	19.24	19.88	25
W1	22-04-17	21.67	18.56	20.05	25

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 26-05-17

RF 14

Apr-17	2.5mg/l ALUM	6mg/l AMMONIA	20mg/l BOD	520mg/l CHLOR	Not Set DO	Not Set Diss Iron	Not Set Tot Fe	Not Set Phos	1.5mg/l Ortho	30mg/l SS
06/04/2017	<0.02	3.22	14.6	19	8.71	<0.019	<0.019	0.228	0.344	2.5
13/04/2017	<0.02	1.9	44.6	69	4.7	<0.023	<0.02	0.489	0.964	4.5
20/04/2017	<0.02	0.47	14.9	14	9.51	<0.019	<0.024	0.17	0.3	<2
27/04/2017	0.03	4.6	7.56	289	14.5	0.04	0.06	0.165	0.142	2.5
Average	0.03	2.5475	20.415	97.75	9.355	0.04	0.06	0.263	0.4375	3.166667

Hyfous

26-5-17

**---SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER**

Permit Number EPR/BL9941IC

South Caernarfon Creameries Limited

Release Summary for month to 30/04/2017

Releases of Rate

W12 Reporting Form					
Emission Point	Date	Daily result of Sampling for instantaneous flow rate Litres per second			Permit Limit Litres per second ¹
		Max	Min	Ave	
W1	01-04-17	8.24	4.09	7.61	9.72
W1	02-04-17	8.14	2.36	7.44	9.72
W1	03-04-17	7.51	5.56	6.98	9.72
W1	04-04-17	8.27	4.85	7.54	9.72
W1	05-04-17	8.50	2.83	6.68	9.72
W1	06-04-17	8.82	2.63	7.84	9.72
W1	07-04-17	8.64	0.75	6.82	9.72
W1	08-04-17	7.15	3.20	6.66	9.72
W1	09-04-17	6.98	0.93	5.50	9.72
W1	10-04-17	7.02	2.33	6.52	9.72
W1	11-04-17	7.71	0.27	6.15	9.72
W1	12-04-17	9.16	2.92	7.18	9.72
W1	13-04-17	9.03	2.02	6.96	9.72
W1	14-04-17	8.39	2.15	6.56	9.72
W1	15-04-17	8.52	1.67	6.15	9.72
W1	16-04-17	8.41	0.88	6.93	9.72
W1	17-04-17	8.59	1.03	6.67	9.72
W1	18-04-17	8.36	0.75	6.07	9.72
W	19-04-17	7.73	0.50	5.77	9.72
W1	20-04-17	8.42	0.40	6.00	9.72
W1	21-04-17	8.65	0.37	5.30	9.72
W1	22-04-17	7.80	1.95	6.91	9.72
W1	23-04-17	7.70	3.48	7.05	9.72
W1	24-04-17	8.31	2.10	6.83	9.72
W1	25-04-17	7.63	0.47	6.14	9.72
W1	26-04-17	8.21	2.33	7.04	9.72
W1	27-04-17	7.29	7.29	7.29	Magflow .72
W1	28-04-17	7.45	1.95	6.84	9.72
W1	29-04-17	7.70	0.83	7.16	9.72
W1	30-04-17	7.81	0.48	6.58	9.72

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 26-05-17

**SCHEDULE 3 REPORTING FORMS
EMISSIONS TO WATER**
Permit Number EPR/BL9941IC
South Caernarfon Creameries Limited
Release Summary for month to 30/04/2017

Releases of Turbidity

W11 Reporting Form			
Emission Point	Date	Result of Sampling for Daily Turbidity NTU	Permit Limit .1
W1	01-04-17	28.76	-
W1	02-04-17	26.19	-
W1	03-04-17	39.68	-
W1	04-04-17	46.72	-
W1	05-04-17	26.65	-
W1	06-04-17	34.16	-
W1	07-04-17	28.95	-
W1	08-04-17	28.42	-
W1	09-04-17	36.36	-
W1	10-04-17	27.40	-
W1	11-04-17	36.59	-
W1	12-04-17	41.42	-
W1	13-04-17	37.05	-
W1	14-04-17	32.28	-
W1	15-04-17	41.39	-
W1	16-04-17	39.52	-
W1	17-04-17	43.15	-
W1	18-04-17	53.30	-
W1	19-04-17	51.82	-
W1	20-04-17	43.66	-
W1	21-04-17	50.76	-
W1	22-04-17	17.04	-
W1	23-04-17	14.40	-
W1	24-04-17	20.94	-
W1	25-04-17	17.03	-
W1	26-04-17	16.46	-
W1	27-04-17	27.76	-
W1	28-04-17	14.38	-
W1	29-04-17	12.36	-
W1	30-04-17	16.55	-

Signed on behalf of South Caernarfon Creameries Ltd



Dated: 26-05-17