



Schedule 1 – Notification of Abnormal Emission **Page 1 of 1**

Part B – 0509

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	Chloride breach @ 596 mg/lit during 24hrs on 03-07-13
Fax To:	01244 548805

Any more accurate information on the matters for modification under Part A	High result queried with Alcontrol
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	A repeat analysis by Alcontrol has confirmed the original result.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	Reduce the rate of chemical dosing in case the elevated dose used for reducing orthophosphate has contributed to the high chloride result.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	N/A

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	
Date:	22-07-13

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*

RF01

	INITIALS	DATE
OK FOR PUBLIC REGISTER	L.C	6.9.13
COPIED TO PUBLIC REGISTER	JB	EDm