

RECEIVED

08 NOV 2013



Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part A – 0514

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllhell, Gwynedd, LL53 6SB
Location of the Emission	W1
Time and date of the Emission	During 24 hours on 30-10-13
Fax To:	01244 548805

Substance(s) emitted	Media	Best estimate of the quantity or rate of emission.	Time during which the emission took place
BOD	W1 water	37.7mg/l	24hrs

Measures taken, or intended to be taken, to stop the emission.	Our internal COD result for the day on the same sample was low. The previous and following day's COD results on the final effluent were also less than our internal action limit. All other parameters tested were well within limit. The result has been queried with Alcontrol.
---	---

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	<i>H G Jones</i>
Date:	07-11-13

* Authorised to sign on behalf of South Caernarfon Creameries Ltd.

	INITIALS	DATE
OK FOR PUBLIC REGISTER	<i>L.C.</i>	<i>18.2.14</i>
COPIED TO PUBLIC REGISTER	<i>JB</i>	<i>EDLm</i>