

RECEIVED

23 SEP 2013



Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part A – 0512

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllhell, Gwynedd, LL53 6SB
Location of the Emission	W1
Time and date of the Emission	For 15 minutes on 21-09-13
Fax To:	01244 548805

Substance(s) emitted	Media	Best estimate of the quantity or rate of emission.	Time during which the emission took place
Rate	W1 water	11.30l/s	15 minutes

Measures taken, or intended to be taken, to stop the emission.	Rate Breach for 15 minutes on 21.09.13 due to blower tripping out and second blower coming on. 19:30 = 6.82l/s 19:45 = 11.30l/s 20:00 = 8.12l/s
---	--

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	<i>H G Jones</i>
Date:	23-09-13

* Authorised to sign on behalf of South Caernarfon Creameries Ltd.

	INITIALS	DATE
OK FOR PUBLIC REGISTER	LC	18.2.14
COPIED TO PUBLIC REGISTER	JB	EDcm