

RECEIVED
09 MAY 2014



RF01

Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part B – 0518

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	Ammonia breach of 9.08mg/l during 24 hours on 23-04-14
Fax To:	01244 548805

Any more accurate information on the matters for modification under Part A	All other parameters well within limit
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Flows adjusted to minimise variation in plant operation
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	Continued internal and external monitoring.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	<i>H.G. Jones</i>
Date:	06-05-14

* Authorised to sign on behalf of South Caernarfon Creameries Ltd.

RF01

	INITIALS	DATE
ONE FOR PUBLIC REGISTER	L.C.	9.7.14
COPIED TO PUBLIC REGISTER	J.B.	EDM