RF01

RECEIVED
04 FEB 2015

Schedule 1 – Notification of Abnormal Emission **Page 1 of 1**

Part B – 0524

Permit Number	**BL9941**
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	BOD breach of 21.7 mg/ for 24 hours during 18-02-15
Fax To:	**01244 548805**

Any more accurate information on the matters for modification under Part A	Other parameters within limit. COD result the previous day was 102mg/l and 5 mg/l the following day.
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Continued monitoring
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	As above
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

*** Name:**	H G Jones
Post:	Quality Assurance Manager
Signature:	
Date:	05-03-15

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*

REMOVED FROM PUBLIC REGISTER K.C 12.8.15
RETURNED TO PUBLIC REGISTER