

RF01


Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part B – 0520

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	Chloride breach of 535 mg/l during 24 hours on 17-09-14
Fax To:	01244 548805

Any more accurate information on the matters for modification under Part A	Alcontrol have confirmed that the original test result was correct
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Dosing of poly-aluminium chloride reduced
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	Continued monitoring. All other parameters on the day well within limit
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	<i>H. G. Jones</i>
Date:	24-09-14

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*

RF01

	RETAILS	DATE
ON FOR PUBLIC REGISTER	K.C.	4-2-15
COPIED TO PUBLIC REGISTER		