



RF01



Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part B – 0515

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	BOD breach @ 28.5mg/l during 24hrs on 02-01-14
Fax To:	01244 548805

Any more accurate information on the matters for modification under Part A	All other parameters well within limit.
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Continued monitoring of internal and external results. SCC internal COD results: 01-01-14 = 45 mg/l 02-01-14 = 136 mg/l 03-01-14 = 132.5 mg/l 04-01-14 = 96 ng/l
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	Additional de-sludging carried out
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	
Date:	10-01-14

* Authorised to sign on behalf of South Caernarfon Creameries Ltd.

OK FOR PUBLIC REGISTER	INITIALS	DATE
	L.C.	11.3.14
COPIED TO PUBLIC REGISTER	JB	EDRM