Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part A – 0534

Permit Number	**BL9941**
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1
Time and date of the Emission	During 24 hours on 13-01-16
Fax To:	**01244 548805**

Substance(s) emitted	**Media**	**Best estimate of the quantity or rate of emission.**	**Time during which the emission took place**
Ammonia	W1 water	6.17 mg/l	24 hours

Measures taken, or intended to be taken, to stop the emission.	SCC internal Ammonia result for the same sample was 3.4 mg/l which is within limit. The sample was not preserved, as there was no preservative supplied with the sample bottles from Alcontrol.

*** Name:**	H G Jones
Post:	Quality Assurance Manager
Signature:	H. G. Jones.
Date:	15-01-16

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*