


RF01




Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part B – 0530

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	BOD breach of 51.5 mg/l for 24 hours during 02-12-15. SS breach of 51.5mg/l for 24 hours during 02-12-15.
Fax To:	01244 548805

Any more accurate information on the matters for modification under Part A	Alcontrol laboratories have checked both BOD and SS test results, and are satisfied with the figures. SCC internal COD result was within internal limit at 44mg/l. The internal result for COD the previous day was 96 mg/l, and 92 mg/l the following day. The SS result for the same day was 20mg/l, the previous day was 18 mg/l, and 20 mg/l the following day.
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Continued monitoring.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	As above
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	
Date:	15-12-15