RF01

RECEIVED
-7 AUG 2015

SOUTH CAERNARFON CREAMERIES
FFERMFA DE ARFON

Schedule 1 – Notification of Abnormal Emission **Page 1 of 1**

Part B – 0527

Permit Number	**BL9941**
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	Suspended Solids breach of 32 mg/ for 24 hours during 22-075-15
Fax To:	**01244 548805**

Any more accurate information on the matters for modification under Part A	Alcontrol have re-tested the sample and corrected the result to 17.5mg/l which is within limit. All other parameters well within limit..
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Continued monitoring
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	As above
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

*** Name:**	H G Jones
Post:	Quality Assurance Manager
Signature:	HGJones
Date:	31-07-15

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*

COPIED TO PUBLIC REGISTER L.C. 12.8.15.
COPIED TO PUBLIC REGISTER

RF01