

RF01


Schedule 1 – Notification of Abnormal Emission Page 1 of 1

Part B – 0528

Permit Number	BL9941
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwillog, Pwllheli, Gwynedd, LL53 6SB
Location of the Emission	W1-water
Time and date of the Emission	Ammonia breach of 6.31 mg/ for 24 hours during 26-08-15
Fax To:	01244 548805

Any more accurate information on the matters for modification under Part A	SCC internal result was within limit at 3.3mg/l. The internal result for Ammonia the previous day was 3.1 mg/l, and 3.0 mg/l the following day. All other parameters well within limit.
Measurement taken, or intended to be taken, to prevent a recurrence of the incident.	Continued monitoring
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission.	As above
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

* Name:	H G Jones
Post:	Quality Assurance Manager
Signature:	
Date:	07-09-15

* Authorised to sign on behalf of South Caernarfon Creameries Ltd.

RF01

