


Revision 01



Schedule 5 – Notification of Abnormal Emission **Page 1 of 1**

Part B -539

Permit Number	EPR/BL9941IC
Name of Operator	South Caernarfon Creameries Ltd (SCC Ltd)
Location of Installation	Rhydygwystl, Chwilog, Pwllheli, Gwynedd, LL53 6SB

Any more accurate information on the matters for modification under Part A	Alcontrol labs have re-tested the sample, and as there was only 1 mg/l difference, have confirmed that they have no issue with their original result. All other parameters within limit.
Measurement taken, or intended to be taken, to prevent a recurrence of the incident	Continued monitoring
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Additional de-sludging carried out to lower the SS.
The dates of any unauthorised emissions from the installation in the preceding 24 months	

* Name:	Gwyn Jones
Post:	Quality Assurance Manager
Signature:	
Date:	22-12-16

** Authorised to sign on behalf of South Caernarfon Creameries Ltd.*

RF01