

Permit Number: BM3965 / NP3235MQ

Operator: Airbus UK Ltd

Installation: Broughton Aircraft Factory

Form Number: Water1 / 11/01/07

**Reporting of emissions to water (other than to sewer) for the period from ...01/07/2017 ..... to ...30/09/2017 .....**

| Emission Point | Substance / Parameter | Emission Limit Value | Reference Period        | Result <sup>[1]</sup> | Test Method <sup>[2]</sup> | Sample Date and Times <sup>[3]</sup> | Uncertainty <sup>[4]</sup> |
|----------------|-----------------------|----------------------|-------------------------|-----------------------|----------------------------|--------------------------------------|----------------------------|
|                |                       |                      |                         |                       |                            |                                      |                            |
| SW16           | Suspended Solids      | 50 mg/l              | 01/07/2017 – 30/09/2017 | 17.0 mg/l             | Method 2540D               | 21/09/2017 @ 13:50                   | <2mg/l                     |
| SW16           | Chromium              | -                    | 01/07/2017 – 31/09/2017 | 6.32 ug/l             | Standard Methods ICP-MS    | 31/08/2017 @ 10:17                   | <3ug/l                     |
|                |                       |                      |                         |                       |                            |                                      |                            |
|                |                       |                      |                         |                       |                            |                                      |                            |

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed .....  
(Authorised to sign as representative of Operator)



Date.....11/10/2017 .....