



Received 7/7/13



Airbus UK Ltd
Environment Team
Chester Road
Broughton
Chester
CH4 0DR

Our reference: **EA/EPR/06/2013**

1st July 2013

Elizabeth Voice
Regulatory Officer
Natural Resources Wales
Chester Road
Buckley
CH7 3AJ

Re: Part B, incident IR/13/03

Dear Beth,

As promised in my e-mail of 27th June 2013, please find attached a signed copy of the Part B return relating to incident IR/13/03

Should you have any further questions please do not hesitate to contact me.

Yours sincerely,

Andy Denton
Environment Officer

Airbus Operations, Broughton


Tel: 01244 524252

	INITIALS	DATE
OK FOR PUBLIC REGISTER	ED	7/7/13
COPIED TO PUBLIC REGISTER	JB	EDRM

IR/13/03

PART B

Any more accurate information on the matters for notification under Part A	As Part A
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Analysis by MCERTS laboratory initially appeared to contradict routine internal analysis. However, investigation has revealed that monitoring equipment on the effluent treatment plant was probably suffering calibration drift due to age, allowing the control of the chemistry to vary and a permit limit to be marginally breached between the routine internal analysis. More modern and reliable pH monitoring equipment, recovered from the now redundant Hawker facility, has been reprogrammed and installed into the LCM treatment facility. We have also now approached potential suppliers to investigate the feasibility of in-line continuous monitoring.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Regular internal analysis of effluent is maintained
The dates of any unauthorised emissions from the installation in the preceding 24 months	10-Apr-2013

Name	Andy Denton
Post	Environment Officer
Signature	
Date	27th June 2013

FOR THE ATTENTION OF Beth Voice