

PART A

Permit Number	BM3965IA (Variation NP3235MQ)
Location of Installation	Airbus UK, Chester Road, Broughton, Chester CH4 0DR
Time and date of detection	22nd January 2018

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution
To be notified within 24hours of detection

Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident	

(b) Notification requirements for the breach of a limit
To be notified within 24hours of detection

Emission point reference / source	Surface water 16 (SW16)
Parameter(s)	Suspended solids
Limit	50 mg/l
Measured value and uncertainty	58 mg/l (LOD 2mg/l)
Date and time of monitoring	15th January 2018 @ 13:42
Measures taken, or intended to be taken, to stop the emission	Undertaking of scheduled maintenance of surface water system to be confirmed

Time periods for notification following detection of a breach of limit

Parameter	Notification period
Suspended solids	5 working days

(c) Notification requirements for the detection of any significant adverse environmental effect
To be notified within 24hours of detection

Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring / sampling	

IR/ 18 / 01

PART B

Any more accurate information on the matters for notification under Part A	Service specification provided to sub-contractor undertaking gully sucking had insufficient detail and was inadequate
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Contractor service specification has been reviewed. Broughton site EHS manager will now undertake process confirmation of the maintenance of the surface water system
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	n/a
The dates of any unauthorised emissions from the installation in the preceding 24 months	SW16 - 18th Feb 2016 SW16 - 13th May 2016

Name	A Denton
Post	Environment Officer
Signature	
Date	09th April 2018