

Permit Number: BT4885IT
UK Ltd

Facility: Shotton Paper Mill

Operator: UPM-Kymmene

Form Number:



Reporting of emissions to water (other than to sewer) for the quarter from 1st April 2015 to 30th June 2015

Emission Point	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
	Substance / Parameter	Limit Value					
W1	BOD	25 mg/l	Weekly	14	BS EN 1899-1 (1998)	26/06/2015 09.00	
W1	Total suspended solids	60 mg/l	Weekly. For 95% of all measured values of periodic samples taken over one month	0.45	BS EN 872		
W1	pH max	9	Instantaneous	8.8	BS6068-2.50	07/04/2015 @ 07.00	
W1	pH min	6	Instantaneous	7	BS6068-2.50	03/06/2015 @16.00	
W1	COD	-	Spot	143		11/06/2015 @ 19.00	
W1	Ammoniacal Nitrogen	4 mg/l	Spot	0.61		19/06/2015 @ 19.00	
W1	Temperature degrees Celsius	25° Celsius	Continuous	23.29		11/06/2015 @17.00	
W1	Total Phosphorus	-	Spot	2	BS EN 872	29/12/14	
W1	Maximum instantaneous Flow rate	800 l/s	24 hour period beginning 00:01	703.3		02/05/2015 @22.50	
W1	Maximum Daily Flow	22,000 m ³ /day	Instantaneous	10390		04/04/2015	
W1	Maximum Tidal Flow	11,000 m ³ /tide	Instantaneous	5987		20/04/2015 @12.40	
W1	Cd (µg/m ³)	-		100	BS 6068-2.89	16/5/15	4.8
W1	Hg (µg/m ³)	-		200	BS 6068-2.89	16/5/15	5.7
W1	Fe (mg/m ³)	-		240	BS 6068-2.89	16/5/15	4.8
W1	Mn (mg/m ³)	-		17	BS 6068-2.89	16/5/15	5.6

CONTINUING RETURNS N. 41115
INITIALS DATE
CHECKED VS AUTHORITY
TRACKING
10/9/15
10/9/15
10/9/15

Emission Point	Substance / Parameter	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value						
W1	Zn (mg/m³)	-	-		16	BS 6068-2.89	16/5/15	5.9
W1	As (mg/m³)	-	-		4	BS 6068-2.89	16/5/15	4.8
W1	Cu (mg/m³)	-	-		1	BS 6068-2.89	16/5/15	4.2
W1	Cr (mg/m³)	-	-		2	BS 6068-2.89	16/5/15	5.6
W1	Ni (mg/m³)	-	-		5	BS 6068-2.89	16/5/15	3.6
W1	Pb (mg/m³)	-	-		1	BS 6068-2.89	16/5/15	3.6

The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values. Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Environment Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed Date.....

(Authorised to sign as representative of Operator)