

Permit Number: BT4885IT
UK Ltd

Operator: UPM-Kymmene

Facility: Shotton Paper Mill

Form Number: W1

Reporting of emissions to water (other than to sewer) for the quarter from 1st July 2015 to 30th September 2015

Emission Point	Substance / Parameter	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value						
W1	BOD	25 mg/l		Weekly	15	BS EN 1899-1 (1998)	18/09/2015@09.00	
W1	Total suspended solids	60 mg/l		Weekly. For 95% of all measured values of periodic samples taken over one month	0.715	BS EN 872		
W1	pH max	9		Instantaneous	8.8	BS6068-2.50	14/09/2015 @ 19.00	
W1	pH min	6		Instantaneous	7.1	BS6068-2.50	12/09/2015 @ 07.00	
W1	COD	-		Spot	150		16/09/2015 @ 19.00	
W1	Ammoniacal Nitrogen	4 mg/l		Spot	0.653		1/7/15	
W1	Temperature degrees Celsius	25° Celsius		Continuous	24.06		01/07/2015 @ 18.00	
W1	Total Phosphorus	-		Spot	0.7	BS EN 872	27/9/15	
W1	Maximum instantaneous Flow rate	800 l/s		24 hour period beginning 00:01	706		10/07/2015 @ 6.20	
W1	Maximum Daily Flow	22,000 m ³ /day		Instantaneous	12510		02/09/2015	
W1	Maximum Tidal Flow	11,000 m ³ /tide		Instantaneous	7625		10/07/2015 @ 06.00	
W1	Cd (µg/m ³)	-			100	BS 6068-2.89	3/8/15	4.8
W1	Hg (µg/m ³)	-			100	BS 6068-2.89	3/8/15	5.7
W1	Fe (mg/m ³)	-			250	BS 6068-2.89	3/8/15	4.8

Emission Point	Substance / Parameter	Emission		Reference Period	Result [1]	Test Method [2]	Sample Date and Times [3]	Uncertainty [4]
		Limit Value						
W1	Mn (mg/m ³)	-			12	BS 6068-2.89	3/8/15	5.6
W1	Zn (mg/m ³)	-			11	BS 6068-2.89	3/8/15	5.9
W1	As (mg/m ³)	-			6	BS 6068-2.89	3/8/15	4.8
W1	Cu (mg/m ³)	-			2	BS 6068-2.89	3/8/15	4.2
W1	Cr (mg/m ³)	-			3	BS 6068-2.89	3/8/15	5.6
W1	Ni (mg/m ³)	-			6	BS 6068-2.89	3/8/15	3.6
W1	Pb (mg/m ³)	-			1	BS 6068-2.89	3/8/15	3.6

The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values. Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Environment Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed Date 28/10/15

(Authorised to sign as representative of Operator)