

CEMS INVALIDATION LOG

UPM-Kymmene (UK)

Permit Reference PP3936SQ

Installation Shotton Paper

The CEMS invalidation log is used to record periods when the CEMS system has been unavailable and/or the data from it could be classed as inaccurate or not available

Period for which this log covers 01/01/2016 to 31/12/2016					
Date	Downtime from	Downtime to	Duration	Reason	Corrective Action
4 th April	10.30	14.30	4 hours	CEMs maintenance	Required to be carried out before surveillance visit
5 th April	10.30	11.30	½ hour	CEMs maintenance	See above
9 th July	14.00	15.30	1 ½ hours	CEMs PC required re-booting	No corrective action found
26 th September	13.00	13.30	½ hour	CEMs update	SAMs update
26 th October	10.30	12.30	2 hours	CEMs maintenance	Required to be carried out before surveillance visit
Comments					
The above dates have been recorded and mentioned in the monthly report					



24/1/17

Kevin Smith
 Utilities Manager
 UPM (UK) Shotton
 Kevin.O.Smith@upm.com
 Office +44 (0) 1244284393
 Mobile +44 (0) 7736497124