

Permit Number : EPR/EP3738NG

Operator: Wepa UK Ltd

Facility: Bridgend Paper Mills

Form Number: Air1

Reporting of emissions to air for the period from

01-Jan-20

to

31-Dec-20

| Emission Point | Substance / Parameter                                                        | Emission Limit Value  | Reference Period | Result [1] | Test Method [2] | Sample Dates and Times [3] | Uncertainty [4] |
|----------------|------------------------------------------------------------------------------|-----------------------|------------------|------------|-----------------|----------------------------|-----------------|
| A1             | Oxides of Nitrogen<br>(NO and NO <sub>2</sub> expressed as NO <sub>2</sub> ) | 250 mg/m <sup>3</sup> | Hourly Average   | 207.5      | BS EN 14792     | 17/12/2020 12.15-13.15     | +/- 4.4         |
| A1             | Sulphur dioxide                                                              | 50 mg/m <sup>3</sup>  | Hourly Average   | 7.3        | EA MID 21       | 17/12/2020 12.15-13.15     | +/- 0.4         |
| A1             | Particulates                                                                 | 10 mg/m <sup>3</sup>  | Hourly Average   | 0.67       | BS EN 13284-1   | 17/12/2020 12.15-13.15     | +/- 0.05        |
| A1             | Carbon Monoxide                                                              | 150 mg/m <sup>3</sup> | Hourly Average   | 21.7       | BS EN 15058     | 17/12/2020 12.15-13.15     | +/- 0.8         |
| A2             | Oxides of Nitrogen<br>(NO and NO <sub>2</sub> expressed as NO <sub>2</sub> ) | 250 mg/m <sup>3</sup> | Hourly Average   | 86.7       | BS EN 14792     | 15/12/2020 15.20-16.20     | +/- 1.4         |
| A2             | Sulphur dioxide                                                              | 50 mg/m <sup>3</sup>  | Hourly Average   | 2.3        | EA MID 21       | 15/12/2020 15.20-16.20     | +/- 0.2         |
| A2             | Particulates                                                                 | 10 mg/m <sup>3</sup>  | Hourly Average   | 0.61       | BS EN 13284-1   | 15/12/2020 15.20-16.20     | +/- 0.04        |
| A2             | Carbon Monoxide                                                              | 150 mg/m <sup>3</sup> | Hourly Average   | 0.7        | BS EN 15058     | 15/12/2020 15.20-16.20     | +/- 0.1         |
| A4             | Oxides of Nitrogen<br>(NO and NO <sub>2</sub> expressed as NO <sub>2</sub> ) | 40 mg/m <sup>3</sup>  | Hourly Average   | 38.6       | BS EN 14792     | 15/12/2020 11.00-12.00     | +/- 0.6         |

The result given is the maximum value (or minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit is expressed as a range, the result is given as the 'minimum - maximum' measured values.

Where an internationally recognised standard is used the reference number is given. Where another method that has been agreed with the Environment Agency is used, then the appropriate identifier is given. In other cases the principle technique is used, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result given. For continuous measurements the percentage of the process operating time covered by the result is given.

The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed .....  
(Authorised to sign as representative of Operator)

Date 28/01/2021