

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	119.21	6.4	188.79	75.6	13.64	1.46	-2.56	6.01
01:00 to C	119.33	6.19	188.77	113.03	13.54	1.32	-2.66	6.22
02:00 to C	118.64	13.96	195.48	130.85	13.8	1.25	-1.67	5.95
03:00 to C	117.94	14.01	194.47	122.29	13.76	1.2	-1.38	5.81
04:00 to C	116.57	16.65	194.99	89.69	13.7	1.18	-1.04	5.98
05:00 to C	117.37	20.76	200.33	97.27	13.54	1.23	0.78	6.1
06:00 to C	121.29	-8.83	176.75	73.48	13.43	1.19	-0.17	6
07:00 to C	123.66	-19.21	169.99	84.78	13.46	1.23	0.11	5.87
08:00 to C	122.27	-23.37	163.71	125.74	13.57	1.24	-0.1	5.76
09:00 to C	118.96	-3.93	178.08	147.77	13.68	1.34	-2.58	5.89
10:00 to 1	121.49	15.43	201.31	107.78	13.64	1.3	1.37	5.92
11:00 to 1	124.93	16.7	207.84	84.54	13.5	1.32	4.94	5.96
12:00 to 1	121.81	-1.44	184.93	68.18	13.28	2.03	0.59	6.19
13:00 to 1	124.89	-4.49	186.59	97.17	13.31	1.33	0.11	6.23
14:00 to 1	124.44	-5.91	184.48	109.22	13.35	1.35	1.57	6.19
15:00 to 1	122.07	-3.49	183.28	112.28	13.42	1.3	-0.69	6.18
16:00 to 1	132.52	4.33	207.09	107.68	13.43	1.37	1.21	6.2
17:00 to 1	138.02	-0.54	210.63	98.39	13.42	1.34	1.02	6.24
18:00 to 1	138.29	-4.98	206.59	97.78	13.31	1.31	0.86	6.2
19:00 to 1	143.04	-4.73	214.13	96.38	13.39	1.33	1.9	6.18
20:00 to 2	144.59	0.49	221.71	87.89	13.52	1.3	1.64	6.1
21:00 to 2	140.94	8.22	223.86	93.57	13.45	1.31	1.27	6.02
22:00 to 2	142.04	-1.82	215.49	92.27	13.44	1.66	1.01	6.09
23:00 to 2	146.27	-4.41	219.37	76.65	13.42	1.47	1.87	6.14
95 Percent	144.59	16.7	221.71	130.85	13.76	1.66	1.9	6.23
Daily Avera	127.52	1.5	196.61	99.59	13.5	1.35	0.31	6.06

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	148.85	-3.47	224.28	94.32	13.38	1.28	-0.26	6.16
01:00 to C	153.77	-6.65	228.61	90.52	13.3	1.39	4.97	5.99
02:00 to C	146.14	9.28	232.88	86.21	13.44	1.38	6.74	5.82
03:00 to C	140.93	-1.52	214.11	81.34	13.42	1.36	8.97	5.57
04:00 to C	144.05	-7.38	213.02	92	13.33	1.32	1.25	6.1
05:00 to C	142.31	-9.83	207.9	107.73	13.55	1.23	-1.7	6.01
06:00 to C	144.2	-17.43	203.19	88.69	13.37	1.23	-0.63	6.04
07:00 to C	142.01	-26.86	190.41	70.28	13.33	1.22	-0.27	6.1
08:00 to C	145.69	-26.64	196.27	84.44	13.22	1.25	-0.19	6.18
09:00 to C	144.52	-7.25	213.87	78.84	13.36	1.26	-2.28	6.26
10:00 to 1	144.22	10.39	231.04	87.25	13.47	1.25	-1.4	6.23
11:00 to 1	143.16	11.06	230.09	109.58	13.67	1.15	-0.7	6.06
12:00 to 1	137.43	6.84	217.1	90.11	13.68	1.67	0.17	5.86
13:00 to 1	139.98	5.3	219.46	87.26	13.69	1.76	0.36	5.87

14:00 to 1	168.55	3.75	261.62	103.64	13.55	1.2	0.03	6.05
15:00 to 1	165.79	-16.11	237.55	156.58	13.26	1.27	0.51	6.07
16:00 to 1	167.14	-25.56	230.17	114.94	13.16	1.28	1.19	6.12
17:00 to 1	173.62	-29.47	236.17	96.28	13.29	1.19	1.47	5.97
18:00 to 1	171.33	-11.03	251.11	107.31	13.55	1.23	-3.89	6.05
19:00 to 1	178.45	-15.41	257.62	117.46	13.59	1.2	-0.98	5.81
20:00 to 2	173.09	3.26	268.1	121.38	13.45	1.18	-0.15	6.08
21:00 to 2	153.69	-11.76	223.38	153.21	13.15	1.23	-2.31	6.39
22:00 to 2	156.21	-19.32	219.68	134.44	13.06	1.92	-1.89	6.47
23:00 to 2	168.41	-16.04	241.62	150.53	13.26	1.25	-1.68	6.25
95 Percent	173.62	10.39	261.62	153.21	13.68	1.76	6.74	6.39
Daily Avera	153.9	-8.41	227.05	104.35	13.4	1.32	0.31	6.06

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	170.15	-1.77	258.55	110.71	13.53	1.25	-3.54	6.13
01:00 to 0	163.55	-1.82	248.42	103.02	13.78	1.26	-3.85	5.89
02:00 to 0	161.4	-1.54	245.4	107.2	13.85	1.33	-2.56	5.79
03:00 to 0	158.98	4.98	248.22	122.91	13.51	1.39	-1.54	6.04
04:00 to 0	152.6	10.33	243.81	136.22	13.51	1.39	-1.51	6.15
05:00 to 0	141.77	12.3	229.2	192.46	13.57	1.4	-1	6.14
06:00 to 0	148.34	-1.72	225.24	140.24	13.47	1.36	-2.63	6.14
07:00 to 0	145.38	-2.1	220.33	160.89	13.48	1.37	-1.08	6.11
08:00 to 0	135.58	-0.17	207.28	102.3	14.04	1.26	-3.03	5.67
09:00 to 0	134.96	1.71	208.2	113.49	13.66	1.28	-1.13	5.8
10:00 to 1	118.78	1.35	183.08	300.38	13.54	1.22	-0.99	6.02
11:00 to 1	127.17	9.85	204.42	125.36	13.74	1.16	-3.15	6.06
12:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.53
13:00 to 1	132.7	-11.1	191.94	124.07	13.49	2.69	-2.15	6.07
14:00 to 1	143.05	-13.08	205.79	167.44	13.44	1.24	-0.12	6.12
15:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.7
16:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.93
17:00 to 1	134.2	4.17	209.5	171.58	13.29	1.27	-0.74	6.25
18:00 to 1	128.98	1.04	198.38	98.63	13.61	1.19	-2.36	6.01
19:00 to 1	124.93	2.38	193.53	99.2	13.88	1.19	-0.99	5.63
20:00 to 2	129.01	-0.67	196.72	126.57	13.43	1.32	0.17	6.11
21:00 to 2	123.8	1.28	190.69	89.26	13.55	1.26	-1.59	6.05
22:00 to 2	117.14	7.8	187.02	255.16	13.86	1.78	-2.33	5.83
23:00 to 2	129.76	11.71	210.24	216.35	13.67	1.33	2.82	5.8
95 Percent	163.55	11.71	248.42	255.16	13.88	1.78	0.17	6.15
Daily Avera	139.15	1.66	214.57	145.88	13.61	1.38	-1.59	5.96

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	137.82	-1.8	209.06	92.58	13.54	1.29	2.12	5.76
01:00 to C	144.15	0.65	221.19	170.88	13.68	1.29	1.34	5.68
02:00 to C	142.98	1.29	220.04	149.12	13.78	1.27	0.98	5.58
03:00 to C	150.19	-0.21	229.57	88.7	13.55	1.35	-1.62	5.92
04:00 to C	157.77	-9.81	231.58	86.05	13.5	1.42	-0.66	5.91
05:00 to C	139.1	5.9	218.72	264.69	13.82	1.33	-1.42	5.7
06:00 to C	140.32	-0.43	214.26	97.89	13.45	1.27	0.95	5.87
07:00 to C	141.4	-12.41	203.94	100.93	13.34	1.22	-0.4	6.1
08:00 to C	138.07	-15.69	195.56	170.42	13.73	1.16	-0.94	5.75
09:00 to C	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.72
10:00 to 1	144.64	-15.92	205.38	94.13	13.43	1.18	-2.39	6.06
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.08
12:00 to 1	158.03	-11.28	230.5	108.96	13.58	1.49	-0.46	5.95
13:00 to 1	163.09	-18.32	231.21	83.27	13.19	3.1	3.21	6.23
14:00 to 1	166.02	-2.02	252	114.62	13.24	1.62	3.03	6.32
15:00 to 1	156.03	-14.3	224.42	174.86	13.56	1.45	1.4	5.8
16:00 to 1	159.08	-13.91	229.48	155.41	13.61	1.49	3.86	5.77
17:00 to 1	160.69	-2.17	243.69	160.33	13.39	1.54	4.83	6
18:00 to 1	161.12	-2.76	243.76	123.46	13.49	1.43	3.76	5.79
19:00 to 1	150.96	0.1	231.07	150.7	13.67	1.42	5.96	5.45
20:00 to 2	155.21	9.03	246.51	173.34	13.32	1.51	7.75	5.71
21:00 to 2	162.13	8.92	256.99	121.93	13.29	1.43	-0.6	6.2
22:00 to 2	160.42	10.45	255.89	107.31	13.34	2.28	5.25	5.83
23:00 to 2	158.07	13.16	255.01	136.54	13.35	1.51	9.26	5.6
95 Percent	163.09	10.45	255.89	174.86	13.78	2.28	7.75	6.23
Daily Avera	152.15	-3.25	229.54	133.01	13.49	1.5	2.06	5.87

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	139.82	-10.07	203.85	163.55	12.92	1.53	6.29	6.07
01:00 to C	140.99	-21.74	193.97	118.38	13.24	1.39	-0.17	6.08
02:00 to C	141.13	-18.6	197.32	135.99	13.41	1.37	2.72	5.78
03:00 to C	142.09	-3.84	213.56	211.83	13.11	1.36	1.65	6.23
04:00 to C	152.11	-19.44	213.29	135.9	13.1	1.38	-0.84	6.3
05:00 to C	147.81	-17.47	208.67	123.75	13.64	1.3	-0.02	5.74
06:00 to C	154.96	-12.92	224.17	140.04	13.34	1.41	0.03	6.01
07:00 to C	156.7	-28.12	211.64	124.17	13.22	1.45	-0.01	6.22
08:00 to C	162.88	-28.13	221.08	114.57	13.55	1.47	-0.74	5.99
09:00 to C	143.66	-1.58	218.22	138.56	13.62	1.48	1.16	5.77
10:00 to 1	155.69	-8.24	229.95	123.36	13.33	1.62	2.75	6.04
11:00 to 1	161.09	0.99	247.45	114.62	13.61	1.48	3.11	5.85
12:00 to 1	153.46	-5.54	229.25	159.25	13.44	3.41	2.6	5.85
13:00 to 1	172.34	-10.06	253.62	113.3	13.36	1.55	5.39	5.88
14:00 to 1	171.99	-13.78	249.37	143.92	13.19	1.56	9.93	5.76
15:00 to 1	156.69	5.23	244.96	124.91	13.73	1.38	0.22	5.69
16:00 to 1	163.11	-5.9	243.66	139.52	13.51	1.57	8.35	5.41

17:00 to 1	162.4	7.4	255.87	213.09	13.12	1.74	10.33	5.76
18:00 to 1	161.83	-10.87	236.73	151.79	13.34	1.73	10.41	5.41
19:00 to 1	157.3	-9.83	230.84	128.88	13.55	1.7	11.28	5.16
20:00 to 2	163.06	-21.05	228.44	210.19	13.07	1.82	12.14	5.56
21:00 to 2	160.73	-29.55	216.36	181.24	12.95	1.81	9.05	5.76
22:00 to 2	157.95	-32.19	209.47	118.3	13.36	1.75	8.68	5.41
23:00 to 2	150	-25.8	203.7	135.26	13.35	2.56	8.51	5.5
95 Percent	171.99	5.23	253.62	211.83	13.64	2.56	11.28	6.23
Daily Avera	155.41	-13.38	224.39	144.35	13.34	1.66	4.7	5.8

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	144.72	-0.78	220.63	222.83	13.16	1.82	8.91	5.75
01:00 to C	154.4	-2.13	234.11	142.81	13.25	1.78	9.35	5.66
02:00 to C	147.9	4.35	230.64	144.12	13.67	1.71	7.75	5.38
03:00 to C	147.48	1.12	226.78	196.79	13.24	1.59	1.07	6.12
04:00 to C	154.14	5.94	241.77	161.43	13.19	1.64	0.76	6.33
05:00 to C	147.1	12.77	237.84	123.74	13.71	1.61	2.71	5.77
06:00 to C	157.19	-5.93	234.58	134.47	13.4	1.63	4.72	5.7
07:00 to C	150.39	7.51	237.61	175.59	13.47	1.51	-0.82	6.16
08:00 to C	159.05	12.19	255.53	120.63	13.43	1.56	0.69	6.18
09:00 to C	153.42	-3.28	231.46	129.88	13.58	1.32	-0.13	5.98
10:00 to 1	163.78	7.76	258.34	134.86	13.49	1.14	0.28	6.21
11:00 to 1	169.53	-5.13	254.24	118.9	13.45	1.38	0.32	6.24
12:00 to 1	149.99	2.21	231.7	112.07	13.51	2.68	-1.21	6.1
13:00 to 1	166.6	-11.66	243.24	107.99	13.47	1.37	0	6.07
14:00 to 1	169.02	-4.63	253.97	111.63	13.5	1.37	1.87	6.03
15:00 to 1	168.05	-1.78	255.33	110.94	13.59	1.38	-0.24	5.97
16:00 to 1	155.26	-2.75	234.8	130.67	13.71	1.41	1.1	5.85
17:00 to 1	170.2	6.37	266.77	123.8	13.59	1.53	3	6.03
18:00 to 1	166.39	-9.17	245.4	100.08	13.61	1.44	0.16	5.95
19:00 to 1	157.62	-13.16	228	124.75	13.6	1.5	3.42	5.82
20:00 to 2	167.1	-17.69	237.97	100.96	13.53	1.49	3.65	5.89
21:00 to 2	164.56	-0.46	251.32	93.68	13.48	1.44	2.59	5.95
22:00 to 2	162.59	10.42	259.19	95.2	13.67	1.45	3.88	5.82
23:00 to 2	140.37	6.02	220.79	129.43	13.8	1.5	4.8	5.65
95 Percent	169.53	12.19	259.19	196.79	13.71	1.82	8.91	6.24
Daily Avera	157.79	-0.08	241.33	131.14	13.5	1.55	2.44	5.94

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	136.69	20.14	229.29	116.56	13.59	2.31	3.36	5.94
01:00 to C	144.7	14.91	236.3	89.73	13.64	1.53	3.41	5.92

02:00 to C	149.96	10.34	239.78	111.99	13.7	1.46	2.41	5.92
03:00 to C	154.15	-3.3	232.55	105.69	13.56	1.44	1.29	5.96
04:00 to C	149.68	-2.08	226.93	101.87	13.44	1.49	3.62	6.08
05:00 to C	144.58	0.32	221.53	91.55	13.76	1.43	1.67	5.87
06:00 to C	153.24	-5.99	228.46	107.31	13.53	1.49	1.93	5.96
07:00 to C	149.42	-9.24	219.36	104.37	13.52	1.44	2.45	6.05
08:00 to C	153.31	-12.76	221.81	87.64	13.69	1.41	1.61	5.92
09:00 to C	145.95	-7.36	215.93	99.18	13.78	1.26	-0.27	5.93
10:00 to 1	143.45	-4.46	215.02	108.8	13.63	1.13	3.23	5.93
11:00 to 1	144.34	-1.51	219.34	104.89	13.6	1.13	1.82	6.08
12:00 to 1	140.7	-3.66	211.61	94.08	13.51	1.79	1.67	5.93
13:00 to 1	144.12	-11.84	208.67	100.17	13.61	2	2.16	5.87
14:00 to 1	148.12	-12.63	214	114.74	13.5	1.38	3.74	5.92
15:00 to 1	145.87	5.5	228.69	99.47	13.62	1.37	2.85	5.87
16:00 to 1	140.29	-3.52	211.13	177.67	13.81	1.41	2.41	5.69
17:00 to 1	145.55	-9.43	213.27	109.15	13.62	1.45	3.09	5.9
18:00 to 1	144.83	-4.33	217.26	94.52	13.55	1.43	0.05	6.08
19:00 to 1	135.76	2.63	210.34	186.15	13.81	1.45	1.76	5.8
20:00 to 2	129.51	-5.41	192.74	224.3	13.86	1.45	2.22	5.68
21:00 to 2	140.02	1.18	215.41	95.46	13.59	1.42	1.74	5.94
22:00 to 2	148.14	0.68	227.33	111.42	13.72	1.45	1.82	5.88
23:00 to 2	139.39	3.14	216.4	212.72	13.82	2.05	2.02	5.77
95 Percent	153.31	14.91	236.3	212.72	13.82	2.05	3.62	6.08
Daily Avera	144.66	-1.61	219.71	118.73	13.64	1.51	2.17	5.91

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	157.14	-13.16	227.26	94.37	13.54	1.45	1.71	5.88
01:00 to C	158.94	-10.26	232.91	92.49	13.54	1.43	2.67	5.94
02:00 to C	156.45	-4.22	235.15	144.99	13.75	1.38	4.05	5.69
03:00 to C	154.13	-0.14	235.68	124.54	13.72	1.38	2.17	5.72
04:00 to C	158.67	-12.45	230.31	95.71	13.57	1.48	2.98	5.9
05:00 to C	163.48	-5.89	244.23	103.66	13.63	1.51	2.79	5.86
06:00 to C	153.72	-7.2	227.99	187.8	13.81	1.54	3.07	5.56
07:00 to C	168.35	-0.37	257.2	101.59	13.64	1.56	4.04	5.75
08:00 to C	157.87	-1.91	239.64	108.57	13.42	1.53	2.66	6.05
09:00 to C	144.51	-1.12	219.97	128.35	13.95	1.38	-0.82	5.62
10:00 to 1	147.14	3.32	228.45	108.61	13.74	1.49	4.41	5.66
11:00 to 1	147.65	-1.68	224.23	141.48	13.18	1.57	4.01	6.28
12:00 to 1	141.4	9.91	226.24	85.72	13.51	3.1	1.84	6.05
13:00 to 1	130.72	7.11	207.11	104.61	13.97	1.6	2.34	5.53
14:00 to 1	148.57	8.91	236.23	157.19	13.34	1.45	4.06	6.12
15:00 to 1	148.89	-5.19	222.61	107.1	13.39	1.4	1.16	6.07
16:00 to 1	144.82	3.26	224.84	94.69	13.73	1.41	2.93	5.72
17:00 to 1	160.84	-1.82	244.26	102.89	13.62	1.45	3.7	5.79
18:00 to 1	161.22	-7.61	239.07	108.46	13.36	1.43	3.03	6
19:00 to 1	161.99	-16.31	231.54	95.62	13.58	1.43	1.46	5.87

20:00 to 2	139.71	-14.62	199.14	95.03	13.74	1.27	3.43	5.64
21:00 to 2	157.31	17.36	258.05	86.94	13.42	1.41	3.02	6.01
22:00 to 2	154.32	7.34	243.45	77.12	13.56	1.31	0.16	6.05
23:00 to 2	157.48	5.13	246.07	129.53	13.54	1.36	2.44	5.96
95 Percent	163.48	9.91	257.2	157.19	13.95	1.6	4.06	6.12
Daily Avera	153.14	-1.73	232.57	111.54	13.59	1.51	2.64	5.86

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	157.19	-0.09	240.41	99.91	13.39	1.34	2.34	5.93
01:00 to 0	150.82	14.14	244.89	91.15	13.28	1.33	3.9	6.19
02:00 to 0	151.77	1.18	233.38	106.38	13.12	1.34	3.2	6.38
03:00 to 0	144.97	10.79	232.6	87.3	13.59	1.18	-0.95	6.14
04:00 to 0	148.85	8.18	235.93	102.45	13.52	1.34	-1.12	6.16
05:00 to 0	118.7	-2.28	179.33	227.91	14.06	1.29	-0.4	5.51
06:00 to 0	130.98	0.16	200.56	113.22	13.85	1.32	-1.01	5.73
07:00 to 0	157.65	-0.13	241.08	84	13.26	1.44	1.5	6.27
08:00 to 0	160.12	4.3	249.28	105.9	13.11	1.41	1.31	6.45
09:00 to 0	158.19	-4.57	237.46	83.07	13.12	1.25	1.01	6.37
10:00 to 1	152.46	-6.44	226.82	68.61	13.52	1.27	-1.15	6.09
11:00 to 1	140.09	-5.08	209.26	110.1	13.75	1.26	-3.5	5.94
12:00 to 1	129.62	2.02	200.34	170.45	13.76	1.22	-0.05	5.68
13:00 to 1	133.92	7.55	212.45	160.92	13.8	1.24	-1.72	5.82
14:00 to 1	165.66	16.73	270.19	107.96	13.32	2.2	2.18	6.19
15:00 to 1	169.88	-20.06	239.85	92.84	13.24	2.33	0.14	6.24
16:00 to 1	174.01	-32.38	233.86	109.1	13.16	1.4	0.87	6.21
17:00 to 1	170.07	-36.78	223.43	93.83	13.34	1.29	1.47	6
18:00 to 1	152.59	-17.93	215.53	118.28	13.66	1.24	-0.56	5.83
19:00 to 1	155	-29.56	207.6	128.54	13.44	1.33	2.25	5.87
20:00 to 2	157.98	-30.72	210.99	65.15	13.3	1.22	2.03	6.09
21:00 to 2	148.5	-7.43	219.77	70.7	13.2	1.25	1.63	6.15
22:00 to 2	148.52	-6.61	220.63	69.34	13.27	1.25	2.84	6.12
23:00 to 2	146.29	-11.8	212.03	80.65	13.41	1.22	2.87	5.95
95 Percent	170.07	14.14	249.28	170.45	13.85	2.2	3.2	6.38
Daily Avera	150.99	-6.12	224.9	106.16	13.44	1.37	0.79	6.05

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	144.84	0	221.6	102.38	13.33	1.29	7.94	5.62
01:00 to 0	138.34	14.4	226.06	106.66	13.65	1.25	7.71	5.46
02:00 to 0	140.74	2.82	218.15	124.12	13.53	1.23	3.86	5.74
03:00 to 0	150.66	-8.99	221.52	107.76	13.27	1.26	3.57	5.86
04:00 to 0	160.78	-2.14	243.85	82.77	13.2	1.25	2.11	6.17

05:00 to 0	162.83	-11.78	237.34	71.46	13.16	1.28	3.24	6.14
06:00 to 0	152.65	-14.19	219.37	86.29	13.33	1.27	2.82	5.91
07:00 to 0	151.63	-22.28	209.72	116.83	13.22	1.38	8.72	5.66
08:00 to 0	130.57	-21.99	177.78	275.77	13.52	1.3	5.9	5.54
09:00 to 0	120.99	6.71	191.82	389.34	13.75	1.08	9.18	5.24
10:00 to 1	142.62	-0.51	217.7	121.99	13.57	0.94	6.82	5.62
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.16
12:00 to 1	152.58	14.89	248.34	78.21	13.31	0.99	0.35	6.26
13:00 to 1	155.16	6.52	243.91	90.45	13.5	1.1	-1.17	6.07
14:00 to 1	154.79	5.85	242.67	179.79	13.38	2.35	0.52	6.11
15:00 to 1	147.87	0.22	226.47	185.33	13.62	2.03	-0.92	5.89
16:00 to 1	172.38	-0.99	262.76	147.2	13.5	1.4	-1.28	6.03
17:00 to 1	181.91	-6.29	272.04	110.5	13.27	1.4	-0.81	6.25
18:00 to 1	166.02	3.19	257.19	149.08	13.23	1.41	-2.31	6.44
19:00 to 1	157.33	-1.34	239.39	161.99	13.01	1.47	-0.56	6.61
20:00 to 2	145.04	-3.55	218.37	72.93	13.45	1.18	-3.75	6.34
21:00 to 2	130.54	8.49	208.21	100.65	13.66	1.15	-6.41	6.29
22:00 to 2	113.08	6.83	179.84	296.92	14.01	1.15	-4.44	5.78
23:00 to 2	124.68	3.23	194	322.52	13.85	1.21	-3.15	5.91
95 Percent	172.38	14.4	262.76	322.52	13.85	2.03	8.72	6.44
Daily Avera	147.74	-0.91	225.13	151.35	13.45	1.32	1.65	5.96

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	160.76	-11.31	234.65	81.06	13.41	1.26	-2.78	6.2
01:00 to 0	157.29	-5.96	234.7	79.94	13.26	1.26	-1.97	6.45
02:00 to 0	143.15	-6.79	212.23	82.28	13.59	1.31	2.39	5.85
03:00 to 0	129.44	11.74	209.78	125.81	13.71	1.36	5.13	5.48
04:00 to 0	112.1	-1.07	170.44	269.25	13.98	1.32	3.49	5.31
05:00 to 0	125.04	-11.68	179.63	203.47	13.78	1.39	4.35	5.47
06:00 to 0	148.42	-4.61	222.47	72.84	13.41	1.45	3.92	5.84
07:00 to 0	146.8	-10.98	213.63	71.82	13.31	1.51	4.67	5.97
08:00 to 0	128.19	-5.83	190.3	127.76	13.81	1.38	3.98	5.56
09:00 to 0	107.19	0.07	164.07	333.59	13.98	1.1	-0.82	5.58
10:00 to 1	118.57	11.04	192.45	221.01	14.02	0.71	3.02	5.47
11:00 to 1	154.14	18.1	253.93	66.34	13.66	0.75	7.52	5.71
12:00 to 1	143.46	0.26	219.75	70.08	13.7	0.82	1.21	5.77
13:00 to 1	125.53	-33.1	158.97	174.17	13.89	1.03	-2.83	5.49
14:00 to 1	137.46	-24.53	185.78	210.8	13.83	2.27	-1.19	5.58
15:00 to 1	178.71	-3.03	270.4	95.38	13.24	1.42	-0.93	6.34
16:00 to 1	171.06	5.86	267.58	81.73	13.85	1.24	-2.95	5.92
17:00 to 1	161.17	-2.66	243.93	94.29	14.05	1.34	-3.75	5.73
18:00 to 1	162.17	-6.32	241.81	122.18	13.59	1.46	-0.37	5.9
19:00 to 1	167.95	-1.81	255.15	111.81	13.46	1.55	2.19	6.02
20:00 to 2	151.53	-10.28	221.57	60.74	13.73	1.42	1.46	5.72
21:00 to 2	132.04	7.3	209.33	295.72	14.04	1.21	-4.05	5.78
22:00 to 2	161.53	5.65	252.8	53.86	13.81	1.24	-3.99	6.04

23:00 to 2	157.12	-4.51	235.88	73.68	13.83	1.26	-3.02	5.93
95 Percent	171.06	11.74	267.58	295.72	14.04	1.55	5.13	6.34
Daily Avera	145.03	-3.52	218.38	132.48	13.71	1.29	0.61	5.8

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	127.03	5.99	200.35	329.63	14.12	1.33	1.04	5.44
01:00 to 0	144.68	4.82	226.18	154.16	13.95	1.34	-1.05	5.72
02:00 to 0	166.58	12.9	267.76	53.01	13.66	1.31	-2.97	6.24
03:00 to 0	149.47	-1.4	227.29	131.95	13.81	1.21	-4.85	6
04:00 to 0	136.34	9.1	217.69	338.95	14.02	1.23	-2.53	5.71
05:00 to 0	168.36	7.18	264.77	48.17	13.62	1.21	-2.77	6.25
06:00 to 0	145.57	8.79	231.5	65.48	13.94	1.12	-8.2	6.17
07:00 to 0	126.11	2.39	195.33	199.45	14.14	1.16	-6.36	5.8
08:00 to 0	136.72	7.57	216.75	51.6	13.98	1.17	-4.29	5.97
09:00 to 0	147.66	-2.14	223.78	48.39	13.6	1.06	-8.25	6.35
10:00 to 1	133.92	-6.25	198.65	88.62	13.94	0.95	-5.55	5.92
11:00 to 1	138.79	-13.07	199.29	92.62	13.95	0.92	-4.02	5.84
12:00 to 1	168.29	-15.44	242.04	40.4	13.33	1.04	-4.31	6.34
13:00 to 1	163.21	-16.83	232.88	47.16	13.58	1.05	-5.17	6.18
14:00 to 1	157.03	-8.41	231.85	67.64	13.87	2.75	-4.38	5.96
15:00 to 1	176.9	0.64	271.29	71.87	13.43	1.21	-4.08	6.28
16:00 to 1	174.06	1.91	268.23	68.7	13.51	1.15	-4.51	6.29
17:00 to 1	160.6	-8.62	237.11	82.74	13.85	1.13	-4.23	5.88
18:00 to 1	157.4	-0.69	240.14	82.92	13.55	1.18	-2.2	6.07
19:00 to 1	159.6	-6.45	237.75	114.14	13.32	1.22	-2.11	6.42
20:00 to 2	148.76	-7.43	220.18	61.91	13.58	1.02	-5.53	6.32
21:00 to 2	114.42	12.64	187.7	487.34	14.18	0.91	-6.15	5.76
22:00 to 2	152.06	2.74	235.39	67.94	13.66	1.03	-2.32	6.08
23:00 to 2	154.28	3.82	239.88	58.13	13.77	1	-6.02	6.24
95 Percent	174.06	12.64	268.23	338.95	14.14	1.34	-1.05	6.35
Daily Avera	150.33	-0.26	229.74	118.87	13.77	1.2	-4.2	6.05

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	134.75	-9.28	196.9	239.88	13.73	1.01	-7.05	6.11
01:00 to 0	143.12	-6.59	212.38	131.94	13.66	1.05	-4.04	6.11
02:00 to 0	161.82	-9.92	237.66	47.67	13.42	0.99	-1.98	6.33
03:00 to 0	144	2.83	223.15	112.61	13.67	1.03	-6.16	6.24
04:00 to 0	136.14	4.91	213.21	242.77	13.77	1.05	-3.87	6.07
05:00 to 0	156.67	7.92	247.62	57.83	13.67	1.06	-4.24	6.29
06:00 to 0	147.32	-8.58	216.82	98.99	13.73	1.05	-6.37	6.1
07:00 to 0	146.2	0.19	223.87	125.53	13.64	1.11	-4.99	6.23

08:00 to 0	135.4	-0.3	206.85	215.09	13.79	1.06	-4.19	6.07
09:00 to 0	161.74	-7.72	239.74	82.27	13.5	1.18	-4.21	6.24
10:00 to 1	168.02	-1.24	255.84	62.77	13.48	1.11	-3.59	6.36
11:00 to 1	170.22	-8.32	252.13	61.14	13.44	1.06	-3.12	6.38
12:00 to 1	158.33	8.89	251.14	61.56	13.75	0.98	-6.21	6.19
13:00 to 1	161.73	10.55	258	80.05	13.73	1.08	-3.71	6.08
14:00 to 1	153.27	5.05	239.55	104.76	13.87	2.79	-3.02	5.93
15:00 to 1	158.42	-2.09	240.29	84.21	13.94	1.17	-3.81	5.75
16:00 to 1	167.4	-1.05	255.07	82.44	13.58	1.22	-2	6.11
17:00 to 1	163.83	6.41	257.07	83.59	13.51	1.18	-2.12	6.24
18:00 to 1	159.51	-11.85	232.2	87.84	13.39	1.22	-2.87	6.28
19:00 to 1	157.97	-8.02	233.68	76.7	13.65	1.19	-3.74	6.09
20:00 to 2	145.24	-13.37	208.85	51.29	13.65	1.1	-4.15	6.15
21:00 to 2	122.6	1.42	189	70.98	13.93	1.07	-6.52	5.91
22:00 to 2	126.18	4.49	197.54	62.27	13.83	1.09	-4.89	5.97
23:00 to 2	138.81	1.48	213.86	48.23	13.59	1.15	-3.43	6.21
95 Percent	168.02	8.89	257.07	239.88	13.93	1.22	-2	6.36
Daily Avera	150.78	-1.42	229.27	98.85	13.66	1.17	-4.18	6.14

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	137.33	8.19	218.3	52.53	13.39	1.17	-3.65	6.36
01:00 to 0	142.23	4.8	222.41	41.48	13.52	1.16	-4.03	6.33
02:00 to 0	144.41	3.81	224.75	43.94	13.81	1.16	-5.12	6.13
03:00 to 0	136.62	-5.87	203.16	47.24	13.72	1.16	-6.79	6.13
04:00 to 0	129.19	-3.3	194.37	55.07	13.79	1.22	-3.27	5.9
05:00 to 0	133.78	-4.94	199.74	48.12	13.69	1.2	-3.84	6.11
06:00 to 0	131.87	-19.31	182.45	42.28	13.37	1.21	-4.84	6.41
07:00 to 0	139.95	-18.04	196.09	50.12	13.45	1.28	-2.45	6.26
08:00 to 0	149.61	-18.06	210.84	49.97	13.55	1.26	-2.74	6.21
09:00 to 0	133.5	5.92	210.17	106.19	13.83	1.12	-4.79	6.06
10:00 to 1	126.75	18.34	212.27	144.24	13.88	0.93	-4.91	6.09
11:00 to 1	120.43	11.23	195.49	217.85	13.94	0.94	-3.21	5.92
12:00 to 1	134.66	4.84	210.87	76.98	13.7	1	-3.55	6.09
13:00 to 1	153.21	0.13	234.54	65.49	13.44	2.29	-2.37	6.28
14:00 to 1	164.86	-3	249.24	82.96	13.49	1.57	-2.53	6.23
15:00 to 1	157.79	-8.86	232.56	80.17	13.58	1.18	-4	6.16
16:00 to 1	150.54	-21	209.32	94.83	13.59	1.27	-2.46	6.03
17:00 to 1	147.13	-23.4	201.72	141.8	13.67	1.28	-3.95	6.06
18:00 to 1	150.22	11.06	240.9	113.89	13.77	1.26	-2.87	5.96
19:00 to 1	158.6	16.17	258.83	90.68	13.57	1.3	-0.56	6.07
20:00 to 2	158.25	10.25	252.37	83.16	13.44	1.27	-1.64	6.28
21:00 to 2	157.32	-9.22	231.49	95.26	13.29	1.29	-2.41	6.32
22:00 to 2	151.08	-10.72	220.42	84.31	13.28	1.26	0.33	6.16
23:00 to 2	151.68	-21.94	210.13	78.24	13.34	1.22	-0.23	6.09
95 Percent	158.6	16.17	252.37	144.24	13.88	1.57	-0.23	6.36
Daily Avera	144.21	-3.04	217.6	82.78	13.59	1.25	-3.16	6.15

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	134.1	-2.02	203.16	94.13	13.53	1.11	-2.45	6.1
01:00 to 0	115.69	2.16	179.17	171.57	13.67	1.09	-4.73	6.05
02:00 to 0	118.8	-5.35	176.42	121.14	13.55	1.13	-2.54	6.06
03:00 to 0	127.06	-9.73	184.67	44.34	13.42	1.11	-1.35	6.07
04:00 to 0	118.58	-0.98	180.45	129.86	13.5	1.07	-3.06	6.12
05:00 to 0	121.94	-9.89	176.69	65.43	13.58	1.09	-4.09	6.11
06:00 to 0	120.61	-0.53	184.01	114.77	13.44	1.12	-4.39	6.27
07:00 to 0	112.08	9.26	180.74	172.34	13.68	1.09	-4.78	6.16
08:00 to 0	111.12	6.47	176.49	246.41	13.74	1.07	-5.02	6.09
09:00 to 0	113.12	-15.04	158.04	105.22	13.45	1.08	-6.06	6.22
10:00 to 1	114.84	-17.94	157.76	63.01	13.38	1.13	-1.84	6.22
11:00 to 1	111.46	-24.29	146.25	78.98	13.42	1.09	-2.45	6.19
12:00 to 1	111.04	2.61	172.5	64.82	13.62	1.03	-4.72	6.12
13:00 to 1	112.52	-5.74	166.42	73.78	13.54	1.13	-3.98	6.19
14:00 to 1	110.69	1.46	170.81	174.23	13.6	2.28	-0.85	6.07
15:00 to 1	129.64	-3.93	194.43	109.98	13.48	1.31	-2.37	6.1
16:00 to 1	147.35	-0.5	224.95	112.47	13.27	1.33	-1.06	6.31
17:00 to 1	146.51	-5.92	218.24	107.24	13.33	1.3	-0.74	6.22
18:00 to 1	155.16	-22.55	214.84	97.95	13.23	1.35	0.43	6.15
19:00 to 1	159.72	-36.65	207.71	86.6	13.42	1.3	-1.76	6.05
20:00 to 2	148.3	-45.51	181.4	97.13	13.35	1.23	-2.26	6.19
21:00 to 2	129.27	-3.93	193.85	284.38	13.69	1.18	-3.95	5.97
22:00 to 2	138.51	9.63	221.55	226.54	13.65	1.23	-2.91	6.08
23:00 to 2	153.02	-10.37	223.74	72.29	13.47	1.31	-2.58	6.24
95 Percent	155.16	9.26	223.74	246.41	13.69	1.35	-0.74	6.27
Daily Avera	127.55	-7.89	187.26	121.44	13.5	1.22	-2.9	6.14

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	152.97	12.32	246.37	78.83	13.33	1.28	-2.47	6.3
01:00 to 0	149.35	10.04	238.54	64.55	13.41	1.31	-1.94	6.31
02:00 to 0	145.41	1.9	224.37	89.29	13.58	1.3	-3.13	6.2
03:00 to 0	137.67	6.94	217.58	89.48	13.53	1.31	-3.59	6.24
04:00 to 0	129.4	18.55	216.53	215.53	13.75	1.29	-2.86	6.06
05:00 to 0	140.23	6.07	220.62	96.97	13.57	1.36	-2.44	6.22
06:00 to 0	145.13	-21.49	200.56	61.89	13.27	1.36	-3	6.3
07:00 to 0	150.12	-21.99	207.7	61.21	13.16	1.4	-2.03	6.45
08:00 to 0	147.57	-16.88	208.91	58.04	13.22	1.35	-2.31	6.46
09:00 to 0	133.39	9.35	213.43	91.81	13.43	1.3	-3.7	6.33
10:00 to 1	126.44	4.34	197.79	128.03	13.57	1.21	-4.2	6.27

11:00 to 1	122.32	17.49	204.65	352.85	13.78	1.14	-3.26	6.07
12:00 to 1	143.31	-14.95	204.31	114.17	13.4	1.3	-4.01	6.17
13:00 to 1	148.98	3.81	231.75	77.81	13.49	1.31	-2.01	6.2
14:00 to 1	150.11	3.1	232.76	76.67	13.21	3.24	-1.88	6.47
15:00 to 1	153.22	4.25	238.67	81.75	13.2	1.47	-3.24	6.48
16:00 to 1	153.5	6.67	241.53	94.05	13.34	1.52	-1.54	6.34
17:00 to 1	134.32	2.39	207.9	108.59	13.6	1.48	-1.59	6.03
18:00 to 1	142.12	0.31	217.75	124.12	13.35	1.54	-2.55	6.22
19:00 to 1	152.26	-8.25	224.71	132.04	13.18	1.7	-0.86	6.42
20:00 to 2	145.61	-35.57	187.21	86.9	13.05	1.59	-1.85	6.55
21:00 to 2	140.86	3.38	218.89	89.19	13.15	1.54	-2.32	6.53
22:00 to 2	140.26	1.05	215.64	96.13	13.31	1.52	-1.87	6.4
23:00 to 2	137.8	3.83	214.66	124.98	13.34	1.52	-1.9	6.39
95 Percent	153.22	17.49	241.53	215.53	13.75	1.7	-1.54	6.53
Daily Avera	142.6	-0.14	218.03	108.12	13.38	1.47	-2.52	6.31

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	122.78	-0.47	187.39	225.71	13.5	1.45	-3.49	6.21
01:00 to 0	131.46	1.77	202.91	169.35	13.51	1.45	-1.22	6.2
02:00 to 0	138.97	7.58	220.19	99.56	13.34	1.48	-0.38	6.41
03:00 to 0	143.54	-2.86	216.75	82.4	13.19	1.41	-1.59	6.44
04:00 to 0	144.6	-3.84	217.39	82.74	13.21	1.44	-0.79	6.49
05:00 to 0	135.23	3.13	210.02	84.09	13.45	1.4	-1	6.33
06:00 to 0	123.6	-1.98	187.13	111.94	13.37	1.39	-1.99	6.29
07:00 to 0	115.34	-2.68	173.8	206.69	13.58	1.35	-1.2	6.1
08:00 to 0	119.02	3.37	185.46	121.18	13.57	1.31	0.2	6.09
09:00 to 0	123.45	2.44	191.32	68.98	13.41	1.22	-2	6.29
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.42
11:00 to 1	128.95	6.25	203.55	68.01	13.27	1.07	-2.48	6.44
12:00 to 1	130.22	0.29	199.52	79.44	13.5	1.11	-3.38	6.25
13:00 to 1	125.85	-1	191.55	110.83	13.51	1.22	-2.48	6.27
14:00 to 1	128.43	-5.27	191.23	164.16	13.65	2.14	-1.26	6.03
15:00 to 1	140.49	3.95	218.9	97.98	13.46	2.28	-1.82	6.17
16:00 to 1	151.46	2.88	234.62	104.43	13.41	1.38	-0.59	6.21
17:00 to 1	143.41	12.44	231.86	101.04	13.39	1.37	0.5	6.23
18:00 to 1	147.77	-4.59	221.5	87.69	13.27	1.37	-2.68	6.36
19:00 to 1	146.98	-2.64	222.24	78.84	13.34	1.34	-0.49	6.16
20:00 to 2	132.89	11.96	215.28	104.16	13.59	1.14	-3.19	6.12
21:00 to 2	127.08	-18.52	175.92	159.11	13.6	1.12	-2.86	5.88
22:00 to 2	138.62	-17.34	194.75	70.22	13.45	1.12	-2.04	6.11
23:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
95 Percent	147.77	11.96	231.86	206.69	13.6	2.14	0.2	6.44
Daily Avera	133.64	-0.23	204.24	112.66	13.43	1.39	-1.65	6.24

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
01:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
02:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to C	111.85	-46.43	124.7	1108.85	1.97	6.42	6.1	17.29
04:00 to C	129.21	-9.2	188.49	67.5	8.56	1.56	-31.54	14.19
05:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to C	Off	Off	Off	Off	Off	Off	Off	Off
10:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
11:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
12:00 to 1	102.6	-6.87	150.1	36.25	5.72	1.65	-15.91	14.95
13:00 to 1	127.98	-4.23	191.58	8.74	11.25	0.97	-31.95	10.38
14:00 to 1	121.1	-10.13	175.15	32.78	12.79	1.07	-9.16	7.42
15:00 to 1	121.57	-4.21	181.8	84.32	12.86	1.15	-6.21	7.06
16:00 to 1	136.01	0.15	208.25	11.15	12.58	1.16	-7.3	7.56
17:00 to 1	146.05	-8.06	215.4	60.46	13.17	2.29	-2.93	6.64
18:00 to 1	142.23	-3.38	214.23	95.12	13.43	1.75	-1.17	6.16
19:00 to 1	132.28	-4.92	197.47	108.34	13.67	1.58	-1.93	6.05
20:00 to 2	129.79	7	205.58	75.15	13.55	1.35	-1.4	6.25
21:00 to 2	133.98	-6.58	198.41	49.64	13.41	1.27	-2.63	6.27
22:00 to 2	145.62	-3.61	219.19	53.18	13.14	1.37	0.03	6.44
23:00 to 2	146.99	-6.13	218.77	44.28	13.35	1.35	0.43	6.2
95 Percent	146.99	7	219.19	1108.85	13.67	6.42	6.1	17.29
Daily Avera	130.52	-7.61	192.08	131.13	11.39	1.78	-7.54	8.78

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	141.97	-22.94	194.27	51.07	13.26	1.32	-1.92	6.24
01:00 to C	134.29	-24.98	180.48	85.08	13.36	1.34	0.26	6.11
02:00 to C	132.67	-18.63	184.37	101.54	13.43	1.36	1.53	6.02
03:00 to C	137.56	-1.87	208.61	48.3	13.28	1.37	-0.01	6.25
04:00 to C	145.03	-4.66	217.24	50.53	13.15	1.41	0.66	6.37
05:00 to C	141.91	1.96	219.08	56.61	13.39	1.38	-0.28	6.24
06:00 to C	131.09	-7.32	193.26	77.51	13.45	1.34	-2.38	6.24
07:00 to C	134.5	-6.34	199.45	75.86	13.46	1.38	0.05	6.17
08:00 to C	135.81	6.21	213.99	72.84	13.48	1.37	0.01	6.24
09:00 to C	135.36	1.29	208.39	47.67	13.18	1.13	-1.42	6.44
10:00 to 1	132.57	9.4	212.23	42.87	13.37	0.94	-2.43	6.47
11:00 to 1	133.96	8.38	213.33	49.06	13.52	1.08	-3.6	6.4
12:00 to 1	128.49	1.05	197.64	94.32	13.42	1.12	-3.22	6.31
13:00 to 1	133.28	-0.92	203	75.8	13.51	1.11	-4.98	6.32

14:00 to 1	140.58	-7.01	208.07	54.47	13.28	2.32	-3.11	6.52
15:00 to 1	149	11.85	239.82	88.7	13.29	1.44	-3.77	6.52
16:00 to 1	148.46	2.22	229.37	79.74	13.39	1.36	-3.58	6.46
17:00 to 1	144.92	0.63	222.37	86.17	13.45	1.38	-1.91	6.35
18:00 to 1	134.21	-4.58	200.77	128.2	13.56	1.36	-2.62	6.14
19:00 to 1	144.9	12.01	233.71	84.32	13.48	1.4	-1.01	6.24
20:00 to 2	140.66	4.08	219.28	57.61	13.36	1.29	-1.19	6.4
21:00 to 2	135.51	6.46	213.79	47.16	13.39	1.16	-2.33	6.3
22:00 to 2	134.78	-0.77	205.44	62.83	13.41	1.17	-2.7	6.28
23:00 to 2	129.03	-2.32	195.09	81.36	13.52	1.17	-2.56	6.28
95 Percent	148.46	11.85	233.71	101.54	13.52	1.44	0.66	6.52
Daily Avera	137.52	-1.53	208.88	70.82	13.39	1.32	-1.77	6.3

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	117.4	-19.94	159.68	250.76	13.42	1.23	-3.02	6.17
01:00 to 0	129.21	-15.58	182.11	74.37	13.26	1.28	-1.82	6.32
02:00 to 0	128.65	-15.28	181.55	56.23	13.27	1.29	-1.48	6.31
03:00 to 0	129.19	3.95	201.62	56.64	13.22	1.31	-2.86	6.46
04:00 to 0	121.76	2.25	188.54	124.66	13.41	1.26	-4.48	6.38
05:00 to 0	114.94	2.84	178.69	214	13.48	1.24	-5.21	6.37
06:00 to 0	114.33	2.84	177.76	152.14	13.5	1.23	-4.45	6.22
07:00 to 0	99.45	-0.9	151.25	93.76	13.3	1.12	-6.59	6.6
08:00 to 0	113.58	-2.7	171.07	80.42	13.02	1.13	-6.94	6.85
09:00 to 0	121.16	4.68	190.06	53.1	13.34	1.17	-4.57	6.36
10:00 to 1	122.01	0.59	187.26	68.59	13.34	1.21	-2.51	6.32
11:00 to 1	123.03	-4.99	183.25	117.44	13.34	1.2	-1.32	6.25
12:00 to 1	120.76	3.1	187.87	131.58	13.42	1.17	-1.29	6.18
13:00 to 1	133.09	2.81	206.44	57.66	13.34	1.16	1.23	6.1
14:00 to 1	139.3	8.91	222.05	73.03	13.18	2.75	2.02	6.3
15:00 to 1	145.26	-0.11	222.15	82.52	13.31	1.18	-1.6	6.28
16:00 to 1	142.55	1.73	219.83	108.81	13.41	1.22	-1.85	6.27
17:00 to 1	134.69	-1	205.07	143.16	13.61	1.2	-0.78	6.04
18:00 to 1	140.05	-4.04	210.24	91.78	13.5	1.25	-0.69	6.02
19:00 to 1	144.88	-12.33	209.34	76.37	13.4	1.33	1.25	6.03
20:00 to 2	139.94	-18.7	195.41	45.25	13.31	1.27	2.13	6.12
21:00 to 2	128.24	-0.3	195.9	61.89	13.47	1.23	-0.59	6.14
22:00 to 2	122.31	-1.09	186.04	182.48	13.5	1.28	-2.51	6.24
23:00 to 2	121.97	-1.84	184.78	243.79	13.6	1.31	-2.74	6.18
95 Percent	144.88	4.68	222.05	243.79	13.6	1.33	2.02	6.6
Daily Avera	126.99	-2.71	191.58	110.02	13.37	1.29	-2.11	6.27

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	127.33	7.77	202.59	147.33	13.52	1.27	-4.46	6.35
01:00 to 0	137.61	6.5	217.05	54.69	13.38	1.34	-3.33	6.47
02:00 to 0	141.44	-1.01	215.39	54.56	13.32	1.31	-4.51	6.56
03:00 to 0	132.44	-3.38	199.25	109.27	13.43	1.3	-4.35	6.39
04:00 to 0	124.84	15.6	206.6	153.34	13.61	1.22	-5.21	6.39
05:00 to 0	124.98	11.37	202.59	123.67	13.62	1.26	-5.32	6.38
06:00 to 0	133.92	-11.16	193.74	70.19	13.33	1.34	-5.49	6.48
07:00 to 0	131.34	-4.38	196.57	89.99	13.38	1.35	-5.23	6.54
08:00 to 0	139.58	-15.27	198.29	70.74	13.35	1.34	-4.54	6.55
09:00 to 0	129.3	-2.04	195.78	235.06	13.46	1.29	-5.06	6.36
10:00 to 1	125.87	-2.64	189.94	270.02	13.5	1.31	-5.86	6.42
11:00 to 1	119.77	7.45	190.69	328.4	13.54	1.3	-3.22	6.26
12:00 to 1	126.97	-1.16	193.11	207.95	13.56	1.27	-4.8	6.23
13:00 to 1	152.28	-5.22	227.77	105.6	13.35	2.15	-1.98	6.33
14:00 to 1	158.19	1.45	243.48	83.4	13.35	2.3	-0.55	6.37
15:00 to 1	154.36	-6.87	229.3	99.5	13.49	1.29	-3.76	6.22
16:00 to 1	148.06	-9.33	217.2	151.25	13.48	1.31	-2.61	6.21
17:00 to 1	137.14	-7.23	202.59	277.8	13.67	1.29	-1.24	5.94
18:00 to 1	151.58	-0.86	231.07	132.73	13.54	1.32	-1.91	6.07
19:00 to 1	150.33	7.52	237.52	109.85	13.48	1.39	-0.27	6.22
20:00 to 2	143.55	9.06	228.69	66.86	13.43	1.21	-0.78	6.35
21:00 to 2	143.79	-7.11	212.89	54.44	13.28	1.2	-2.95	6.42
22:00 to 2	149.32	-5.8	222.66	64.17	13.49	1.17	-2.96	6.29
23:00 to 2	147.9	-4.77	221.52	112.42	13.54	1.17	-1.91	6.21
95 Percent	154.36	11.37	237.52	277.8	13.62	2.15	-0.55	6.55
Daily Avera	138.83	-0.9	211.51	132.22	13.46	1.36	-3.43	6.33

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	137.77	-8	202.79	116.34	13.41	1.18	-2.52	6.17
01:00 to 0	139.79	-6.39	207.49	124.23	13.44	1.2	-0.09	6.07
02:00 to 0	148.33	-16.39	210.54	68.32	13.32	1.21	-2.22	6.32
03:00 to 0	151.91	4.42	236.84	59.59	13.27	1.21	-0.07	6.28
04:00 to 0	161.47	13.52	260.57	64.7	13.45	1.22	1.99	6.04
05:00 to 0	167.19	2.81	258.61	70.12	13.5	1.23	2.62	5.93
06:00 to 0	147.39	2.74	228.25	90.89	13.5	1.2	1.74	5.89
07:00 to 0	131.09	-2.85	197.72	209.87	13.59	1.19	1.7	5.81
08:00 to 0	138.73	-1.69	210.57	82.57	13.46	1.22	3.58	5.88
09:00 to 0	139.65	-0.41	213.26	62.59	13.54	1.15	-0.97	6.07
10:00 to 1	143.63	11.1	230.85	61.14	13.43	1.14	-0.17	6.29
11:00 to 1	146.39	7.74	231.71	59.92	13.5	1.09	-1.89	6.33
12:00 to 1	137.44	6.43	216.71	107.81	13.64	1.04	-4.16	6.21
13:00 to 1	137.97	-0.93	210.17	108.77	13.51	1.12	-3.42	6.27
14:00 to 1	143.55	0.07	219.71	119.04	13.65	3.16	-2.02	6.09
15:00 to 1	195.52	-3.72	295.43	95.46	13.33	1.42	1.4	6.09
16:00 to 1	183.89	-10.47	270.88	85.7	13.33	1.39	-0.04	6.19

17:00 to 1	178.71	-3.08	270.35	97.19	13.39	1.59	1.61	6.13
18:00 to 1	171.51	-16.78	245.62	87.18	13.37	1.59	-0.41	6.09
19:00 to 1	164.84	-12.1	240.11	86.56	13.55	1.52	1.09	5.92
20:00 to 2	149.73	-10.69	218.4	62.58	13.46	1.23	-1.04	6.17
21:00 to 2	142.07	4.37	221.74	64.61	13.63	1.18	-2.64	6.06
22:00 to 2	155.74	5.53	243.81	64.56	13.56	1.24	-0.49	6.1
23:00 to 2	151.14	18.32	249.57	65.13	13.5	1.27	2.02	6.09
95 Percent	183.89	13.52	270.88	124.23	13.64	1.59	2.62	6.32
Daily Avera	152.73	-0.68	232.99	88.12	13.47	1.33	-0.18	6.1

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	155.27	-3.25	234.32	59.06	13.37	1.24	0.88	6.11
01:00 to 0	155.54	-14	223.98	57.17	13.28	1.25	-0.47	6.26
02:00 to 0	143.62	-24.28	195.45	55.29	13.57	1.19	-2.68	5.99
03:00 to 0	140.66	6.24	221.44	62.98	13.56	1.24	-4.74	6.25
04:00 to 0	137.68	15.99	226.64	67.64	13.66	1.23	-3.69	6.18
05:00 to 0	144.81	16.99	238.55	64.06	13.65	1.25	-0.74	6.08
06:00 to 0	154.13	1.46	237.28	63.02	13.42	1.21	1.01	6.03
07:00 to 0	156.12	4.04	242.91	61.18	13.44	1.19	0.68	6.09
08:00 to 0	156.3	4.88	244.02	58.88	13.51	1.19	-0.2	6.08
09:00 to 0	145.6	2.35	225.11	68.81	13.61	1.27	0.68	5.92
10:00 to 1	139.66	-0.21	213.47	66.05	13.74	1.18	1.29	5.76
11:00 to 1	142.33	11.01	228.77	77.08	13.77	1.15	1.48	5.75
12:00 to 1	164.49	-0.83	250.84	64.84	13.43	1.18	0.58	5.98
13:00 to 1	178.84	-8.91	264.71	69.59	13.42	1.39	-0.24	6.07
14:00 to 1	186.76	-22.47	263.27	71.74	13.26	3.1	-1.51	6.25
15:00 to 1	179.66	10.17	285.05	83.57	13.43	1.4	-2.11	6.21
16:00 to 1	175.61	15.72	284.4	79.8	13.46	1.3	-0.24	6.17
17:00 to 1	163.58	6.44	256.71	74.13	13.66	1.19	-0.85	5.97
18:00 to 1	168.23	-15.42	241.97	86.12	13.38	1.31	1.72	5.94
19:00 to 1	177.26	-20.22	250.98	90.22	13.16	1.39	2.59	6.15
20:00 to 2	163.39	-25.23	224.76	58.5	13.08	1.18	3.04	6.2
21:00 to 2	151.64	12.53	244.54	60.89	13.47	1.14	2.2	6
22:00 to 2	139.31	2.59	215.73	57.47	13.65	1.11	-1.83	6.01
23:00 to 2	136.5	1.57	210.41	78.83	13.7	1.11	-2.72	5.97
95 Percent	179.66	15.99	284.4	86.12	13.74	1.4	2.59	6.25
Daily Avera	156.54	-0.95	238.55	68.21	13.49	1.31	-0.24	6.06

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	132.02	2.9	204.88	108.88	13.86	1.03	-3.64	5.82
01:00 to 0	147.71	9.38	235.37	73.55	13.62	1.09	-0.72	6

02:00 to C	158.2	7.09	249.14	56.62	13.57	1.08	-2.54	6.15
03:00 to C	160.43	-5.16	240.3	56.69	13.32	1.09	-0.83	6.18
04:00 to C	159.73	0.99	245.37	55.6	13.44	1.07	-0.35	6.05
05:00 to C	149.07	9.01	237.09	53.46	13.75	1.02	-1.44	5.84
06:00 to C	133.53	-7.32	196.98	63.54	13.76	1.04	-0.87	5.72
07:00 to C	135.2	-24.45	182.41	51.74	13.62	1.18	-3.86	5.95
08:00 to C	142.44	-44.58	173.36	48.57	13.48	1.32	-4.1	6.11
09:00 to C	143.52	0.83	220.42	61.71	13.54	1.33	-5.03	6.3
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.41
11:00 to 1	147.87	9.45	235.68	53.86	13.57	1.22	-4.44	6.25
12:00 to 1	143.81	-0.05	219.97	49.83	13.56	1.18	-2.76	6.07
13:00 to 1	149.29	-6.45	221.97	55.94	13.62	1.24	-2.61	5.97
14:00 to 1	161.65	-10.17	237.15	56.69	13.55	2.76	-1.26	6
15:00 to 1	177.03	-6.24	264.61	81.65	13.33	1.32	-2.49	6.19
16:00 to 1	173.72	-7.72	258.07	79.27	13.26	1.38	-2.2	6.31
17:00 to 1	168.06	-6.69	250.44	81.54	13.18	1.44	-1.61	6.46
18:00 to 1	163.08	4.6	254.12	80.86	13.34	1.51	-1.78	6.27
19:00 to 1	153.59	14.63	249.63	77.96	13.79	1.37	-0.44	5.89
20:00 to 2	136.82	13.95	223.28	52.44	13.71	1.19	-1.19	6.05
21:00 to 2	136.59	0.18	209.16	56.96	13.52	1.18	-1.9	6.07
22:00 to 2	152.03	-3.92	228.68	57.05	13.21	1.2	-1.91	6.45
23:00 to 2	153	-2.46	231.64	60.85	13.27	1.18	-2.33	6.48
95 Percent	173.72	13.95	258.07	81.65	13.79	1.51	-0.44	6.46
Daily Average	151.23	-2.27	229.12	64.14	13.52	1.28	-2.19	6.12

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	153.47	-2.57	232.24	56.09	13.28	1.15	-2.45	6.39
01:00 to C	154.71	-0.01	236.7	55.48	13.38	1.14	-3.38	6.37
02:00 to C	143.75	-6.11	213.82	50.88	13.63	1.15	-2.89	6.05
03:00 to C	126.36	-11.4	181.93	73.55	13.8	1.16	-5.22	5.93
04:00 to C	133.79	-8.41	196.28	98.93	13.76	1.21	-3.15	5.97
05:00 to C	149.76	-5.62	223.52	61.59	13.46	1.3	-2.14	6.33
06:00 to C	149.16	-6.76	221.46	63.21	13.3	1.28	-2.33	6.31
07:00 to C	147.41	-6.27	219.27	56.55	13.4	1.29	-0.53	6.17
08:00 to C	141.1	-18.3	197.58	55.94	13.59	1.27	-4.09	6.15
09:00 to C	130.32	4.79	204.18	79.08	13.73	1.18	-3.55	5.95
10:00 to 1	121.96	4.23	190.83	170.97	13.8	1.15	-2.97	5.85
11:00 to 1	133.12	7.88	211.55	129.8	13.72	1.07	-1.61	6
12:00 to 1	159.13	-8.14	235.33	60.69	13.48	1.01	-2.43	6.08
13:00 to 1	163.03	-6.33	243.1	56.75	13.36	1.07	-0.6	6.15
14:00 to 1	167.14	-16.26	239.47	63.42	13.35	1.46	-2.69	6.2
15:00 to 1	167.05	-9.29	246.3	62.63	13.52	2.48	-3.74	6.11
16:00 to 1	169.55	-10.1	249.31	89.44	13.45	1.39	-2.52	6.18
17:00 to 1	159.38	4.13	247.99	97.83	13.64	1.37	0.33	5.91
18:00 to 1	156.91	-3.9	236.18	89.24	13.55	1.31	-2.2	6.07
19:00 to 1	161.54	0.14	247.3	89.66	13.47	1.33	-0.79	6.14

20:00 to 2	156.82	0.45	240.39	62.4	13.37	1.26	1.32	6.17
21:00 to 2	160.82	-18.47	227.58	59.73	13.32	1.23	-0.56	6.1
22:00 to 2	144.69	-21.17	200.21	85.07	13.52	1.26	-0.67	5.96
23:00 to 2	139.35	-30.14	183.06	138.81	13.56	1.29	-0.51	5.89
95 Percent	167.14	4.79	247.99	138.81	13.8	1.46	0.33	6.37
Daily Avera	149.6	-6.98	221.9	79.49	13.52	1.28	-2.06	6.1

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	133.9	11.26	216.13	160.31	13.72	1.29	1.13	5.76
01:00 to 0	148.54	-8.04	219.22	80.45	13.54	1.31	0.36	5.98
02:00 to 0	153.93	-3.6	231.92	57.23	13.44	1.32	2.81	5.98
03:00 to 0	145.27	-1.31	220.96	53.8	13.42	1.3	2.04	6.01
04:00 to 0	139.42	12.33	225.65	63.94	13.51	1.33	2.58	5.94
05:00 to 0	130.23	6.46	205.72	112.59	13.75	1.3	1.82	5.77
06:00 to 0	123.2	-18.56	169.94	169.84	13.7	1.26	0.08	5.77
07:00 to 0	127.26	-16.41	178.31	113.43	13.63	1.27	0.27	5.87
08:00 to 0	137.24	-19.53	190.44	60.9	13.44	1.31	3.46	5.93
09:00 to 0	134.47	0.98	206.71	53.7	13.54	1.17	3.47	5.9
10:00 to 1	136.66	-3.53	205.56	52.92	13.52	1.05	3.67	5.93
11:00 to 1	138.72	-11.5	200.74	58.43	13.7	0.97	2.68	5.81
12:00 to 1	138.44	6.26	218.07	105.43	13.68	1.01	2.46	5.82
13:00 to 1	131.83	-4.23	197.46	193.51	13.8	1.06	1.43	5.73
14:00 to 1	152.33	1.71	234.77	186.84	13.75	1.71	1.87	5.77
15:00 to 1	169.89	-1.17	258.76	80.64	13.45	1.99	-0.34	6.15
16:00 to 1	176.14	1.93	271.42	94.54	13.5	1.26	1.06	6.1
17:00 to 1	168.85	4.67	263.01	85.09	13.58	1.29	5.57	5.79
18:00 to 1	161.17	2.2	248.79	81.14	13.65	1.29	5.46	5.66
19:00 to 1	152.68	-0.06	233.54	108.83	13.67	1.29	2.49	5.83
20:00 to 2	130.38	-1.13	198.35	182.67	13.8	1.18	2	5.72
21:00 to 2	140.19	-6.3	208.19	66.55	13.68	1.16	-0.21	5.89
22:00 to 2	149.93	-10.94	218.46	56.01	13.48	1.22	0.96	6.07
23:00 to 2	152.45	1.25	234.5	54.38	13.51	1.2	1.86	6.07
95 Percent	169.89	11.26	263.01	186.84	13.8	1.71	5.46	6.1
Daily Avera	144.71	-2.39	219.03	97.22	13.6	1.27	2.04	5.89

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	147.62	-4.56	221.29	51.39	13.54	1.14	-2.11	6.19
01:00 to 0	145.02	-8.78	213.1	53.86	13.64	1.11	-4.18	6.21
02:00 to 0	139.26	-3.2	209.87	76.43	13.62	1.12	-2.05	6.12
03:00 to 0	128.5	-0.18	196.42	107.81	13.81	1.07	-5.63	6.1
04:00 to 0	138.2	-2.37	209.08	59.11	13.64	1.11	-4.63	6.26

05:00 to 0	141.03	-10.89	204.89	55.85	13.48	1.15	-4.52	6.39
06:00 to 0	137.91	-25.7	185.3	51.61	13.29	1.21	-5.32	6.57
07:00 to 0	135.41	-28.95	178.24	47	13.41	1.18	-4.94	6.48
08:00 to 0	134.29	-21.85	183.61	65.38	13.65	1.16	-5.45	6.33
09:00 to 0	132.96	12.49	215.93	77.89	13.74	1.13	-7.4	6.35
10:00 to 1	126.83	9.25	203.3	129.58	13.77	1.11	-4.29	6.13
11:00 to 1	142.92	8.43	227.1	70.6	13.66	1.08	-4.79	6.28
12:00 to 1	153.74	2.91	238.14	65.09	13.51	1.08	-6.39	6.46
13:00 to 1	159.05	-7.07	236.28	64.66	13.31	1.17	-2.48	6.44
14:00 to 1	160.28	-0.67	244.56	70.33	13.49	2.37	-1.84	6.28
15:00 to 1	155.97	-6.08	232.56	88.91	13.62	1.21	-3.64	6.12
16:00 to 1	146.15	-3.53	220.08	109.01	13.69	1.21	-3.25	6.08
17:00 to 1	139.44	-7.26	206.1	137.67	13.7	1.22	-2.15	6.01
18:00 to 1	154.27	-1.76	234.29	92.99	13.52	1.21	-3.23	6.26
19:00 to 1	149.16	4.32	232.53	99.07	13.64	1.22	-0.32	6
20:00 to 2	127.46	-1.17	193.84	146.07	13.63	1.09	-2.87	6.17
21:00 to 2	132.04	1.91	203.93	83.63	13.59	1.07	-2.95	6.18
22:00 to 2	143.12	-2.51	216.47	59.64	13.51	1.08	-4.03	6.39
23:00 to 2	136.54	-0.28	208.63	60.45	13.6	1.05	-4.41	6.36
95 Percent	159.05	9.25	238.14	137.67	13.77	1.22	-1.84	6.48
Daily Avera	141.97	-4.06	213.15	80.17	13.59	1.19	-3.87	6.26

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	121.43	4.83	190.61	219.61	13.75	1.05	-5.6	6.23
01:00 to 0	128.63	-0.96	195.85	132.81	13.7	1.07	-3.35	6.16
02:00 to 0	141.52	-0.1	216.43	49.43	13.55	1.07	-3.29	6.36
03:00 to 0	137.9	-3.39	207.6	49.01	13.59	1.06	-5.45	6.36
04:00 to 0	126	0.76	193.54	127.49	13.66	1.08	-1.75	6.09
05:00 to 0	117.39	7.3	186.91	268.51	13.91	1.05	-3.39	5.98
06:00 to 0	129.22	7.89	205.59	53.3	13.71	1.05	-1.75	6.05
07:00 to 0	125.54	2	194.07	54.26	13.54	1.08	2.32	6
08:00 to 0	119.19	-7.59	174.78	81.36	13.63	1.04	-3.29	6.21
09:00 to 0	118.22	1.9	182.78	237.45	13.71	1.02	-5.94	6.26
10:00 to 1	127.36	2.97	197.82	116.36	13.64	1.07	-4.4	6.32
11:00 to 1	133.84	0.42	205.19	64.88	13.64	1.07	-4.63	6.38
12:00 to 1	136.09	-12.76	195.46	106.3	13.54	1.05	-5.6	6.3
13:00 to 1	129	-12.92	184.44	182.75	13.53	1.09	-4.72	6.35
14:00 to 1	144.24	-8	212.69	156.39	13.6	2.07	-2.94	6.23
15:00 to 1	166.19	-2.45	251.82	109.17	13.25	1.3	-2.96	6.5
16:00 to 1	160.17	-5.87	239.19	84.68	13.49	1.2	-3.83	6.29
17:00 to 1	148.97	-1.18	226.74	114.84	13.67	1.21	-2.06	6.12
18:00 to 1	146.09	0.91	224.43	123.27	13.72	1.19	-2.46	5.99
19:00 to 1	161.76	3.15	250.64	86.9	13.49	1.2	-1.89	6.24
20:00 to 2	150.56	4.9	235.26	48.84	13.46	1.06	-2.78	6.39
21:00 to 2	143.4	-25.23	194.17	51.43	13.45	1.05	-3.97	6.33
22:00 to 2	128.11	-24.04	171.98	160.7	13.69	1.01	-5.78	6.16

23:00 to 2	141.05	-23.06	192.74	63.01	13.49	1.09	-4.19	6.31
95 Percent	161.76	7.3	250.64	237.45	13.75	1.3	-1.75	6.39
Daily Avera	136.74	-3.77	205.45	114.28	13.6	1.13	-3.49	6.23

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	139.8	-6.74	207.16	48.28	13.45	1.08	-5.46	6.41
01:00 to 0	142.78	-3.03	215.43	56.3	13.55	1.09	-3.53	6.31
02:00 to 0	133.97	2.15	207.13	149.51	13.69	1.06	-4.74	6.26
03:00 to 0	135.51	2.62	209.95	124.94	13.62	1.07	-3.6	6.16
04:00 to 0	141.12	9.01	224.93	54.05	13.58	1.07	-3.95	6.32
05:00 to 0	139.69	2.99	216.71	64.2	13.66	1.06	-5.24	6.28
06:00 to 0	129.53	-1.08	197.1	96.31	13.63	1.06	-4.33	6.18
07:00 to 0	126.08	-8.52	184.37	109.34	13.71	1.03	-5.31	6.12
08:00 to 0	147.91	-7.72	218.58	75.44	13.5	1.22	-2.72	6.24
09:00 to 0	153.72	-14.45	220.74	77.12	13.55	1.22	-4.74	6.17
10:00 to 1	163.29	-20.83	229	79.54	13.44	1.24	-3.89	6.27
11:00 to 1	173.66	-23.57	242.12	82.27	12.86	1.5	3.33	6.32
12:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
13:00 to 1	129.98	19.76	218.63	1518.79	3.58	16.27	-5.35	17
14:00 to 1	154.48	-0.79	235.56	33.6	10.55	6.39	-10.83	10.35
15:00 to 1	130.71	-3.35	196.64	311.74	12.88	2.64	-1.05	7.07
16:00 to 1	151.87	0.75	233.11	152.64	12.33	2.14	3.6	7.13
17:00 to 1	128.95	-14.85	182.45	363.24	12.87	1.55	5.56	6.36
18:00 to 1	124.18	7.96	197.95	236.17	12.8	1.47	2.88	7
19:00 to 1	120.8	0.84	185.66	220.64	12.85	1.49	5.19	6.51
20:00 to 2	121.41	5.45	191.21	438	13.57	1.4	6.76	5.69
21:00 to 2	160.04	-17.19	227.67	93.64	13.07	1.65	3.26	6.31
22:00 to 2	160.31	-16.39	228.88	95.52	13.19	1.68	4.95	6.12
23:00 to 2	149.29	-15.42	212.99	89.68	13.47	1.64	6.39	5.74
95 Percent	163.29	9.01	235.56	438	13.69	6.39	6.39	10.35
Daily Avera	141.7	-4.45	212.35	198.74	12.76	2.26	-0.99	6.97

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	140.95	-10.04	205.61	63.55	13.16	2.79	4.31	6.12
01:00 to 0	163.8	-7.42	243.18	91.48	13.38	1.65	5.74	5.92
02:00 to 0	164.63	-8.61	243.27	97.28	13.18	1.71	4.64	6.17
03:00 to 0	163.48	-7.54	242.58	97.2	13.06	1.71	4.19	6.29
04:00 to 0	157.75	-1.86	239.5	85.61	13.27	1.68	5.03	6.07
05:00 to 0	154.5	-2.27	234.11	75.93	13.37	1.67	5.29	5.96
06:00 to 0	156.76	-29.42	210.43	82.68	13.27	1.65	6.22	5.87
07:00 to 0	160.23	-11.82	233.33	92.06	13.15	1.65	5.57	6.15

08:00 to 0	161.13	-20.01	226.52	85.02	13.24	1.51	-2.18	6.52
09:00 to 0	141.97	4.9	222.12	79.66	13.5	1.25	-3.31	6.35
10:00 to 1	145.12	15.07	237.09	88.95	13.44	1.38	-3.19	6.48
11:00 to 1	140.35	23.03	237.76	92.06	13.77	1.29	-3.33	6.19
12:00 to 1	108.34	-7.3	158.47	98.1	13.37	1.17	-3.08	6.45
13:00 to 1	101.41	-10.75	144.41	245.21	13.46	1.17	-6.53	6.39
14:00 to 1	105.48	2.91	164.29	79.66	13.68	1.22	-5.8	6.3
15:00 to 1	149.63	3.42	232.35	107.63	13.32	1.41	-3.08	6.43
16:00 to 1	150.06	-0.39	229.2	85.31	13.49	1.32	-3.24	6.27
17:00 to 1	158.11	0.67	242.58	90.15	13.41	1.34	-2.53	6.35
18:00 to 1	162.4	4.44	252.91	105.21	13.42	1.73	-3.71	6.4
19:00 to 1	164.24	4.82	256.11	81.91	13.38	2.88	-3.14	6.42
20:00 to 2	175.21	8.11	276.18	106.86	13.39	1.41	-1.33	6.29
21:00 to 2	171.84	-4.91	258	93.88	13.36	1.29	-3.21	6.36
22:00 to 2	171.27	-10.07	251.97	91.4	13.44	1.3	-2.54	6.33
23:00 to 2	172.54	-18.91	245.08	98.96	13.42	1.39	-2.28	6.37
95 Percent	172.54	15.07	258	107.63	13.68	2.79	5.74	6.48
Daily Avera	151.72	-3.5	228.63	96.49	13.37	1.56	-0.48	6.27

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	164.65	2.1	254.02	107.21	13.45	1.4	-2.66	6.3
01:00 to 0	163.84	5.29	255.96	103.6	13.4	1.42	-1.66	6.38
02:00 to 0	159.48	6.74	250.74	98.63	13.45	1.4	-2.34	6.35
03:00 to 0	149.57	-4.75	224.09	95.68	13.38	1.38	-3.06	6.32
04:00 to 0	141.05	0.84	216.65	98.51	13.7	1.31	-4.23	6.13
05:00 to 0	129.45	-0.81	197.26	104.03	13.59	2.01	-3.37	6.2
06:00 to 0	137.91	-8.46	202.55	96.4	13.65	1.27	-3.61	6.01
07:00 to 0	138.54	-8.52	203.44	91.64	13.58	1.3	-1.97	6.09
08:00 to 0	135.63	-24.08	183.43	89.22	13.45	1.46	-1.63	6.1
09:00 to 0	140.16	9.47	223.91	87.49	13.52	1.5	-2.21	6.16
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.85
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6
12:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.81
13:00 to 1	120.24	-19.75	164.23	77.78	13.39	2.79	-1.71	6.21
14:00 to 1	126.76	-15.21	178.73	99.64	13.43	1.41	0.12	6.2
15:00 to 1	139.62	0.32	213.94	82.41	13.57	1.3	-3.27	6.1
16:00 to 1	138.98	-9	203.64	81.12	13.57	1.35	-1.15	6
17:00 to 1	139.05	-10.89	201.86	100.01	13.68	1.44	-1.74	5.93
18:00 to 1	139.9	-11.15	202.89	89.38	13.58	1.43	-2	5.94
19:00 to 1	140.7	-9.1	206.16	100.45	13.49	1.44	-0.63	6.03
20:00 to 2	143.65	-2.38	217.41	126.5	13.44	1.43	-0.85	6.14
21:00 to 2	152.89	-0.36	233.56	84.29	13.51	1.39	-2.22	6.12
22:00 to 2	161.92	3.7	251.43	99.51	13.4	1.46	-0.58	6.18
23:00 to 2	156.2	0.26	239.24	133.68	13.42	1.66	1.09	6.1
95 Percent	163.84	6.74	254.02	126.5	13.68	2.01	0.12	6.35
Daily Avera	143.82	-4.56	215.48	97.48	13.51	1.5	-1.89	6.11

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Streak	Flow Nm3/	Temperatu	Static Press
0	5.9	580.7	N/A	0	0	81.19	151.42	996.57
0	6.1	735.1	N/A	0	0	82.36	152	996.74
0	5.9	857.1	N/A	0	0	81.29	152.18	997.05
0	5.8	617.5	N/A	0	0	80.9	151.79	996.84
0	5.9	801.7	N/A	0	0	82.18	152.99	996.33
0	6.2	881	N/A	0	0	82.86	153.48	995.23
0	6	679.7	N/A	0	0	81.03	154.02	994.4
0	5.9	834.6	N/A	0	0	80.77	153.31	993.69
0	5.8	918.4	N/A	0	0	80.6	153.13	994.05
0	5.7	525.4	N/A	0	0	81.02	152.72	993.38
0	6	725.3	N/A	0	0	81.85	152.94	994.77
0	6.3	976.5	N/A	0	0	83.91	154.36	996.79
0	6.2	713.9	N/A	0	0	85.39	153.72	997.74
0	6.3	852.2	N/A	0	0	85.13	153.35	997.93
0	6.3	936.8	N/A	0	0	86.71	154.17	998.94
0	6.1	629.3	N/A	0	0	85.35	154.7	1000.13
0	6.3	775	N/A	0	0	87.51	155.25	1001.82
0	6.3	855.1	N/A	0	0	87.16	156.12	1003.35
0	6.3	605.2	N/A	0	0	85.27	155.13	1004.91
0	6.3	770.3	N/A	0	0	86.35	155.2	1006.34
0	6.2	832.5	N/A	0	0	84.21	154.98	1007.43
0	6.1	600.8	N/A	0	0	84.26	154.64	1008.53
0	6.2	748.7	N/A	0	0	85.09	154.19	1009.23
0	6.3	823.2	N/A	0	0	83.14	152.44	1009.95
0	6.3	936.8	N/A	0	0	87.16	155.25	1009.23
0	6.1	761.5	N/A	0	0	83.56	153.68	999.67

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Streak	Flow Nm3/	Temperatu	Static Press
0	6.1	574.2	N/A	0	0	84.04	153.57	1009.74
0	6.3	673.1	N/A	0	0	83.7	153.27	1009.91
0	6.2	749.6	N/A	0	0	82.9	153.66	1010.08
0	6.1	624.3	N/A	0	0	82.78	154.13	1009.84
0	6.2	772.4	N/A	0	0	82.98	153.63	1009.02
0	5.9	865.9	N/A	0	0	81.24	153.03	1008.53
0	6	646	N/A	0	0	81.37	152.66	1007.31
0	6.1	823.9	N/A	0	0	81.23	153.24	1007.15
0	6.2	864	N/A	0	0	81.66	153.33	1005.3
0	6.1	600.5	N/A	0	0	82.18	154.21	1004.5
0	6.2	740.2	N/A	0	0	80.52	153.8	1003.06
0	6	912.7	N/A	0	0	78.76	152.8	1002.89
0	5.9	729.2	N/A	0	0	77.6	150.97	1003.92
0	5.9	918.8	N/A	0	0	76.92	147.9	1003.61

0	6.1	1012.6	N/A	0	0	80.02	149.15	1004.06
0	6.1	686.2	N/A	0	0	81.13	151.26	1002.53
0	6.2	865.7	N/A	0	0	82.3	152.4	1000.27
0	6.1	1013	N/A	0	0	80.76	152.23	999.43
0	5.8	659.3	N/A	0	0	79.21	151.68	995.55
0	5.8	878	N/A	0	0	78.42	150.96	993.54
0	6.1	1013.1	N/A	0	0	78.6	151.18	991.61
0	6.3	679.8	N/A	0	0	79.04	151.42	991.05
0	6.4	855.9	N/A	0	0	78.78	150.34	991.15
0	6.2	946.2	N/A	0	0	77.42	149.75	990.9
0	6.3	1013	N/A	0	0	83.7	154.13	1009.91
0	6.1	796	N/A	0	0	80.56	152.11	1002.29

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combusio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	5.9	627.2	N/A	0	0	76.05	150.01	990.26
0	5.7	750.2	N/A	0	0	76.13	149.49	990.58
0	5.7	758.7	N/A	0	0	75.31	149.01	990.75
0	6	578.3	N/A	0	0	78.34	150.03	991.35
0	6.1	731.7	N/A	0	0	79.18	151	992.45
0	6.1	824.4	N/A	0	0	78.31	151.58	993.66
0	6	557.2	N/A	0	0	77.81	151.6	994.84
0	6.1	746.3	N/A	0	0	78.33	151.13	996.28
0	5.5	867	N/A	0	0	77.06	151.07	997.89
0	5.8	634.9	N/A	0	0	78.7	150.82	999.02
0	6	832.9	N/A	0	0	79.82	152.22	1000.38
0	5.9	940.3	N/A	0	0	79.25	152.47	1001.1
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6	353.7	N/A	0	0	80.94	151.08	1001.76
0	6.1	660.8	N/A	0	0	80.66	150.02	1001.72
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.2	315.9	N/A	0	0	81.43	151.51	1001.91
0	5.8	414.9	N/A	0	0	80.36	151.98	1002.35
0	5.6	674.8	N/A	0	0	79.15	151.34	1002.4
0	6.1	798.8	N/A	0	0	81.94	152.15	1001.76
0	5.9	598	N/A	0	0	81.07	153.21	1000.48
0	5.7	783.1	N/A	0	0	81.85	151.61	999.88
0	6	863.8	N/A	0	0	80.23	150.98	999.54
0	6.1	867	N/A	0	0	81.85	152.47	1002.35
0	5.9	681.6	N/A	0	0	79.14	151.16	997.64

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow Nm3/	Temperatu	Static Press	
0	5.9	621.8	N/A	0	0	80.63	151.95	998.43
0	5.8	777.4	N/A	0	0	79.83	152.19	997.79
0	5.6	846.9	N/A	0	0	79.06	151.83	996.63
0	5.9	592.2	N/A	0	0	80.58	152.39	994.48
0	5.9	718.3	N/A	0	0	80.33	152.67	992.79
0	5.6	825.5	N/A	0	0	80.11	153.09	992.17
0	6	677.4	N/A	0	0	80.91	153.71	991.75
0	6.1	947.2	N/A	0	0	82.19	154.4	991.99
0	5.7	1091.4	N/A	0	0	80.61	154.15	992.38
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	5.9	362.1	N/A	0	0	80.69	154	991.93
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	5.9	270.1	N/A	0	0	83.79	156.78	993.18
0	6.4	549.5	N/A	0	0	87.95	156.76	994.13
0	6.5	726.1	N/A	0	0	88.65	157.21	994.85
0	5.9	564.6	N/A	0	0	86.43	156.24	995.53
0	6	732.4	N/A	0	0	84.18	155.61	995.65
0	6.3	841.6	N/A	0	0	85.81	156.1	995.72
0	6	629.9	N/A	0	0	84.28	156.1	995.01
0	5.8	797.2	N/A	0	0	81.39	154.89	994.39
0	6.2	879.2	N/A	0	0	82.91	154.8	993.65
0	6.2	621.5	N/A	0	0	82.84	154.78	993.23
0	6.2	780.6	N/A	0	0	82.62	153.83	993.53
0	6.2	887.7	N/A	0	0	82.64	153.78	993.11
0	6.4	947.2	N/A	0	0	87.95	156.78	997.79
0	6	715.5	N/A	0	0	82.66	154.42	994.2

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow Nm3/	Temperatu	Static Press	
0	6.5	651.6	N/A	0	0	85.06	155.48	992.45
0	6.1	756.5	N/A	0	0	84.04	155.71	991.6
0	6	884	N/A	0	0	81.5	154.5	991.22
0	6.3	656	N/A	0	0	83.67	155.6	990.77
0	6.3	774.7	N/A	0	0	83.81	155.9	989.83
0	5.7	888.3	N/A	0	0	80.96	154.7	989.51
0	6.1	581.1	N/A	0	0	82.52	154.85	989.06
0	6.2	670.8	N/A	0	0	83.62	155.18	988.7
0	6	761.9	N/A	0	0	84.51	154.84	989.4
0	5.9	509.5	N/A	0	0	82.38	154.62	990.41
0	6.2	627.5	N/A	0	0	86.4	156.07	991.54
0	6.1	752.9	N/A	0	0	86.2	157.95	992.2
0	6	603	N/A	0	0	87.71	157.22	993.02
0	6.2	690.7	N/A	0	0	84.54	153.23	993.35
0	6.4	774.6	N/A	0	0	85.01	154.02	993.91
0	5.7	573.8	N/A	0	0	82.12	153.13	994.25
0	5.9	696.7	N/A	0	0	83.47	153.26	994.59

0	6.4	762.4 N/A	0	0	86.67	155.18	995.13
0	6	550.8 N/A	0	0	85.42	156.03	995.73
0	5.8	678.7 N/A	0	0	83.7	154.33	996.4
0	6.3	719.9 N/A	0	0	84.84	154.65	997.09
0	6.4	519.7 N/A	0	0	85.84	156.08	997.91
0	5.9	644.7 N/A	0	0	85.17	156.18	998.45
0	6	691.2 N/A	0	0	86.53	155.35	999.01
0	6.4	884 N/A	0	0	86.67	157.22	998.45
0	6.1	684.2 N/A	0	0	84.4	155.17	993.15

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.3	498.1 N/A	0	0	87.39	156.1	999.61	
0	6.3	606.3 N/A	0	0	86.52	157	1000.31	
0	5.8	677.9 N/A	0	0	85.71	156.47	1000.79	
0	6.3	534.1 N/A	0	0	87.81	157.26	1001.28	
0	6.4	670.3 N/A	0	0	88.88	158.05	1002.13	
0	5.9	724.3 N/A	0	0	86.83	157.81	1002.96	
0	6.1	530.8 N/A	0	0	87.44	157.18	1003.74	
0	6.1	655.9 N/A	0	0	86.01	156.98	1004.27	
0	6.2	711 N/A	0	0	87.37	157.52	1005.42	
0	6	581.7 N/A	0	0	87.43	158.38	1007.14	
0	6.2	884.6 N/A	0	0	89.51	159.1	1008.62	
0	6.3	1012.2 N/A	0	0	88.46	159.09	1009.69	
0	6.1	759.6 N/A	0	0	87.97	157.1	1010.6	
0	6.1	820.7 N/A	0	0	89.21	155.61	1010.91	
0	6.2	892.7 N/A	0	0	88.93	156.39	1011.72	
0	5.9	621.8 N/A	0	0	87.51	156.38	1012.56	
0	5.9	757.6 N/A	0	0	87.9	156.59	1013.39	
0	6.2	793.3 N/A	0	0	89.47	157.3	1014.5	
0	5.9	566.1 N/A	0	0	88.67	157.43	1015.64	
0	6	695.6 N/A	0	0	86.57	156.72	1016.68	
0	6.1	759.3 N/A	0	0	87.84	156.29	1017.9	
0	6.1	542.7 N/A	0	0	85.89	155.76	1018.86	
0	6.1	656.3 N/A	0	0	84.85	154.93	1019.74	
0	5.9	716.6 N/A	0	0	84.92	154.4	1020.43	
0	6.3	892.7 N/A	0	0	89.47	159.09	1019.74	
0	6.1	694.6 N/A	0	0	87.46	156.91	1009.54	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.2	528.6 N/A	0	0	86.7	155.47	1021.01	
0	6.1	640.8 N/A	0	0	85.75	154.9	1021.04	

0	6.1	695.4 N/A	0	0	84.33	154.76	1021.25
0	6.1	504.9 N/A	0	0	84.86	155.13	1021.77
0	6.3	628.3 N/A	0	0	87.22	155.46	1021.81
0	6	682.9 N/A	0	0	84.58	155.49	1022.34
0	6.1	496.8 N/A	0	0	85.24	154.91	1022.71
0	6.2	631.6 N/A	0	0	85.84	155.17	1023.11
0	6	696.6 N/A	0	0	83.92	155.03	1023.47
0	5.9	524.3 N/A	0	0	84.19	154.68	1024.24
0	6.1	758.7 N/A	0	0	84.56	154.46	1025.15
0	6.2	979.1 N/A	0	0	85.61	155.31	1025.33
0	6.1	688.4 N/A	0	0	86.19	155.16	1024.56
0	6	710.6 N/A	0	0	84	152.58	1023.61
0	6.2	756.8 N/A	0	0	84.11	152.63	1023.43
0	6	548.8 N/A	0	0	84.65	153.07	1023.27
0	5.8	654.4 N/A	0	0	82.89	152.64	1022.55
0	6.1	697 N/A	0	0	84.48	152.58	1022.14
0	6.1	487.9 N/A	0	0	84.43	153.3	1021.78
0	5.9	589.6 N/A	0	0	83	152.65	1021.74
0	5.8	634 N/A	0	0	81.81	151.77	1021.66
0	6.1	482.2 N/A	0	0	82.48	151.78	1021.64
0	6	605.3 N/A	0	0	82.02	151.91	1021.21
0	5.9	646.2 N/A	0	0	82.46	152.03	1020.82
0	6.2	758.7 N/A	0	0	86.7	155.47	1025.15
0	6.1	636.2 N/A	0	0	84.39	153.87	1022.57

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6	477.2 N/A	0	0	82.95	151.15	1020.38	
0	6.1	609.3 N/A	0	0	83.16	152.16	1020.15	
0	5.9	707.9 N/A	0	0	81.86	151.92	1020.1	
0	5.9	508.2 N/A	0	0	81.77	151.68	1019.64	
0	6.1	574.1 N/A	0	0	81.88	152.06	1019.14	
0	6	603.2 N/A	0	0	82.28	152.05	1019.01	
0	5.7	453.4 N/A	0	0	80.4	151.83	1019.15	
0	6	563.7 N/A	0	0	81.35	151.92	1019.12	
0	6.2	651.5 N/A	0	0	82.49	152.63	1019.11	
0	5.6	498.7 N/A	0	0	79.97	152.35	1019.12	
0	5.9	622 N/A	0	0	79.09	151.55	1019.42	
0	6.6	700.2 N/A	0	0	84.27	153.58	1019.12	
0	6.1	521.1 N/A	0	0	84.93	154.13	1017.9	
0	5.7	685.2 N/A	0	0	80.4	150.51	1016.97	
0	6.4	766.5 N/A	0	0	84.27	150.77	1016.42	
0	6.2	535.6 N/A	0	0	84.03	152.42	1015.94	
0	5.9	673.3 N/A	0	0	82.54	152.2	1015.45	
0	6	721.9 N/A	0	0	82.74	152.11	1014.53	
0	6.2	552.7 N/A	0	0	84.25	153.63	1014.45	
0	6	666.5 N/A	0	0	83.29	153.34	1014.01	

0	5.8	761.1 N/A	0	0	73.34	148.52	1013.29
0	6.2	518.9 N/A	0	0	74.99	145.46	1012.2
0	6.1	662.1 N/A	0	0	76.63	146.52	1011.77
0	6.1	763.5 N/A	0	0	76.56	147.77	1010.94
0	6.4	763.5 N/A	0	0	84.27	153.63	1020.15
0	6	616.6 N/A	0	0	81.23	151.34	1016.97

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow Nm3/	Temperatu	Static Press
0	6.2	552.1 N/A	0	0	74.6	146.84	1010.06
0	6.5	712.4 N/A	0	0	74.27	145.95	1009.43
0	6.6	810.6 N/A	0	0	75.71	146.98	1008.54
0	6	596.5 N/A	0	0	73.4	147.1	1008.05
0	6.1	680.2 N/A	0	0	74.45	146.99	1006.92
0	5.5	733.9 N/A	0	0	71.42	146.15	1006.19
0	5.7	526.9 N/A	0	0	71.74	145.96	1005.34
0	6.4	660.2 N/A	0	0	74.91	147.17	1004.54
0	6.5	759.5 N/A	0	0	74.4	148.42	1003.55
0	6.4	620.9 N/A	0	0	74.66	148.62	1003.74
0	6	725.6 N/A	0	0	73.49	147.69	1003.01
0	5.7	783.9 N/A	0	0	73.24	147.54	1002.32
0	5.7	610.9 N/A	0	0	70.69	146.51	1000.8
0	5.7	761.2 N/A	0	0	72.69	146.92	1000.34
0	6.3	829 N/A	0	0	82.82	152.92	999.52
0	6.2	639.3 N/A	0	0	83	153.77	999.23
0	6.3	812.3 N/A	0	0	85.68	154.1	998.66
0	6.1	942.8 N/A	0	0	83.58	154.73	998.62
0	5.8	698.4 N/A	0	0	82.46	155.17	998.65
0	6	877.1 N/A	0	0	83.86	155.07	998.6
0	6.2	910 N/A	0	0	75.56	151.74	998.37
0	6.3	621.2 N/A	0	0	74.88	148.58	998.59
0	6.3	798.1 N/A	0	0	74.69	148.22	999.07
0	6.2	905.9 N/A	0	0	74.41	148.17	999.73
0	6.5	910 N/A	0	0	83.86	155.07	1009.43
0	6.1	732 N/A	0	0	76.27	149.22	1002.58

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow Nm3/	Temperatu	Static Press
0	6.2	703.2 N/A	0	0	75.1	148.12	1000.26
0	5.9	888.9 N/A	0	0	74.35	148.3	1000.59
0	6	959.1 N/A	0	0	73.65	148.09	1000.76
0	6.2	687.7 N/A	0	0	73.78	148.1	1001.15
0	6.3	831 N/A	0	0	73.87	148.69	1001.45

0	6.4	891.5	N/A	0	0	74.9	149.18	1002.08
0	6.1	623.5	N/A	0	0	73.97	149.66	1002.62
0	6.2	797.4	N/A	0	0	74.46	148.68	1003.35
0	5.9	890.4	N/A	0	0	73.42	148.6	1003.58
0	5.8	711.6	N/A	0	0	73.02	147.88	1004.54
0	6	1032.7	N/A	0	0	74.1	147.93	1005.56
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.3	638.9	N/A	0	0	74.56	149.94	1005.92
0	6	866.9	N/A	0	0	74.08	149.97	1004.68
0	6.2	999.7	N/A	0	0	84.25	154.98	1004.54
0	5.8	690.4	N/A	0	0	81.61	153.88	1004.44
0	6	831.2	N/A	0	0	84.02	154.19	1004.68
0	6.2	889.9	N/A	0	0	85.43	155.72	1004.83
0	6.3	650.4	N/A	0	0	85.5	156.3	1004.9
0	6.6	799.7	N/A	0	0	86.51	157.14	1005.46
0	6.1	880.7	N/A	0	0	73.58	151.67	1005.85
0	5.9	637.7	N/A	0	0	73.98	147.78	1006.3
0	5.5	782.6	N/A	0	0	71.96	146.03	1006.58
0	5.7	832	N/A	0	0	72.2	145.98	1007.24
0	6.4	999.7	N/A	0	0	85.5	156.3	1006.58
0	6.1	805.1	N/A	0	0	76.62	150.3	1003.97

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.1	594	N/A	0	0	74.69	146.66	1008.29
0	6.3	761.2	N/A	0	0	74.57	147.69	1008.78
0	6	825.8	N/A	0	0	74.18	148.15	1010.28
0	5.8	589.5	N/A	0	0	74.23	147.35	1011.38
0	5.5	711.2	N/A	0	0	71.49	146.51	1012.03
0	5.7	756.4	N/A	0	0	72.46	145.91	1013.08
0	6.1	535.8	N/A	0	0	73.94	147	1014.5
0	6.3	623.8	N/A	0	0	75.14	148.04	1015.69
0	5.8	729.6	N/A	0	0	72.59	147.19	1017.17
0	5.5	582.7	N/A	0	0	72.56	147.37	1018.1
0	5.6	1019.4	N/A	0	0	72.82	147.36	1020.6
0	6.2	1462.9	N/A	0	0	75.1	148.2	1021.81
0	5.8	1059.2	N/A	0	0	75.06	149.64	1022.32
0	5.4	962.6	N/A	0	0	71.58	147.78	1020.98
0	5.5	937.1	N/A	0	0	81.6	151.29	1021.47
0	6.3	629.3	N/A	0	0	83.9	153.58	1021.77
0	5.8	753.2	N/A	0	0	80.36	152.91	1021.7
0	5.5	762.7	N/A	0	0	81.3	151.95	1021.9
0	6	533.1	N/A	0	0	82.04	152.21	1022.87
0	6.2	639	N/A	0	0	83.76	153.46	1023.82
0	5.8	685.1	N/A	0	0	73.91	149.72	1023.84
0	5.5	525.2	N/A	0	0	69.95	143.98	1023.64
0	5.8	646.3	N/A	0	0	70.1	142.67	1023.82

0	5.8	686 N/A	0	0	70.47	143.21	1023.98
0	6.3	1059.2 N/A	0	0	83.76	153.46	1023.84
0	5.9	750.5 N/A	0	0	75.32	148.33	1018.49

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	n Flow Nm3/	Temperatu	Static Press
0	5.4	478.7 N/A		0	0	70	143.01	1024.33
0	5.7	604.2 N/A		0	0	70.69	142.75	1024.09
0	6.1	707.5 N/A		0	0	72.05	143.77	1022.65
0	5.7	531.1 N/A		0	0	71.96	144.33	1023.88
0	5.6	638.2 N/A		0	0	69.94	143.81	1023.17
0	6.1	750.4 N/A		0	0	72.18	144.31	1023.07
0	5.7	548.1 N/A		0	0	71.75	145.52	1023.08
0	5.5	673 N/A		0	0	71.62	144.76	1023.17
0	5.7	717.6 N/A		0	0	71.15	144.2	1023.04
0	5.9	575.5 N/A		0	0	73.32	145.65	1023.46
0	5.6	803.2 N/A		0	0	71.58	145.37	1023.85
0	5.6	1008 N/A		0	0	72	145.29	1023.66
0	6.2	732 N/A		0	0	72.52	146.25	1022.49
0	5.9	869.3 N/A		0	0	71.65	146.62	1021.71
0	5.7	956.7 N/A		0	0	82.72	151.68	1021.17
0	6.1	642.6 N/A		0	0	82.32	151.94	1020.33
0	6	821.8 N/A		0	0	83.08	152.82	1020.13
0	5.7	908.7 N/A		0	0	80.99	152.66	1019.72
0	6	624.2 N/A		0	0	82.73	152.72	1019.51
0	6.3	798.4 N/A		0	0	83.08	153.79	1019.09
0	6	925.7 N/A		0	0	72.62	149.2	1018.75
0	5.4	702.4 N/A		0	0	69.75	144.06	1018.49
0	5.9	875.9 N/A		0	0	71.45	143.17	1017.93
0	5.9	937.3 N/A		0	0	70.91	144.14	1017.23
0	6.2	956.7 N/A		0	0	83.08	152.82	1024.09
0	5.8	742.9 N/A		0	0	74.25	146.74	1021.58

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	n Flow Nm3/	Temperatu	Static Press
0	5.7	658.5 N/A		0	0	71.01	144.14	1016.51
0	5.9	812.6 N/A		0	0	70.32	143.74	1015.69
0	6.2	985.4 N/A		0	0	71.58	144.34	1015.7
0	5.9	647.5 N/A		0	0	70.81	144.66	1014.81
0	5.9	804.4 N/A		0	0	70.16	144.44	1014.4
0	6	898.7 N/A		0	0	71.54	144.53	1014.09
0	5.8	615.4 N/A		0	0	70.01	145.04	1013.31
0	5.9	767.4 N/A		0	0	72.27	145.35	1013.1

0	5.8	869 N/A	0	0	70.48	144.83	1013.38
0	6	593.7 N/A	0	0	75.09	147.44	1013.19
0	6.1	807.4 N/A	0	0	74.46	149.19	1013.57
0	6.2	953.1 N/A	0	0	74.17	149.52	1013.83
0	5.8	683.3 N/A	0	0	73.69	149.22	1013.65
0	5.9	853.1 N/A	0	0	74.62	148.34	1013.19
0	5.8	863 N/A	0	0	81.21	151.68	1012.63
0	5.6	636.1 N/A	0	0	78.09	149.87	1012.93
0	6	822.9 N/A	0	0	80.32	150.69	1013.57
0	6.1	896.5 N/A	0	0	80.63	151.79	1014.05
0	6.1	615.1 N/A	0	0	81.78	152.94	1014.22
0	5.9	786.9 N/A	0	0	80.45	153.26	1014.43
0	5.9	862.9 N/A	0	0	70.76	147.2	1014.65
0	5.6	605.7 N/A	0	0	69.57	143.89	1014.72
0	5.7	768.6 N/A	0	0	70.71	143.69	1015.34
0	6	837.5 N/A	0	0	71.79	144.14	1015.52
0	6.2	953.1 N/A	0	0	81.21	152.94	1015.7
0	5.9	776.9 N/A	0	0	73.98	147.25	1014.19

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.2	583.7 N/A	0	0	72.05	144.86	1015.54	
0	6.1	731.5 N/A	0	0	71.51	145.1	1015.49	
0	5.8	780.4 N/A	0	0	70.5	144.6	1015.5	
0	5.7	547.4 N/A	0	0	70.6	144.54	1015.61	
0	5.7	691 N/A	0	0	69.83	144.02	1015.47	
0	5.9	761.2 N/A	0	0	70.88	144.57	1015.45	
0	6.1	539.3 N/A	0	0	73.38	146.21	1015.51	
0	6.1	667.3 N/A	0	0	73.24	146.61	1015.64	
0	6.1	729 N/A	0	0	72.66	146.36	1016	
0	5.8	538.6 N/A	0	0	70.61	145.68	1016.37	
0	5.8	810.6 N/A	0	0	71.51	145.27	1016.76	
0	5.7	1018.2 N/A	0	0	70.95	144.83	1017.41	
0	5.9	749 N/A	0	0	72.32	144.88	1016.9	
0	6.1	866.3 N/A	0	0	82.82	151.17	1015.75	
0	6.1	898.6 N/A	0	0	82.49	151.57	1015.33	
0	5.9	614.9 N/A	0	0	82.48	152.27	1014.11	
0	5.9	714 N/A	0	0	80.72	151.96	1013.85	
0	5.8	770.5 N/A	0	0	82.15	152.51	1013.56	
0	5.8	569.1 N/A	0	0	79.74	152.33	1013.33	
0	6.1	747.6 N/A	0	0	81.51	152.81	1013.15	
0	6.2	864.6 N/A	0	0	81.99	154.24	1012.35	
0	6.2	647.5 N/A	0	0	84.72	156.1	1011.72	
0	6.2	862.1 N/A	0	0	83.66	155.92	1010.96	
0	6.1	977.7 N/A	0	0	82.83	155.57	1009.51	
0	6.2	977.7 N/A	0	0	83.66	155.92	1016.9	
0	6	736.7 N/A	0	0	76.46	148.91	1014.64	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	5.9	657.9	N/A	0	0	70.91	150.85	1007.39
0	5.8	789.6	N/A	0	0	67.81	144.26	1005.57
0	5.9	866.7	N/A	0	0	67.38	141.08	1003.72
0	6	642.3	N/A	0	0	67.1	140.87	1001.87
0	6	822.7	N/A	0	0	67.47	141.04	1000.05
0	5.9	905.4	N/A	0	0	68.59	141.55	998.67
0	6	626.6	N/A	0	0	71.21	144.94	997.52
0	5.9	788.4	N/A	0	0	70.88	145.18	996.38
0	5.8	863.2	N/A	0	0	70.47	145.22	995.65
0	5.9	632.3	N/A	0	0	70.79	145.18	994.9
0	6.1	787.4	N/A	0	0	70.16	144.74	994.71
0	6.1	910.9	N/A	0	0	70.78	145.36	994.6
0	5.9	630.9	N/A	0	0	69.1	144.84	994.66
0	6	749	N/A	0	0	71.86	144.98	994.49
0	6	876.7	N/A	0	0	80.47	150.92	994.85
0	6	549.6	N/A	0	0	77.72	149.09	994.79
0	6.2	743.8	N/A	0	0	82.56	151.05	995.06
0	6.2	814.3	N/A	0	0	81.26	151.73	995.34
0	6.2	585	N/A	0	0	82.18	152.51	995.1
0	6	770	N/A	0	0	80.35	152.87	994.88
0	6.1	819.1	N/A	0	0	72.72	148.81	994.86
0	5.7	573	N/A	0	0	69.86	144.86	994.56
0	5.9	722.7	N/A	0	0	71.01	143.97	994.47
0	6.1	708.8	N/A	0	0	71.63	144.53	993.56
0	6.2	905.4	N/A	0	0	82.18	152.51	1005.57
0	6	743.2	N/A	0	0	72.68	146.27	996.99

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.2	556.8	N/A	0	0	71.43	145.04	993.71
0	6.2	715.7	N/A	0	0	71.22	145.24	993.59
0	6	713.9	N/A	0	0	71.18	145.24	993.99
0	6	506.7	N/A	0	0	70.8	145.18	994.25
0	5.9	656	N/A	0	0	71.31	145.03	994.61
0	6.1	664.9	N/A	0	0	71.98	145.12	994.42
0	6.1	487.9	N/A	0	0	72.13	146.25	994.6
0	6.3	636.8	N/A	0	0	73.24	146.73	995.02
0	6.3	726.8	N/A	0	0	73.61	147.18	995.76
0	6.1	528.8	N/A	0	0	73.57	147.24	996.64
0	6	621.8	N/A	0	0	73.32	147.56	996.99

0	5.9	813.4	N/A	0	0	71.89	146.99	997.18
0	6	486	N/A	0	0	71.27	145.93	996.16
0	6.1	674.8	N/A	0	0	73.45	146.26	995.35
0	6.4	648.1	N/A	0	0	80.08	151.41	994.55
0	6.3	488.4	N/A	0	0	78.75	149.31	993.66
0	6.3	590.6	N/A	0	0	79.88	149.98	993.56
0	5.9	633	N/A	0	0	80.03	151.23	993.41
0	6.1	487.1	N/A	0	0	82.68	153.16	993.8
0	6.4	575	N/A	0	0	84.85	155.68	993.81
0	6.4	555.9	N/A	0	0	74.61	150.68	993.65
0	6.4	441.5	N/A	0	0	74.94	148.33	994.63
0	6.3	562.6	N/A	0	0	74.49	147.92	994.99
0	6.3	601.3	N/A	0	0	74.16	147.36	995.4
0	6.4	726.8	N/A	0	0	82.68	153.16	996.99
0	6.2	598.9	N/A	0	0	74.79	147.92	994.74

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6	457.7	N/A	0	0	72.94	147.27	996.46
0	6.1	570.9	N/A	0	0	72.82	146.9	997.53
0	6.4	619.2	N/A	0	0	74.38	147.62	998.59
0	6.3	464.6	N/A	0	0	73.61	148.11	1000.11
0	6.4	591.3	N/A	0	0	74.77	148.38	1001.74
0	6.3	640.5	N/A	0	0	73.81	148.58	1003.09
0	6.2	477.6	N/A	0	0	73.47	148.35	1004.47
0	6	605.4	N/A	0	0	72.83	147.63	1005.12
0	6.1	699.4	N/A	0	0	72.91	147.39	1006.16
0	6.2	536.6	N/A	0	0	73.06	147.83	1007.27
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.3	312.5	N/A	0	0	73.29	147.47	1008.68
0	6	409	N/A	0	0	72.18	147.39	1009.05
0	6.1	593.8	N/A	0	0	72.91	147.37	1008.86
0	6	719.6	N/A	0	0	79.36	150.24	1008.36
0	6	539.6	N/A	0	0	79.98	149.85	1008.26
0	6.2	694.6	N/A	0	0	82.95	151.42	1007.97
0	6.3	778.3	N/A	0	0	82.42	152.91	1007.22
0	6.2	509.2	N/A	0	0	82.69	153.71	1005.59
0	6.1	643.7	N/A	0	0	80.13	153.11	1004.06
0	5.9	756.6	N/A	0	0	71.44	147.18	1001.41
0	5.7	605.9	N/A	0	0	70.06	143.87	998.14
0	6	814.3	N/A	0	0	70.94	143.54	996.61
Off	Off	Off	Off	Off	Off	Off	Off	Off
0	6.4	778.3	N/A	0	0	82.69	153.11	1008.86
0	6.1	592.7	N/A	0	0	75.13	148.46	1003.85

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
	0	18.3	559.3	N/A	0	0	39.06	127.36	996.33
	0	10.9	690.5	N/A	0	0	50.18	136.73	997.64
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
	0	12.7	573.8	N/A	0	0	43.27	123.89	1002.31
	0	7.8	751.4	N/A	0	0	55.75	128.2	1002.36
	0	6.8	812.1	N/A	0	0	56.86	129.09	1002.26
	0	6.7	577.8	N/A	0	0	57.15	128.5	1002.89
	0	7.1	687.6	N/A	0	0	58.67	129.83	1003.63
	0	6.5	712.3	N/A	0	0	80.96	140.27	1004.36
	0	6.1	529.6	N/A	0	0	86.87	154.39	1004.67
	0	5.9	665.9	N/A	0	0	84.96	154.82	1004.91
	0	6.2	706.7	N/A	0	0	75.02	149.93	1005.44
	0	6.1	500.6	N/A	0	0	72.65	144.53	1005.77
	0	6.5	608.3	N/A	0	0	73.63	144.06	1005.85
	0	6.2	672	N/A	0	0	72.75	144.01	1006.06
	0	18.3	812.1	N/A	0	0	86.87	154.82	1006.06
	0	8.1	646.3	N/A	0	0	64.84	138.26	1003.18

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press	
	0	6.2	485.9	N/A	0	0	72.47	143.51	1005.87
	0	6.1	602.7	N/A	0	0	71.63	143.22	1005.86
	0	6.1	665.1	N/A	0	0	71.14	143.07	1006.19
	0	6.3	469.9	N/A	0	0	71.6	143.13	1006.37
	0	6.4	580.1	N/A	0	0	73.3	144.07	1006.66
	0	6.2	643.1	N/A	0	0	72.19	144.09	1006.73
	0	6.1	470.6	N/A	0	0	71.68	144.01	1006.8
	0	6.2	581.6	N/A	0	0	72.34	143.43	1007.12
	0	6.3	639.6	N/A	0	0	71.54	143.3	1007.23
	0	6.4	532.4	N/A	0	0	72.12	143.47	1008.08
	0	6.3	767.8	N/A	0	0	72.72	143.72	1009.1
	0	6.2	846.6	N/A	0	0	72.03	143.66	1009.02
	0	6.1	615.4	N/A	0	0	71.9	143.9	1008.52
	0	6	762.5	N/A	0	0	71.15	143.94	1006.95

0	6.3	798.2 N/A	0	0	81.3	147.9	1008.26
0	6.3	557.1 N/A	0	0	83.22	150.12	1008.27
0	6.3	667.9 N/A	0	0	83.1	151.26	1008.15
0	6.2	712.5 N/A	0	0	82.81	151.36	1008.09
0	6	514 N/A	0	0	82.26	151.61	1008.07
0	6.2	649.8 N/A	0	0	83.1	151.9	1008.09
0	6.3	724.7 N/A	0	0	74.84	149.36	1008.18
0	6.2	549.4 N/A	0	0	71.57	143.76	1008.04
0	6.1	714.3 N/A	0	0	71.3	142.64	1007.31
0	6.1	792.9 N/A	0	0	71.43	142.26	1006.74
0	6.4	798.2 N/A	0	0	83.1	151.61	1009.02
0	6.2	639.3 N/A	0	0	74.7	145.53	1007.49

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combus	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6	484.4 N/A	0	0	70.79	142.43	1005.18	
0	6.2	607.3 N/A	0	0	72.02	142.59	1004.11	
0	6.2	677.2 N/A	0	0	72.4	143.49	1002.66	
0	6.3	508.8 N/A	0	0	73.5	144.08	1000.48	
0	6.1	661.7 N/A	0	0	72.67	144.42	999.01	
0	6.1	726.7 N/A	0	0	72.49	144.56	998.12	
0	6	543.7 N/A	0	0	71.71	144.14	997.31	
0	6.2	698.7 N/A	0	0	58.45	137.56	996.81	
0	6.5	792.8 N/A	0	0	63.38	132.72	997.17	
0	6.2	594.2 N/A	0	0	70.8	140.17	997.38	
0	6.2	771.3 N/A	0	0	73.08	143.72	998.07	
0	6.2	888.7 N/A	0	0	72.02	144.96	997.65	
0	6.1	635.3 N/A	0	0	70.82	144.9	996.58	
0	6.2	815.5 N/A	0	0	72.07	144.82	996.37	
0	6.4	909.6 N/A	0	0	84.6	150.44	997	
0	6.2	713.7 N/A	0	0	81.46	151.41	998.42	
0	6.2	868.1 N/A	0	0	83.23	151.94	999.82	
0	6	903.2 N/A	0	0	81.42	151.35	1002.26	
0	6	584.8 N/A	0	0	80.81	150.8	1003.63	
0	6.1	682.4 N/A	0	0	81.13	151.23	1005.12	
0	6.3	741.6 N/A	0	0	73.11	147.56	1007.2	
0	6.1	553.3 N/A	0	0	71.43	143.35	1008.28	
0	6.1	664.7 N/A	0	0	71.46	142.33	1009.31	
0	6	707.9 N/A	0	0	70.98	141.69	1009.93	
0	6.4	903.2 N/A	0	0	83.23	151.41	1009.31	
0	6.2	697.3 N/A	0	0	73.58	144.86	1001.16	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.1	526.6	N/A	0	0	71	141.72	1010.81
0	6.3	624.5	N/A	0	0	70.71	141.67	1011
0	6.3	684.8	N/A	0	0	70.89	141.96	1010.66
0	6.1	500.6	N/A	0	0	70.87	142.1	1010.86
0	6.1	652.9	N/A	0	0	71.05	142.22	1010.73
0	6.1	697	N/A	0	0	71.58	142.61	1010.04
0	6.2	462.1	N/A	0	0	71.84	143.45	1008.78
0	6.2	583.5	N/A	0	0	73.39	144.18	1008.05
0	6.3	647.2	N/A	0	0	72.41	144.86	1007.81
0	6.1	474.4	N/A	0	0	71.18	144.6	1007.35
0	6.1	614.6	N/A	0	0	72.53	145.49	1007.05
0	6.1	715	N/A	0	0	71.72	145.66	1006.08
0	6	562.1	N/A	0	0	73.35	146.63	1007.07
0	6.2	778.9	N/A	0	0	85.5	153.12	1007.22
0	6.3	927	N/A	0	0	85.29	154.5	1006.84
0	6	643	N/A	0	0	86.22	154.59	1005.97
0	6.1	816.6	N/A	0	0	85.98	154.32	1006.11
0	5.9	909.1	N/A	0	0	84.73	154.31	1006.47
0	6	623.8	N/A	0	0	85.18	154.58	1006.2
0	6.2	800.5	N/A	0	0	86.3	155.74	1006.61
0	6.3	900.6	N/A	0	0	75.55	151.08	1006.69
0	6.2	635.6	N/A	0	0	75.16	147.39	1006.88
0	6.1	834.5	N/A	0	0	74.96	146.97	1006.84
0	6.1	910.7	N/A	0	0	73.99	146.38	1006.97
0	6.3	910.7	N/A	0	0	86.22	154.59	1010.86
0	6.1	688.6	N/A	0	0	76.31	147.51	1007.88

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6	631.9	N/A	0	0	74.05	146.66	1006.77
0	6.1	805.7	N/A	0	0	74.4	147.29	1006.65
0	6.2	865.3	N/A	0	0	75.07	147.75	1005.99
0	6.3	612.9	N/A	0	0	72.97	147.54	1006.09
0	6.2	790.4	N/A	0	0	72.51	146.34	1006.46
0	6.1	878.1	N/A	0	0	73.42	146.98	1007.24
0	6	648.6	N/A	0	0	72.75	146.44	1008.14
0	5.9	815.8	N/A	0	0	72.5	146.05	1008.94
0	6.1	904.5	N/A	0	0	73.13	146.34	1010.27
0	6	660.3	N/A	0	0	73.88	147.27	1011.35
0	6.3	861.6	N/A	0	0	74.17	146.95	1012.38
0	6.2	986.5	N/A	0	0	73.79	146.91	1013.08
0	5.9	658.3	N/A	0	0	72.11	146.62	1013.7
0	6.1	841.4	N/A	0	0	74.91	146.84	1014.35
0	6	902.1	N/A	0	0	86.79	153.43	1014.82
0	6.2	650.8	N/A	0	0	87.11	153.97	1015.58
0	6.2	844.6	N/A	0	0	87.52	155.37	1015.81

0	6.2	912.7 N/A	0	0	91.46	158.01	1016.4
0	6.1	676.3 N/A	0	0	93.39	160	1016.82
0	6	872.3 N/A	0	0	91.39	160.11	1017.19
0	6.1	951.1 N/A	0	0	78.37	153.96	1016.86
0	5.9	661.8 N/A	0	0	75.12	147.76	1016.71
0	6.1	850.7 N/A	0	0	75.84	146.99	1016.75
0	6.2	948.9 N/A	0	0	77.47	148	1016.97
0	6.3	951.1 N/A	0	0	91.46	160	1016.97
0	6.1	801.4 N/A	0	0	78.09	149.73	1012.3

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.2	744.3 N/A	0	0	78.23	148.5	1016.93	
0	6.2	950.7 N/A	0	0	77.26	148.31	1015.79	
0	5.8	1008.2 N/A	0	0	75.64	147.42	1014.66	
0	6	649.3 N/A	0	0	75.56	147.25	1012.57	
0	6	830.6 N/A	0	0	76.75	147.12	1012.1	
0	6	940.8 N/A	0	0	76.11	147.43	1012.16	
0	6.1	746 N/A	0	0	76.83	147.76	1012.34	
0	6.1	1018.1 N/A	0	0	77.57	148.23	1012.73	
0	6.1	1081 N/A	0	0	77.2	148.04	1012.64	
0	5.9	759.4 N/A	0	0	77.27	148.09	1013.03	
0	5.8	1047.5 N/A	0	0	76.13	148.15	1013.32	
0	5.8	1168.5 N/A	0	0	76.05	147.42	1012.99	
0	6.1	844.9 N/A	0	0	76.7	147.61	1011.89	
0	6.1	1035.8 N/A	0	0	81.59	149.08	1011.51	
0	6.2	1032.8 N/A	0	0	91.82	157.46	1010.98	
0	6.1	703.5 N/A	0	0	90.56	156.75	1011.84	
0	6.2	904.6 N/A	0	0	90.07	156	1012.39	
0	5.9	992.3 N/A	0	0	87.04	155.51	1012.72	
0	6.1	719.1 N/A	0	0	88.14	155.47	1012.72	
0	6.3	928.2 N/A	0	0	90.25	156.45	1012.85	
0	6.4	1102.4 N/A	0	0	79.38	152.64	1012.64	
0	6.1	819.8 N/A	0	0	78.29	148.79	1012.37	
0	5.9	1033.2 N/A	0	0	77.58	148.24	1011.9	
0	5.8	1098.5 N/A	0	0	76.01	146.85	1010.74	
0	6.3	1102.4 N/A	0	0	90.56	156.75	1015.79	
0	6.1	923.3 N/A	0	0	80.33	150.19	1012.74	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	5.6	803.1 N/A	0	0	74.14	145.66	1009.21	
0	6	1028.9 N/A	0	0	74.72	144.97	1008.44	

0	6	1126.9	N/A	0	0	75.03	145.53	1007.11
0	6.1	879.1	N/A	0	0	75.49	145.81	1006.25
0	6	1174.7	N/A	0	0	74.92	145.87	1005.03
0	5.8	1329.9	N/A	0	0	74.87	146.11	1004.08
0	5.7	968.7	N/A	0	0	74.87	146.22	1002.72
0	5.7	996.3	N/A	0	0	74.1	145.31	1001.6
0	5.9	844.8	N/A	0	0	73.86	145.04	1001.25
0	6	569.6	N/A	0	0	75.07	145.44	1001.64
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6	318.8	N/A	0	0	73.72	145.18	1001.65
0	5.9	462	N/A	0	0	72.7	143.89	1001.83
0	5.8	756.6	N/A	0	0	77.3	144.74	1002.11
0	5.9	935.6	N/A	0	0	85.87	151.23	1002.07
0	6.1	639.7	N/A	0	0	84.9	151.47	1001.9
0	6.2	805.4	N/A	0	0	86.92	152.42	1002.09
0	6.4	860.5	N/A	0	0	87.57	153.34	1002.58
0	6.2	528.8	N/A	0	0	88.53	154.01	1002.66
0	5.9	777.7	N/A	0	0	85.45	153.43	1003.36
0	6	871.8	N/A	0	0	74.59	148.24	1003.92
0	6	637.3	N/A	0	0	73.34	143.83	1004.45
0	6.3	825.4	N/A	0	0	74.09	143.55	1004.58
0	6.3	905.3	N/A	0	0	74.09	143.67	1004.66
0	6.3	1174.7	N/A	0	0	87.57	153.43	1008.44
0	6	828.1	N/A	0	0	77.66	147.17	1003.7

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.2	659.9	N/A	0	0	74.7	143.83	1004.71
0	6.2	833.6	N/A	0	0	73.76	143.67	1004.53
0	5.9	902.3	N/A	0	0	73.63	143.38	1004.23
0	5.6	569.5	N/A	0	0	72.3	143.2	1003.44
0	5.8	738.1	N/A	0	0	72.93	143.05	1003.71
0	6.2	782.6	N/A	0	0	75.16	143.52	1003.69
0	6.2	567.2	N/A	0	0	75.04	144.39	1003.87
0	6.1	710.2	N/A	0	0	74.93	144.92	1004.27
0	5.9	695.7	N/A	0	0	73.69	144.6	1003.98
0	5.8	597.6	N/A	0	0	74.19	144.14	1004.28
0	5.7	793.5	N/A	0	0	73.16	143.93	1004.57
0	5.9	1005.5	N/A	0	0	72.97	143.91	1004.77
0	6	890.9	N/A	0	0	74.14	144.08	1004.89
0	6.1	1045.1	N/A	0	0	73.91	144.17	1004.4
0	6.1	955.6	N/A	0	0	80.6	147.25	1003.2
0	5.9	581.5	N/A	0	0	83.09	150.42	1002.8
0	6	666.4	N/A	0	0	85	150.77	1002.91
0	5.9	808.5	N/A	0	0	84.34	151.23	1003.98
0	6	615.8	N/A	0	0	84.28	151.74	1004.61
0	6.1	758.5	N/A	0	0	85.15	152.05	1004.94

0	6.3	804.5 N/A	0	0	73.85	147.04	1005.36
0	6.1	585.5 N/A	0	0	73.47	143.23	1005.9
0	5.9	715.1 N/A	0	0	72.25	142.57	1006.54
0	5.9	762 N/A	0	0	72.83	142.55	1007.16
0	6.2	1005.5 N/A	0	0	85	151.74	1006.54
0	6	751.9 N/A	0	0	76.22	145.57	1004.45

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow Nm3/	Temperatu	Static Press
0	5.9	561 N/A	0	0	72.06	142.06	1008.15
0	6	654.8 N/A	0	0	71.65	141.65	1008.33
0	6.2	741.5 N/A	0	0	72.49	142.1	1009.12
0	6.1	545.9 N/A	0	0	72.19	142.62	1009.8
0	6.1	688.1 N/A	0	0	73.09	142.81	1010.65
0	5.9	761 N/A	0	0	71.41	142.24	1012.28
0	5.8	562.6 N/A	0	0	70.84	141.86	1013.84
0	5.9	703.9 N/A	0	0	72.13	141.69	1015.38
0	6.2	781.4 N/A	0	0	71.65	141.77	1016.97
0	6.1	652.1 N/A	0	0	72.59	142.65	1018.75
0	6.2	899.3 N/A	0	0	73.41	142.94	1020.22
0	6	1062.4 N/A	0	0	72.52	142.95	1021.66
0	6	849.7 N/A	0	0	73.32	143.22	1022.14
0	5.8	962.3 N/A	0	0	71.65	143.31	1021.72
0	5.9	1028.9 N/A	0	0	81.87	147.83	1021.85
0	6.2	715 N/A	0	0	84.68	149.57	1023.07
0	6.2	839 N/A	0	0	84.55	150.69	1023.41
0	6.1	947.2 N/A	0	0	85.11	151.25	1024.64
0	6	682 N/A	0	0	84.32	151.75	1025.26
0	6	860.6 N/A	0	0	83.9	151.37	1025.39
0	5.8	937 N/A	0	0	72.21	146.14	1025.43
0	5.9	665.5 N/A	0	0	71.51	141.97	1025.38
0	6.1	822.1 N/A	0	0	72.93	141.55	1025.24
0	6.2	926.4 N/A	0	0	72.42	141.65	1025.75
0	6.2	1028.9 N/A	0	0	84.68	151.37	1025.43
0	6	785.4 N/A	0	0	75.19	144.49	1018.93

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow Nm3/	Temperatu	Static Press
0	6.1	674.4 N/A	0	0	72.8	141.91	1025.44
0	6	840 N/A	0	0	72.3	142	1024.97
0	6	974.3 N/A	0	0	73.21	141.91	1024.99
0	5.8	698.3 N/A	0	0	72.67	142.05	1023.99
0	6	845.9 N/A	0	0	71.91	142.03	1023.71

0	6.1	858.5 N/A	0	0	72.43	142.32	1023.19
0	6.3	579.8 N/A	0	0	73.53	142.84	1022.15
0	6.2	720.7 N/A	0	0	73.4	142.92	1021.76
0	6	801.9 N/A	0	0	72.99	142.99	1021.65
0	5.9	591.5 N/A	0	0	74.28	143.26	1021.37
0	5.9	789.4 N/A	0	0	73.27	143.17	1021.49
0	6	895.5 N/A	0	0	73.77	143.48	1021.6
0	6.1	643 N/A	0	0	74.07	144.19	1021.54
0	6.3	803.8 N/A	0	0	74.02	144.27	1021.4
0	6.2	900.7 N/A	0	0	86.17	149	1021.44
0	5.9	654.4 N/A	0	0	84.82	150.88	1021.87
0	5.9	832.9 N/A	0	0	84.53	151.69	1022.59
0	5.9	911.9 N/A	0	0	85.79	151.7	1023.63
0	6	654.9 N/A	0	0	86.38	153.08	1024.26
0	6	850.3 N/A	0	0	85.51	153.18	1025
0	6	936.9 N/A	0	0	74.65	148.14	1025.37
0	6	684.6 N/A	0	0	74.09	143.56	1026.03
0	6.2	866.4 N/A	0	0	74.53	143.58	1026.34
0	6.1	948.4 N/A	0	0	74.18	143.47	1027.02
0	6.3	948.4 N/A	0	0	86.17	153.08	1026.34
0	6	789.9 N/A	0	0	76.47	145.32	1023.45

O2 After Cc	O2 in Stack H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	5.9	666.7 N/A	0	0	72.43	142.75	1027.36
0	6	830 N/A	0	0	72.72	141.88	1027.4
0	6.2	902 N/A	0	0	73.56	142.19	1027.51
0	6	620.6 N/A	0	0	72.7	142.68	1027.62
0	6	791.5 N/A	0	0	72.78	142.38	1027.71
0	5.8	877.9 N/A	0	0	71.62	142.34	1028.14
0	6	655 N/A	0	0	73.37	142.8	1029.2
0	6.2	864 N/A	0	0	73.49	143.05	1030.18
0	6	908.9 N/A	0	0	73.06	143.63	1029.92
0	5.9	655.3 N/A	0	0	73.07	143.65	1030.19
0	6.1	833.6 N/A	0	0	73.42	143.67	1030.44
0	6.1	918.7 N/A	0	0	74.55	144.4	1030.8
0	6	645 N/A	0	0	74.18	144.74	1030.55
0	6.1	841.3 N/A	0	0	75.85	145.18	1030.54
0	6.1	949.7 N/A	0	0	87.74	150.61	1030.51
0	6.3	666.3 N/A	0	0	90.03	153.09	1030.43
0	6.1	834.1 N/A	0	0	87.9	154.36	1030.3
0	6	894.3 N/A	0	0	86.58	153.3	1030.19
0	5.9	667.2 N/A	0	0	86.12	153.38	1030.18
0	6.1	859.8 N/A	0	0	86.72	153.34	1030.28
0	6.2	941.3 N/A	0	0	74.31	147.93	1029.91
0	6.1	669.1 N/A	0	0	73.61	143.83	1029.33
0	5.8	841.5 N/A	0	0	72.61	143.06	1029.03

0	6.1	883.9	N/A	0	0	72.78	142.28	1028.6
0	6.2	941.3	N/A	0	0	87.9	153.38	1030.55
0	6	800.7	N/A	0	0	76.88	145.85	1029.43

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.2	612.9	N/A	0	0	74.01	142.59	1028
0	6.1	785.2	N/A	0	0	72.45	142.58	1027.67
0	6	895.9	N/A	0	0	72.81	142.29	1027.62
0	6	636.2	N/A	0	0	71.49	142.1	1026.66
0	6.1	809.2	N/A	0	0	72.61	142.37	1026.08
0	6	879.4	N/A	0	0	73.5	143.14	1025.39
0	5.9	654.5	N/A	0	0	73.83	143.51	1025.02
0	5.8	847.6	N/A	0	0	73.07	143.98	1025.14
0	6.1	947.8	N/A	0	0	80.62	146.11	1025.15
0	5.9	632.9	N/A	0	0	85.36	153.65	1024.34
0	6	797.8	N/A	0	0	86.24	154.32	1024.07
0	6.9	871.3	N/A	0	0	80.49	153.66	1024.24
Off	Off	Off	Off	Off	Off	Off	Off	Off
0	16.7	754	N/A	0	0	57.01	141.57	1025.49
0	9.4	849.8	N/A	0	0	68.25	151.32	1026.32
0	6.7	652.4	N/A	0	0	88.53	151.96	1027.16
0	7.4	801.8	N/A	0	0	94.4	159.67	1028.22
0	6.8	822.4	N/A	0	0	88.46	158.18	1028.45
0	6.9	590.2	N/A	0	0	88.07	156.56	1029.1
0	6.9	717.9	N/A	0	0	88.52	156.34	1029.63
0	6.1	770.3	N/A	0	0	76.72	153.12	1030.21
0	6.5	544.1	N/A	0	0	87.17	149.07	1030.45
0	6.4	656.4	N/A	0	0	87.05	154.5	1030.59
0	6.1	739.3	N/A	0	0	86.67	154.93	1030.86
0	9.4	895.9	N/A	0	0	88.53	158.18	1030.59
0	6.9	750.8	N/A	0	0	79.45	149.46	1027.21

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.5	520.2	N/A	0	0	88.84	154.87	1030.34
0	6.3	627.7	N/A	0	0	86.19	153.04	1030.37
0	6.5	685.3	N/A	0	0	88.6	154.6	1029.86
0	6.6	496.2	N/A	0	0	88.88	154.95	1029.04
0	6.4	614	N/A	0	0	87.24	155.13	1028.75
0	6.3	666.9	N/A	0	0	87.73	154.94	1028.28
0	6.3	498.6	N/A	0	0	85.59	154.27	1027.89
0	6.5	656.8	N/A	0	0	86.53	154.49	1028.06

0	6.4	730.6	N/A	0	0	87.19	154.69	1027.24
0	6.2	594.5	N/A	0	0	85.06	154.43	1026.93
0	6.3	753.9	N/A	0	0	86.86	155.56	1026.18
0	6	866.3	N/A	0	0	84.06	155.55	1025.99
0	6.3	780	N/A	0	0	80.34	152.46	1025.38
0	6.1	866	N/A	0	0	76.02	148.07	1023.72
0	6	948.6	N/A	0	0	81.73	150.69	1022.52
0	6.3	661.5	N/A	0	0	87.37	155.88	1020.93
0	6.1	794	N/A	0	0	84.64	156.6	1019.04
0	6.2	825.1	N/A	0	0	84.32	155.38	1017.14
0	6.2	589.8	N/A	0	0	85.91	155.66	1015.67
0	6.2	747.4	N/A	0	0	86.88	153.51	1015.48
0	6.2	833.4	N/A	0	0	87.34	153.14	1014.65
0	6.2	622.9	N/A	0	0	86.8	154.16	1013.48
0	6.2	789.4	N/A	0	0	86.39	154.31	1012.59
0	6.2	846.4	N/A	0	0	86.72	154.1	1012.16
0	6.5	866.3	N/A	0	0	88.84	155.88	1030.34
0	6.3	709	N/A	0	0	85.72	154.19	1022.99

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.1	551.5	N/A	0	0	86.41	154.53	1011.59
0	6.3	731.3	N/A	0	0	88.01	155.22	1010.78
0	6.2	792.4	N/A	0	0	88.4	155.77	1009.29
0	6.2	566.9	N/A	0	0	87.22	156.08	1007.6
0	5.9	731.7	N/A	0	0	85.88	155.51	1006.65
0	6	847.8	N/A	0	0	87.68	155.33	1006.05
0	5.8	598.4	N/A	0	0	86.44	154.09	1005.83
0	6	750.4	N/A	0	0	86.8	154.57	1005.22
0	6	669.3	N/A	0	0	87.63	155.13	1004.62
0	6.1	499.7	N/A	0	0	88.34	155.66	1004.67
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.1	210.6	N/A	0	0	87.29	153.91	1003.31
0	6.2	450.2	N/A	0	0	84.4	150.43	1003.23
0	5.9	408.2	N/A	0	0	85.2	151.14	1003
0	5.9	572.7	N/A	0	0	83.02	150.5	1002.71
0	5.8	622.4	N/A	0	0	82.53	150.7	1002.2
0	5.8	452.7	N/A	0	0	83.47	150.88	1001.5
0	6	624.6	N/A	0	0	84.45	151.64	1000.78
0	6.1	690.5	N/A	0	0	84.66	152.54	1000.04
0	6	488.7	N/A	0	0	82.61	152.22	998.95
0	6.2	633.9	N/A	0	0	83.81	151.6	998.62
0	6.2	666.6	N/A	0	0	83.36	151.91	998.11
0	6.2	792.4	N/A	0	0	88.34	155.77	1010.78
0	6	598.1	N/A	0	0	85.6	153.3	1004.04

Velocity m/s

17.72  
18  
17.77  
17.67  
18.01  
18.2  
17.84  
17.76  
17.71  
17.8  
17.97  
18.44  
18.72  
18.65  
19.01  
18.71  
19.18  
19.11  
18.62  
18.84  
18.34  
18.32  
18.47  
17.96  
19.11  
18.28

Velocity m/s

18.2  
18.11  
17.95  
17.95  
17.99  
17.59  
17.63  
17.62  
17.75  
17.92  
17.56  
17.14  
16.8  
16.54

17.25  
17.6  
17.94  
17.62  
17.32  
17.16  
17.24  
17.35  
17.25  
16.93  
18.11  
17.52

Velocity m/s

16.65  
16.65  
16.44  
17.14  
17.34  
17.15  
17.02  
17.09  
16.79  
17.12  
17.39  
17.27

N/A

17.57  
17.46

N/A

N/A

17.69  
17.47  
17.18  
17.83  
17.7  
17.82  
17.45  
17.82  
17.25

Velocity m/s

17.59  
17.44  
17.28  
17.67  
17.66  
17.64  
17.85  
18.15  
17.79

N/A

17.81

N/A

18.59  
19.49  
19.65  
19.1  
18.58  
18.96  
18.63  
17.95  
18.3  
18.29  
18.19  
18.21  
19.49  
18.22

Velocity m/s

18.83  
18.63  
18.02  
18.56  
18.62  
17.94  
18.3  
18.57  
18.73  
18.23  
19.17  
19.19  
19.48  
18.6  
18.72  
18.04  
18.34

19.12  
18.87  
18.4  
18.65  
18.92  
18.77  
19.02  
19.19  
18.65

Velocity m/s

19.23  
19.07  
18.85  
19.34  
19.6  
19.12  
19.21  
18.88  
19.18  
19.2  
19.66  
19.41  
19.19  
19.39  
19.35  
19.02  
19.1  
19.45  
19.26  
18.76  
18.99  
18.53  
18.25  
18.23  
19.6  
19.09

Velocity m/s

18.65  
18.42

18.11  
18.23  
18.75  
18.17  
18.28  
18.42  
17.99  
18.02  
18.08  
18.33  
18.46  
17.9  
17.93  
18.07  
17.69  
18.03  
18.06  
17.73  
17.44  
17.58  
17.5  
17.6  
18.65  
18.06

Velocity m/s

17.68  
17.77  
17.48  
17.46  
17.51  
17.59  
17.18  
17.39  
17.66  
17.11  
16.89  
18.08  
18.27  
17.16  
18.01  
18.04  
17.72  
17.77  
18.17  
17.95

15.64  
15.89  
16.29  
16.34  
18.17  
17.38

Velocity m/s

15.89  
15.8  
16.16  
15.68  
15.92  
15.25  
15.33  
16.06  
16.02  
16.08  
15.8  
15.75  
15.19  
15.64  
18.1  
18.17  
18.78  
18.35  
18.12  
18.43  
16.48  
16.21  
16.14  
16.07  
18.43  
16.48

Velocity m/s

16.21  
16.05  
15.89  
15.91  
15.95

16.18  
15.99  
16.04  
15.81  
15.68  
15.9

N/A

16.07  
15.99  
18.4  
17.78  
18.31  
18.69  
18.72  
18.97  
15.93  
15.86  
15.36  
15.4  
18.72  
16.57

Velocity m/s

15.94  
15.94  
15.85  
15.81  
15.19  
15.36  
15.69  
15.97  
15.37  
15.36  
15.38  
15.87  
15.91  
15.12  
17.38  
17.95  
17.17  
17.33  
17.49  
17.89  
15.65  
14.61  
14.59

14.68  
17.89  
15.98

Velocity m/s

14.58  
14.71  
15.04  
15.04  
14.61  
15.09  
15.05  
14.99  
14.87  
15.37  
15  
15.08  
15.24  
15.09  
17.64  
17.58  
17.78  
17.33  
17.71  
17.84  
15.43  
14.64  
14.98  
14.91  
17.78  
15.65

Velocity m/s

14.94  
14.79  
15.08  
14.94  
14.8  
15.1  
14.81  
15.3

14.9  
15.97  
15.9  
15.85  
15.73  
15.91  
17.46  
16.71  
17.21  
17.32  
17.61  
17.33  
15.02  
14.65  
14.88  
15.12  
17.46  
15.72

Velocity m/s

15.2  
15.09  
14.86  
14.88  
14.7  
14.94  
15.53  
15.51  
15.37  
14.91  
15.08  
14.94  
15.24  
17.73  
17.68  
17.73  
17.35  
17.68  
17.16  
17.56  
17.74  
18.42  
18.2  
18.03  
18.2  
16.31

Velocity m/s

15.3  
14.43  
14.25  
14.21  
14.32  
14.6  
15.3  
15.25  
15.17  
15.25  
15.11  
15.26  
14.88  
15.49  
17.58  
16.91  
18.04  
17.78  
18.01  
17.63  
15.81  
15.05  
15.26  
15.43  
18.01  
15.68

Velocity m/s

15.41  
15.37  
15.35  
15.27  
15.37  
15.52  
15.59  
15.84  
15.92  
15.9  
15.85

15.52  
15.37  
15.86  
17.52  
17.16  
17.43  
17.52  
18.18  
18.76  
16.31  
16.27  
16.15  
16.06  
18.18  
16.23

Velocity m/s

15.77  
15.71  
16.06  
15.89  
16.12  
15.9  
15.8  
15.63  
15.62  
15.65

N/A

15.66  
15.42  
15.57  
17.08  
17.2  
17.9  
17.87  
17.99  
17.43  
15.37  
15  
15.2

Off

17.9  
16.17

Velocity m/s

Off

Off

Off

8.05

10.57

Off

Off

Off

Off

Off

Off

Off

8.79

11.44

11.69

11.73

12.07

17.1

18.95

18.54

16.18

15.46

15.65

15.46

18.95

13.69

Velocity m/s

15.38

15.2

15.08

15.18

15.57

15.33

15.22

15.33

15.16

15.27

15.4

15.25

15.24

15.09

17.41  
17.91  
17.93  
17.87  
17.76  
17.96  
16.08  
15.17  
15.08  
15.1  
17.93  
15.91

Velocity m/s

15  
15.28  
15.42  
15.71  
15.57  
15.55  
15.38  
12.35  
13.23  
15.04  
15.64  
15.47  
15.22  
15.49  
18.42  
17.75  
18.13  
17.67  
17.49  
17.56  
15.65  
15.12  
15.07  
14.94  
18.13  
15.76

Velocity m/s

14.93  
14.87  
14.92  
14.92  
14.96  
15.1  
15.2  
15.57  
15.39  
15.12  
15.45  
15.29  
15.67  
18.55  
18.57  
18.79  
18.72  
18.44  
18.56  
18.84  
16.32  
16.09  
16.03  
15.8  
18.79  
16.34

Velocity m/s

15.82  
15.93  
16.1  
15.64  
15.49  
15.69  
15.52  
15.44  
15.56  
15.74  
15.77  
15.68  
15.3  
15.9  
18.69  
18.77  
18.92

19.88  
20.39  
19.95  
16.87  
15.94  
16.06  
16.44  
19.95  
16.73

Velocity m/s

16.62  
16.43  
16.07  
16.08  
16.33  
16.21  
16.37  
16.54  
16.46  
16.46  
16.22  
16.18  
16.35  
17.46  
20.04  
19.72  
19.57  
18.88  
19.12  
19.62  
17.11  
16.72  
16.56  
16.19  
19.72  
17.22

Velocity m/s

15.77  
15.88

15.99  
16.11  
16.01  
16.02  
16.05  
15.86  
15.81  
16.08

N/A

15.78  
15.51  
16.52  
18.64  
18.44  
18.92  
19.09  
19.33  
18.62  
16.05  
15.6  
15.75  
15.75  
19.09  
16.68

Velocity m/s

15.89  
15.68  
15.65  
15.37  
15.5  
15.99  
15.99  
15.98  
15.71  
15.8  
15.57  
15.52  
15.78  
15.74  
17.31  
17.99  
18.41  
18.27  
18.27  
18.46

15.82  
15.59  
15.29  
15.4  
18.41  
16.29

Velocity m/s

15.21  
15.1  
15.29  
15.23  
15.41  
15.02  
14.86  
15.1  
14.98  
15.18  
15.34  
15.14  
15.31  
14.97  
17.29  
17.93  
17.94  
18.07  
17.91  
17.8  
15.13  
14.84  
15.12  
15.01  
17.94  
15.8

Velocity m/s

15.1  
15.01  
15.19  
15.1  
14.95

15.07  
15.34  
15.32  
15.24  
15.52  
15.3  
15.42  
15.51  
15.5  
18.26  
18.04  
18  
18.25  
18.42  
18.23  
15.72  
15.42  
15.51  
15.42  
18.26  
16.03

Velocity m/s

15.03  
15.05  
15.24  
15.08  
15.08  
14.83  
15.2  
15.22  
15.15  
15.15  
15.22  
15.48  
15.41  
15.78  
18.49  
19.09  
18.69  
18.37  
18.27  
18.4  
15.57  
15.28  
15.05

15.06  
18.69  
16.05

Velocity m/s

15.34  
15.02  
15.09  
14.82  
15.07  
15.29  
15.38  
15.24  
16.9  
18.23  
18.45  
17.19

Off

11.83  
14.46  
18.78  
20.37  
19.01  
18.85  
18.92  
16.28  
18.31  
18.51  
18.44  
19.01  
16.77

Velocity m/s

18.91  
18.27  
18.86  
18.95  
18.61  
18.72  
18.24  
18.45

18.61  
18.15  
18.6  
18  
17.09  
16.03  
17.36  
18.82  
18.29  
18.21  
18.59  
18.71  
18.8  
18.75  
18.69  
18.76  
18.91  
18.35

Velocity m/s

18.72  
19.11  
19.25  
19.04  
18.74  
19.14  
18.82  
18.93  
19.14  
19.32

N/A

N/A

N/A

19.04  
18.26  
18.47  
17.98  
17.89  
18.11  
18.37  
18.47  
18.03  
18.27  
18.19  
19.25  
18.63

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	157.73	-7.95	233.38	78.67	13.32	1.98	-0.76	6.18
01:00 to 0	159.65	-8.64	235.63	92.21	13.32	1.49	1.66	6.06
02:00 to 0	155.42	-12.18	225.61	95.6	13.22	1.55	2.9	6.1
03:00 to 0	146.19	1.48	225.14	103.67	13.26	1.53	1.26	6.11
04:00 to 0	142.99	2.54	221.31	103.02	13.52	1.51	2.09	5.9
05:00 to 0	147.17	2.11	227.28	111.71	13.42	1.51	0.99	6.11
06:00 to 0	142.12	2.93	220.37	116.86	13.42	1.57	1.9	5.93
07:00 to 0	157.45	-3.36	237.54	105.74	13.41	1.6	3.48	5.99
08:00 to 0	158.4	9.49	251.84	105.06	13.45	1.6	3.75	6.01
09:00 to 0	163.25	-2.1	247.68	95.54	13.34	1.44	0.82	6.06
10:00 to 1	156.17	-1.3	237.64	82.97	13.57	1.18	1.41	5.98
11:00 to 1	156.51	-5.53	233.93	82.41	13.68	1.24	2.41	5.81
12:00 to 1	152.09	1.68	234.38	88.43	13.69	1.29	-1.25	5.91
13:00 to 1	148.92	-5.35	222.5	79.35	13.47	3.09	-0.66	6.06
14:00 to 1	168.04	-9.43	247.67	94.57	13.43	1.45	1.85	6.03
15:00 to 1	159.7	-15.07	229.27	75.64	13.39	1.39	0.25	6.01
16:00 to 1	158.52	-10.96	231.57	70.37	13.47	1.34	0.53	6.03
17:00 to 1	153.44	-18.27	216.5	68.91	13.41	1.4	0.99	6.08
18:00 to 1	146.77	1.19	225.75	81.72	13.53	1.4	0.55	5.94
19:00 to 1	147.57	2.2	227.98	90.14	13.57	1.43	0.74	5.98
20:00 to 2	150.76	2.21	232.87	87.48	13.64	1.4	2.28	5.87
21:00 to 2	158.75	-8.31	234.57	76.46	13.43	1.38	0.54	6.01
22:00 to 2	162.23	-9.52	238.69	66.37	13.43	1.37	0.93	6.02
23:00 to 2	157.28	-8.01	232.63	62.39	13.27	2.03	2.12	6.14
95 Percent	163.25	2.93	247.68	111.71	13.68	2.03	3.48	6.14
Daily Avera	154.46	-4.17	232.16	88.14	13.44	1.55	1.28	6.01

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	157.26	-6.34	234.27	65.38	13.46	1.35	1.03	5.98
01:00 to 0	160.75	-3.92	242.04	78.48	13.41	1.41	2.87	5.95
02:00 to 0	152.34	-8	225.09	83.33	13.58	1.37	3.29	5.76
03:00 to 0	148.09	14.06	240.63	89.94	13.67	1.34	3.4	5.71
04:00 to 0	155.81	2.98	241.36	82.46	13.43	1.4	4.19	5.87
05:00 to 0	153.96	1.02	236.59	76.35	13.48	1.37	1.93	5.92
06:00 to 0	150.29	-5.5	224.45	71.88	13.43	1.37	1.67	5.94
07:00 to 0	152.03	0.93	233.54	77.32	13.37	1.44	2.96	5.99
08:00 to 0	150.69	0.95	231.49	78.45	13.38	1.43	2.88	6.01
09:00 to 0	160.32	5.97	251.26	80.4	13.65	1.51	-1.33	5.99
10:00 to 1	154.12	1.88	237.68	78.47	13.63	1.4	0.88	5.95
11:00 to 1	158.09	-6.44	235.44	77.19	13.51	1.26	3.43	5.9
12:00 to 1	153.69	8.9	244.05	73.8	13.35	2.73	4.52	6.04
13:00 to 1	158.75	-9.39	233.49	103.59	13.25	1.33	3.4	6.13

14:00 to 1	156.47	-4.56	234.84	89.02	13.43	1.24	0.52	6.11
15:00 to 1	151.53	-12.49	219.36	93.12	13.42	1.23	-2.07	6.2
16:00 to 1	151.02	-13.28	217.77	88.22	13.57	1.26	-0.83	6.02
17:00 to 1	151.6	-10.16	221.79	100.4	13.48	1.38	2.18	5.97
18:00 to 1	150.43	4.52	234.67	92.38	13.5	1.41	1.19	6
19:00 to 1	147.39	2.96	228.47	94.71	13.45	1.42	3.68	5.9
20:00 to 2	146.83	1.44	226.08	85.22	13.42	1.41	5.19	5.81
21:00 to 2	141.84	-1.49	215.52	91.49	13.64	1.37	4.99	5.58
22:00 to 2	146.39	-2.65	221.32	85.95	13.41	2.58	6.37	5.75
23:00 to 2	151.91	14.06	246.48	96.45	13.69	1.35	5.87	5.59
95 Percent	160.32	14.06	246.48	100.4	13.67	2.58	5.87	6.13
Daily Avera	152.57	-1.02	232.4	84.75	13.48	1.47	2.59	5.92

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	165.36	-5.8	247.21	97.88	13.45	1.32	1.14	5.98
01:00 to 0	162.85	-5.06	244.09	79.01	13.52	1.31	2.75	5.82
02:00 to 0	162.26	-8.56	239.7	82.67	13.5	1.28	0.09	5.99
03:00 to 0	166.83	-15.54	239.71	75.41	13.35	1.34	-3.36	6.26
04:00 to 0	156.29	-12.85	226.28	86.2	13.53	1.31	-2.66	6.06
05:00 to 0	155.68	-5.81	232.38	92.92	13.54	1.34	-0.66	5.99
06:00 to 0	150.2	3.14	232.94	98.05	13.62	1.29	-1.65	5.98
07:00 to 0	164.29	-0.75	250.62	96.42	13.47	1.33	-2.17	6.21
08:00 to 0	161.61	-0.85	246.42	83.25	13.46	1.36	-0.98	6.17
09:00 to 0	158.46	7.94	250.38	79.53	13.4	1.4	-0.56	6.18
10:00 to 1	155.85	7.82	246.27	75.72	13.49	1.4	1.09	6.04
11:00 to 1	160.93	3.56	249.78	71.13	13.57	1.43	1.37	5.95
12:00 to 1	155.15	14.38	251.76	65.48	13.38	2.84	-0.19	6.2
13:00 to 1	163.72	15.97	266.46	76.15	13.72	1.34	-1.26	5.98
14:00 to 1	167.6	11.61	268.03	72.22	13.7	1.35	-0.98	5.99
15:00 to 1	167.85	-0.06	256.75	76.55	13.61	1.36	-1.41	5.98
16:00 to 1	161.71	-11.9	235.51	58.74	13.72	1.38	-2.14	5.91
17:00 to 1	159.42	-6.43	237.48	67.23	13.78	1.42	0.4	5.79
18:00 to 1	148.09	3.88	230.46	71.32	13.9	1.4	-2.34	5.71
19:00 to 1	156.69	-1.07	238.66	75.96	13.69	1.49	0.95	5.84
20:00 to 2	155.87	2.95	241.43	69.57	13.7	1.44	1.39	5.87
21:00 to 2	151.11	4.21	235.41	74.71	13.52	1.45	0.57	5.99
22:00 to 2	145.37	-2.86	219.56	57.86	13.56	1.91	1.13	5.92
23:00 to 2	159.05	-4.85	238.5	78.69	13.61	1.41	0.46	5.98
95 Percent	167.6	14.38	266.46	97.88	13.78	1.91	1.39	6.21
Daily Avera	158.84	-0.29	242.74	77.61	13.57	1.45	-0.38	5.99

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	150.44	-0.29	229.89	63.7	13.83	1.29	-4.33	5.93
01:00 to 0	154.95	-4.43	232.65	68.93	13.68	1.37	-3.26	6.09
02:00 to 0	157.02	-17.52	222.73	64.48	13.67	1.41	-1.52	6
03:00 to 0	149.49	-3.79	224.93	59.05	13.59	1.37	-1.9	6.05
04:00 to 0	146.38	-5.19	218.77	57.96	13.78	1.38	-0.97	5.83
05:00 to 0	138.62	-4.36	207.73	69.99	13.95	1.4	-1.26	5.71
06:00 to 0	145.92	-8.07	215.19	63.38	13.9	1.36	-1.29	5.7
07:00 to 0	151.78	-7.74	224.49	62.7	13.66	1.42	0.07	5.91
08:00 to 0	151.38	-11.23	220.38	61.92	13.66	1.42	1.94	5.84
09:00 to 0	144.55	-0.6	220.56	58.53	13.65	1.28	-3.71	6.08
10:00 to 1	139.24	4.85	217.88	63.84	13.76	1.09	-3.79	6.05
11:00 to 1	128.12	2.76	198.78	66.39	13.98	1.1	-5.38	5.91
12:00 to 1	137.66	1.27	211.9	76.02	13.73	1.2	-4.01	6.08
13:00 to 1	136.94	-0.9	208.62	58.08	13.59	2.35	-4.71	6.29
14:00 to 1	140.19	-1.41	213.08	78.34	13.65	1.23	-3.36	6.24
15:00 to 1	135.39	-0.07	207.08	61.22	13.75	1.19	-5.01	6.15
16:00 to 1	140.57	0.2	215.27	60.95	13.74	1.26	-2.9	6.05
17:00 to 1	141.28	-2.26	213.89	56.5	13.91	1.31	-1.29	5.77
18:00 to 1	145.67	-16.42	206.45	58.77	13.56	1.39	-1.44	5.98
19:00 to 1	150.55	-20.98	209.36	55.4	13.52	1.43	-0.62	6.02
20:00 to 2	147.37	-23.43	202.04	57.38	13.46	1.47	0.41	6.04
21:00 to 2	144.07	10.05	230.48	57.99	13.82	1.45	-1.33	5.93
22:00 to 2	148.41	5.09	232.16	63.18	13.51	1.64	1.68	6.08
23:00 to 2	147.39	1.35	226.85	54.96	13.7	1.77	0.15	5.98
95 Percent	154.95	5.09	232.16	76.02	13.95	1.77	1.68	6.24
Daily Avera	144.72	-4.3	217.13	62.49	13.71	1.4	-1.99	5.99

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	159.63	7.7	251.93	68.81	13.5	1.48	-1.97	6.28
01:00 to 0	157.89	5.36	246.92	63.52	13.65	1.47	-1.62	6.16
02:00 to 0	154.71	6.57	243.29	59.9	13.64	1.43	-2.4	6.24
03:00 to 0	146.49	-6.84	217.29	63.75	13.64	1.4	-2.59	6.05
04:00 to 0	143.12	-13.23	205.73	62.46	13.73	1.38	-4.43	6.07
05:00 to 0	150.08	-16.78	212.84	64.33	13.62	1.43	-3.26	6.17
06:00 to 0	148.46	-16.81	210.33	61.24	13.54	1.41	-4.93	6.3
07:00 to 0	141.68	-21.7	195.07	58.02	13.52	1.44	-2.61	6.24
08:00 to 0	150.63	-13.98	216.49	56.57	13.58	1.46	-1.27	6.17
09:00 to 0	159.99	-4.16	240.62	57.91	13.74	1.38	-2.92	5.94
10:00 to 1	159.68	1.69	246	61.67	13.99	1.35	-1.4	5.68
11:00 to 1	165.89	9.09	262.89	55.14	13.83	1.14	-3.71	6.02
12:00 to 1	157.5	16.59	257.56	62.29	13.88	1.28	-4.36	6.03
13:00 to 1	159.41	7.38	251.28	57.74	13.76	1.28	-4.73	6.15
14:00 to 1	155.67	22.33	260.51	56.09	13.8	1.79	-4.12	6.18
15:00 to 1	153.37	-4.4	230.26	61.12	13.77	1.25	-6.07	6.06
16:00 to 1	158.49	-7.04	235.45	61.14	13.7	1.34	-2.77	5.94



02:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	146.65	19.43	243.8	14.29	9.43	0.87	-22.54	12.82
10:00 to 1	163.91	17.6	268.39	18.8	11.81	0.74	-7.3	8.54
11:00 to 1	172.89	11.04	275.57	13.24	11.87	0.98	-4.24	8.29
12:00 to 1	151.25	-0.23	231.18	6.15	12.23	1.01	-2.51	7.79
13:00 to 1	140.97	-7.73	207.95	6.6	12.58	1.04	-4.76	7.5
14:00 to 1	171.71	-10.83	251.88	29.34	12.63	1.23	-4.85	7.34
15:00 to 1	173.88	-3.46	262.58	81.81	13.5	1.56	-2.84	6.27
16:00 to 1	172.34	-0.28	263.4	88.14	13.67	1.49	-0.04	5.95
17:00 to 1	165.06	3.55	256.1	62.84	13.79	1.47	0.04	5.84
18:00 to 1	165.69	-1.46	252.06	62.32	13.76	1.49	0.62	5.8
19:00 to 1	162.42	6.3	254.8	61.34	13.64	1.49	3.03	5.84
20:00 to 2	156.73	1.08	240.87	58.02	13.83	1.41	1.55	5.7
21:00 to 2	151.75	-3.57	228.61	57.25	14	1.4	-3.57	5.73
22:00 to 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.56
23:00 to 2	158.53	-14.72	227.83	52.93	13.74	1.52	0.62	5.71
95 Percent	173.88	19.43	275.57	88.14	14	1.56	3.03	12.82
Daily Average	160.98	1.19	247.5	43.79	12.89	1.26	-3.34	6.98

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	156.25	-2.35	236.72	54.53	13.49	2.05	1.56	5.95
01:00 to 0	155.34	5.2	242.87	49.39	13.68	1.35	-0.32	5.95
02:00 to 0	144.45	0.35	221.36	49.49	13.82	1.33	-1.02	5.82
03:00 to 0	142.3	6.13	223.86	57.31	14.12	1.26	-2.25	5.61
04:00 to 0	147.25	10.45	235.75	59.83	13.75	1.27	-1.42	5.99
05:00 to 0	151.14	5	236.24	66.27	13.5	1.29	-0.6	6.21
06:00 to 0	139.74	-4.13	209.67	53.07	13.85	1.17	-4.33	5.98
07:00 to 0	136.42	5.56	214.28	56.3	14.06	1.15	-4.61	5.79
08:00 to 0	142.68	-4	214.3	60.24	13.75	1.18	-2.44	5.98
09:00 to 0	149.42	5.81	234.42	63.42	13.59	1.15	-2	6.1
10:00 to 1	141.92	-1.65	215.49	56.98	13.75	1.07	-2.58	5.99
11:00 to 1	140.95	-9.06	206.6	56.35	13.71	1.06	-2.42	6.01
12:00 to 1	142.52	-8.79	209.27	60.03	13.57	2.47	-1.19	6
13:00 to 1	159.25	-9.07	234.58	64.28	13.5	1.07	-1.19	6.1
14:00 to 1	154.07	-1.21	234.53	57.69	13.62	1.05	-1.36	5.99
15:00 to 1	147.7	-12.76	213.22	63.08	13.7	1.04	-1.65	5.85
16:00 to 1	151.74	3.14	235.3	65.53	13.89	1.03	-2.67	5.81
17:00 to 1	163.46	-11.21	238.88	64.26	13.6	1.13	-3.72	6.12
18:00 to 1	157.58	1.98	243.08	60.74	13.61	1.12	-4.29	6.17
19:00 to 1	152.9	3.7	237.63	69.71	13.74	1.12	-5.15	6.08

20:00 to 2	150.02	5.39	234.92	74.51	13.91	1.15	-5.52	5.95
21:00 to 2	155.06	-13.35	223.9	63.32	13.48	1.32	-4.28	6.2
22:00 to 2	152.43	-10.02	223.19	61.47	13.47	1.43	-1.65	6.15
23:00 to 2	157.57	-19.43	221.66	65.43	13.47	1.2	-3.22	6.22
95 Percent	159.25	6.13	242.87	69.71	14.06	2.05	-0.32	6.21
Daily Avera	149.67	-2.26	226.74	60.55	13.69	1.27	-2.43	6

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	143.41	16.18	235.6	81.66	13.94	1.19	-5.17	5.99
01:00 to 0	150.06	14.5	244.09	79.19	13.84	1.24	-2.36	5.91
02:00 to 0	156.05	4.91	243.66	68.46	13.75	1.28	-4.4	6.12
03:00 to 0	154.72	-8.92	227.8	57.34	13.56	1.34	-6.11	6.19
04:00 to 0	154.62	-14.52	222.04	69.53	13.59	1.42	-3.15	6.05
05:00 to 0	156.32	-20.11	219.05	64.96	13.76	1.46	-3.23	5.92
06:00 to 0	160.37	-11.99	233.38	61.11	13.5	1.46	-4.69	6.21
07:00 to 0	156.87	-18.41	221.61	58.2	13.51	1.53	-3.08	6.2
08:00 to 0	152.65	-16.34	217.21	57.8	13.58	1.51	-3.12	6.16
09:00 to 0	157.38	2.78	243.58	64.19	13.72	1.24	-4.31	6.02
10:00 to 1	151.21	13.45	244.81	70.16	13.83	1.24	-3.03	5.97
11:00 to 1	152.49	18.81	252.13	60.44	13.78	1.25	-2.6	6.08
12:00 to 1	150.02	-1.07	228.46	57.27	13.51	1.92	-2.75	6.15
13:00 to 1	147.68	-12	213.94	77.31	13.83	2.08	-5.49	6.01
14:00 to 1	167.48	-15.67	240.58	68.09	13.61	1.35	-1.69	6.05
15:00 to 1	162.13	9.64	257.71	77.56	13.52	1.35	-1.65	6.15
16:00 to 1	157.04	-0.41	239.86	76.83	13.74	1.3	-5.35	6.11
17:00 to 1	156.19	-1.41	237.55	83.31	13.6	1.43	-1.18	6.06
18:00 to 1	151.19	-1.56	229.77	84.34	13.85	1.43	-1.09	5.71
19:00 to 1	154.62	5.8	242.37	73.12	13.72	1.47	1.83	5.76
20:00 to 2	153.12	3.29	237.56	72.29	13.6	1.49	3.31	5.78
21:00 to 2	144.55	-1.93	219.24	71.84	13.79	1.42	0.19	5.71
22:00 to 2	139.95	-0.44	213.68	82.39	13.88	1.8	0.23	5.67
23:00 to 2	146.72	5.85	230.32	64.3	13.7	1.67	3.37	5.73
95 Percent	162.13	16.18	252.13	83.31	13.88	1.92	3.31	6.2
Daily Avera	153.2	-1.23	233.17	70.07	13.7	1.45	-2.31	5.99

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	144.71	-0.53	220.87	59.85	13.73	1.42	0.85	5.78
01:00 to 0	144.14	-1.95	218.58	67.62	13.84	1.4	0.86	5.62
02:00 to 0	139.95	3.4	217.52	92.12	14.05	1.32	-1.31	5.57
03:00 to 0	146.54	-10.31	213.89	70.87	13.8	1.3	-1.94	5.75
04:00 to 0	144.72	-7.49	213.92	61.71	13.86	1.22	-2.86	5.78

05:00 to 0	143.62	-11.75	207.99	60.78	13.82	1.23	-3.98	5.86
06:00 to 0	139.49	-8.7	204.71	88.96	13.86	1.28	-5.78	5.93
07:00 to 0	148.82	-6.35	221.34	75.67	13.79	1.29	-3.09	5.93
08:00 to 0	152.53	-9.87	223.5	58.78	13.76	1.26	-5.07	6.07
09:00 to 0	148.52	0.16	227.4	58.21	13.76	1.2	-5.75	6.06
10:00 to 1	148.78	-0.63	227	70.92	13.85	1.17	-4.17	5.87
11:00 to 1	150.32	4.1	234.09	75.31	13.74	1.34	-2.06	5.94
12:00 to 1	153.42	-5.94	228.8	59.5	13.66	2	-5.64	6.17
13:00 to 1	166.34	-6.14	248.36	69.1	13.42	1.17	-3.81	6.32
14:00 to 1	154.12	-5.5	230.3	67.72	13.78	1.1	-5.49	6.04
15:00 to 1	158.4	-18.97	223.38	73.87	13.74	1.15	-5.46	6.03
16:00 to 1	166.45	-14.82	239.85	68.39	13.62	1.2	-3.73	6.1
17:00 to 1	161.69	-20.82	226.56	65.02	13.64	1.19	-4.43	6.1
18:00 to 1	150.98	5.58	236.58	72.55	13.74	1.18	-3.37	5.96
19:00 to 1	146.46	12.66	236.75	98.24	13.84	1.17	-2.56	5.82
20:00 to 2	149.95	6.53	235.95	91.69	13.79	1.17	-2.9	5.89
21:00 to 2	152.8	-2.57	231.21	68.91	13.57	1.28	-5.58	6.2
22:00 to 2	156.75	-8.45	231.38	52.96	13.52	1.6	-4.11	6.3
23:00 to 2	151.32	-3.81	227.71	70.8	13.71	1.25	-3.32	6.16
95 Percent	166.34	6.53	239.85	92.12	13.86	1.6	0.85	6.3
Daily Avera	150.87	-4.67	226.15	70.81	13.74	1.29	-3.53	5.97

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	147.93	0.61	226.93	70.16	13.72	1.25	-4.68	6.03
01:00 to 0	149.26	-3.96	224.4	72.49	13.48	1.33	-2.82	6.23
02:00 to 0	150.7	-11.42	219.14	65.87	13.48	1.35	-3.35	6.25
03:00 to 0	144.45	8.53	229.54	64.36	13.65	1.34	-4.8	6.16
04:00 to 0	139.67	3.7	217.39	84.98	13.84	1.37	-4.15	5.97
05:00 to 0	151.85	-0.48	231.85	76.1	13.57	1.44	-2.08	6.13
06:00 to 0	148.83	3.39	231.11	68.48	13.56	1.4	-3.33	6.11
07:00 to 0	143.88	-2.88	217.25	63.68	13.6	1.42	-3.29	6.1
08:00 to 0	155.79	-10.61	227.76	67.24	13.53	1.46	-2.54	6.15
09:00 to 0	160.96	4.04	250.3	71.3	13.56	1.26	-2.94	6.12
10:00 to 1	159.41	10.12	254.02	65.82	13.62	1.17	-3.3	6.17
11:00 to 1	153	7.46	241.55	63.82	13.63	1.23	-3.83	6.18
12:00 to 1	145.05	1.76	223.69	75.46	13.4	2.8	-3.78	6.31
13:00 to 1	155.86	-4.25	234.21	76.55	13.73	1.37	-2.53	5.99
14:00 to 1	160.35	-11.5	233.84	70.57	13.46	1.41	-2.25	6.28
15:00 to 1	147.8	1.34	227.48	66.35	13.5	1.34	-3.53	6.22
16:00 to 1	146.03	-2.45	220.97	69.12	13.56	1.4	-1.89	6.12
17:00 to 1	150.25	-4.78	225.1	90.25	13.6	1.47	-0.81	6.01
18:00 to 1	163.32	2.76	252.64	70.42	13.47	1.49	-1.78	6.15
19:00 to 1	169.33	-4.35	254.73	60.7	13.49	1.53	0.67	6.02
20:00 to 2	165.75	-5.85	247.74	58.08	13.57	1.54	1.34	5.91
21:00 to 2	159.19	-6.1	237.46	66.98	13.51	1.63	0.81	5.95
22:00 to 2	151.49	-1.05	230.73	59.91	13.57	1.96	1.84	5.94

23:00 to 2	159.19	-1.59	241.97	68	13.55	1.57	1.61	6.01
95 Percent	165.75	8.53	254.02	84.98	13.73	1.96	1.61	6.28
Daily Avera	153.3	-1.15	233.41	69.45	13.57	1.48	-2.14	6.1

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	149.35	-7.38	221.13	54.93	13.57	1.52	-1.18	6.01
01:00 to 0	151.88	-11.93	220.44	81.28	13.45	1.61	1.68	6.03
02:00 to 0	152.94	-4.19	229.81	79.85	13.59	1.6	1.8	5.94
03:00 to 0	153.18	-4.57	229.8	75.53	13.51	1.6	0.63	5.99
04:00 to 0	150.84	2.24	233.02	70.32	13.46	1.62	1.99	6.02
05:00 to 0	149.44	0.55	229.2	72.26	13.58	1.57	1.64	5.93
06:00 to 0	148.01	-1.96	224.5	77.84	13.62	1.54	-0.02	5.88
07:00 to 0	153.42	4.09	238.82	80.19	13.45	1.62	2.92	5.98
08:00 to 0	149.38	12.51	241.06	74.35	13.57	1.49	4.2	5.84
09:00 to 0	160.16	4.71	249.75	77.74	13.74	1	2.85	5.69
10:00 to 1	151.41	-2.39	229.28	124.76	13.75	1.12	-2.3	5.95
11:00 to 1	164.03	-11.64	239.32	78.47	13.52	1.34	-2.66	6.16
12:00 to 1	212.34	-23.52	301.37	104.47	12.1	8.6	6.84	6.18
13:00 to 1	157.7	8.44	249.73	83.52	13.51	1.37	-1.23	6.23
14:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.14
15:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.1
16:00 to 1	161.09	-7.68	238.78	77.32	13.48	1.34	-0.13	6.17
17:00 to 1	162.63	-33.2	215.63	65.53	13.35	1.43	-1.21	6.23
18:00 to 1	154.2	7.84	243.77	102	13.65	1.36	-0.74	6.03
19:00 to 1	155.66	16.25	254.41	107.69	13.77	1.34	-0.06	5.96
20:00 to 2	161.68	12.41	259.77	84.52	13.64	1.39	-1.72	6.11
21:00 to 2	154.04	10.12	245.8	84.45	13.35	1.42	-2.73	6.38
22:00 to 2	150.88	4.45	235.29	80.85	13.55	1.33	-3.34	6.17
23:00 to 2	148.55	16.64	243.93	87.59	13.74	1.19	-2.44	6
95 Percent	164.03	16.25	259.77	107.69	13.75	1.62	4.2	6.23
Daily Avera	156.95	-0.37	239.75	82.98	13.5	1.75	0.22	6.05

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	149.88	0.82	230.14	77.17	13.37	1.61	-2.21	6.3
01:00 to 0	154.26	-2.87	233.15	77.71	13.32	1.2	-1.77	6.34
02:00 to 0	153.24	-4.89	229.57	74.12	13.4	1.07	-2.76	6.28
03:00 to 0	152.57	7.31	240.75	84.48	13.58	0.98	-3.17	6.09
04:00 to 0	162.18	9.64	257.78	90.39	13.61	1.07	-1.86	6.01
05:00 to 0	156.42	-0.81	238.51	82.68	13.48	1.17	-2.91	6.16
06:00 to 0	149.58	-11.79	217.06	80.23	13.43	1.18	-4.72	6.19
07:00 to 0	143.55	-7.67	211.97	137.45	13.66	1.36	-4.16	5.96

08:00 to 0	148.08	-20.95	205.61	99.27	13.58	1.49	-1.3	5.86
09:00 to 0	154.99	-18.79	218.35	80.91	13.24	1.59	-1.76	6.19
10:00 to 1	146.77	-15.53	209.03	82.42	13.15	1.61	1.03	6.25
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.1
12:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.92
13:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.23
14:00 to 1	171.31	-7.49	254.62	74.14	13.39	1.43	0	6.22
15:00 to 1	168.99	3.68	262.23	67.93	13.55	1.32	-1.49	6.16
16:00 to 1	169.92	-6.93	253.05	69.3	13.67	1.38	-0.47	5.97
17:00 to 1	175.07	-7.24	260.62	65.63	13.64	1.48	3.33	5.83
18:00 to 1	172.37	-2.85	260.88	62.92	13.52	1.53	2.44	5.91
19:00 to 1	168.32	-1.72	255.81	65.94	13.39	1.56	4.03	5.98
20:00 to 2	162.02	-4.06	243.83	61.97	13.65	1.59	6.68	5.56
21:00 to 2	158.01	-10.36	231.38	62.4	13.73	1.59	2.85	5.54
22:00 to 2	168.33	-5.36	252.19	67.21	13.42	1.69	3.13	5.89
23:00 to 2	168.99	-13.5	245.06	71.23	13.2	1.69	1.04	6.22
95 Percent	172.37	7.31	260.88	99.27	13.67	1.69	4.03	6.3
Daily Average	159.76	-5.78	238.65	77.88	13.48	1.41	-0.19	6.05

CDAS 2004  
Report print

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	158.91	-4.17	238.96	54.22	13.46	2.1	-3.43	6.22
01:00 to 0	160.08	2.51	247.43	65.25	13.74	1.49	-2.41	5.91
02:00 to 0	165.24	12.6	265.41	66	13.54	1.52	-2.11	6.15
03:00 to 0	170.53	-20.58	240.33	63.64	13.33	1.49	-2.39	6.21
04:00 to 0	159.2	8.39	251.97	70.72	13.47	1.43	-3.38	6.26
05:00 to 0	152.71	8.24	241.89	80.35	13.79	1.37	-5.34	6.01
06:00 to 0	158.88	0.48	243.57	73.72	13.61	1.34	-3.34	5.99
07:00 to 0	158.51	-15.11	227.41	62.32	13.43	1.42	-3.04	6.2
08:00 to 0	151.36	-1.77	229.82	63.79	13.57	1.36	-4.58	6.15
09:00 to 0	146.86	-7.5	217.2	66.99	13.66	1.28	-3.94	5.94
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.86
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.24
12:00 to 1	150.57	-7.85	222.52	61.35	13.18	2.52	-2.79	6.41
13:00 to 1	149.82	-22.97	206.25	77.53	13.36	1.21	-1.55	6.12
14:00 to 1	150.59	-24.32	206.09	73.04	13.54	1.23	-3.01	5.98
15:00 to 1	157.09	-1.17	239.19	83.8	13.38	1.32	-2.54	6.19
16:00 to 1	158.07	2.88	244.73	81.01	13.34	1.33	-1.54	6.23
17:00 to 1	151.29	6.61	238.07	70.38	13.63	1.25	-2.63	6.02
18:00 to 1	145.4	-2.92	219.54	83.71	13.79	1.24	-1.35	5.75
19:00 to 1	155.45	-1.62	236.22	89.85	13.64	1.34	2.16	5.76
20:00 to 2	156.71	8.71	248.48	78.56	13.55	1.31	0.44	6.01
21:00 to 2	159.2	1.02	244.6	76.74	13.48	1.27	-1.63	6.1
22:00 to 2	159.89	-1.11	243.52	85.7	13.59	1.3	1.31	5.82
23:00 to 2	161.36	1.32	248.2	93	13.69	1.32	3.7	5.63
95 Percent	165.24	8.71	251.97	89.85	13.79	2.1	2.16	6.26
Daily Average	156.26	-2.65	236.43	73.71	13.53	1.43	-1.97	6.05

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	153.28	-3.34	231.18	66.67	13.44	1.92	0.88	5.97
01:00 to 0	161.4	5.49	252.42	96.05	13.27	1.34	2.08	6.16
02:00 to 0	157.59	-12.06	229.06	78.49	13.65	1.25	-3.71	6.01
03:00 to 0	150.72	4.94	235.54	104.18	13.94	1.24	-3.39	5.73
04:00 to 0	165.51	-0.75	252.47	92.73	13.59	1.35	-1.45	6.03
05:00 to 0	160.85	-0.98	245.13	88.91	13.46	1.4	-0.99	6.21
06:00 to 0	154.77	-24.28	212.52	82.63	13.58	1.34	-3.5	6.01
07:00 to 0	152.04	-35.88	196.75	109.06	13.63	1.39	-1.92	5.84
08:00 to 0	166.54	-39.42	215.4	80.29	13.45	1.49	0.69	5.9
09:00 to 0	157.05	9.71	250	90.83	13.44	1.32	-0.12	6.08
10:00 to 1	158.31	9.71	251.93	71.52	13.56	1.27	-1.91	6.16
11:00 to 1	163.28	5.43	255.24	84.47	13.63	1.19	-2.32	6.15
12:00 to 1	157.99	15.28	257.01	104.38	13.85	1.21	-4.04	5.92
13:00 to 1	166.6	1.66	256.55	85.38	13.29	2.55	-2.35	6.39
14:00 to 1	169.82	-6.96	252.86	107.09	13.25	1.64	-1.94	6.43
15:00 to 1	164.74	0.94	252.98	89.41	13.25	1.43	-2.19	6.41
16:00 to 1	156.06	15.7	254.47	87.79	13.67	1.37	-3.79	6.17
17:00 to 1	160.96	-5.09	241.17	92.17	13.41	1.53	0.76	6.15
18:00 to 1	152.94	7.92	241.92	98.89	13.45	1.46	-1.43	6.21
19:00 to 1	148.17	-2.04	224.67	70.19	13.6	1.44	-1.47	6.06
20:00 to 2	144.85	-9.1	212.52	80.02	13.9	1.4	-2.75	5.81
21:00 to 2	147.91	-4.95	221.36	80.82	13.5	1.42	-1.65	6.06
22:00 to 2	149.22	-6.35	221.96	75.68	13.47	1.47	2.24	6.03
23:00 to 2	146.39	13.55	237.52	71.36	13.63	1.45	1.51	5.99
95 Percent	166.6	15.28	256.55	107.09	13.9	1.92	2.08	6.41
Daily Avera	156.96	-2.54	237.61	87.04	13.54	1.45	-1.36	6.08

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	145.01	-9.65	212.2	85.59	13.44	1.5	2.08	5.92
01:00 to 0	147.6	-19.72	206.1	69.26	13.33	2.11	3.97	5.9
02:00 to 0	161.67	-12.72	234.63	75.85	13.29	1.49	3.68	6.03
03:00 to 0	154.22	-2.38	233.58	67.14	13.45	1.45	2.74	5.93
04:00 to 0	158.44	1.67	244.07	69.77	13.6	1.43	5.46	5.66
05:00 to 0	161.41	3.76	250.71	73.77	13.68	1.47	6.79	5.52
06:00 to 0	161.82	2.65	250.24	64.11	13.62	1.4	2.8	5.76
07:00 to 0	163.66	-1.96	248.44	63.58	13.45	1.43	1.4	6.06
08:00 to 0	161.43	3.15	250.14	65.6	13.49	1.38	0.46	6.13
09:00 to 0	153.9	-0.62	234.86	72.9	13.69	1.17	-1.69	5.97
10:00 to 1	152.78	-1.91	231.84	65.92	13.65	1	1.05	5.94

11:00 to 1	147.91	-7.68	218.62	70.18	13.52	1.03	0	6.14
12:00 to 1	149.65	-17.57	211.4	71.94	13.44	1.1	0.15	6.03
13:00 to 1	155.71	-54.46	183.77	48.32	13.27	2.2	-2.07	6.19
14:00 to 1	173.62	-69.23	196.41	56.08	13.07	1.12	-1.83	6.35
15:00 to 1	159.84	5.01	249.57	63.61	13.45	1.11	-2.25	6.33
16:00 to 1	150.9	18.79	249.67	73.32	13.56	1.16	-3.02	6.31
17:00 to 1	144.69	8.66	230.04	88.25	13.66	1.22	-1.87	6.06
18:00 to 1	136.33	6.68	215.27	94.81	13.75	1.23	-3.17	6.02
19:00 to 1	141.89	13.05	230.14	86.72	13.44	1.29	-2.64	6.39
20:00 to 2	142.56	8.29	226.4	84.01	13.43	1.3	-1.42	6.35
21:00 to 2	139.75	-6.18	207.64	84.19	13.6	1.26	-3.05	6.15
22:00 to 2	136.34	4.83	213.43	96.65	13.69	1.31	-2.59	6.09
23:00 to 2	145.18	-2.26	219.87	79.08	13.35	1.97	-1.64	6.4
95 Percent	163.66	13.05	250.24	94.81	13.69	2.11	5.46	6.39
Daily Avera	151.93	-5.41	227.04	73.78	13.5	1.38	0.14	6.07

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	170.54	-13.9	247.03	75.54	13.34	1.36	-3.12	6.39
01:00 to 0	171.46	-29.72	232.62	73.49	13.3	1.38	-2.2	6.35
02:00 to 0	155.6	-14.95	223.12	92.85	13.63	1.3	-3.52	6.12
03:00 to 0	161.87	3.31	250.97	87.58	13.53	1.32	-2.84	6.19
04:00 to 0	165.53	-1.58	251.67	74.99	13.46	1.31	-2.09	6.29
05:00 to 0	158.24	11.25	253.36	76.93	13.53	1.32	-2.98	6.31
06:00 to 0	144.21	-0.34	220.31	96.81	13.92	1.28	-4.51	5.87
07:00 to 0	145.88	-10.09	213.11	96.31	13.9	1.34	-2.66	5.76
08:00 to 0	152.96	-13.83	220.2	72.88	13.66	1.41	-2.06	6.01
09:00 to 0	154.29	7.7	243.77	73.31	13.65	1.32	-3.88	6.21
10:00 to 1	151.25	14.59	246	74.43	14.05	0.96	0.16	5.67
11:00 to 1	148.36	26.57	253.57	79.63	13.24	0.84	2.67	6.37
12:00 to 1	189.4	-38.67	251.1	44.92	11.49	1.02	7.31	7.46
13:00 to 1	197.24	-43.84	257.94	54.45	11.82	1.08	0.87	7.73
14:00 to 1	185.29	-77.05	206.44	48.72	12.1	1.18	0.53	7.36
15:00 to 1	175.98	16.98	286.23	57.74	12.42	1.19	2.14	7.24
16:00 to 1	166.67	6.22	261.23	55.87	12.44	1.19	2.23	7.17
17:00 to 1	156.75	7.06	246.89	50.85	12.62	1.24	4.33	6.87
18:00 to 1	152.62	12.69	246.2	56.91	12.63	1.24	2.85	6.94
19:00 to 1	153.95	1.87	237.41	54.55	12.6	1.26	3.52	6.91
20:00 to 2	152.45	-0.29	232.96	52.35	12.53	1.27	-0.42	7.26
21:00 to 2	147.46	-8.49	217.13	49.97	12.51	1.26	-2.04	7.33
22:00 to 2	148.48	-9.05	218.12	55.11	12.49	1.28	-1.52	7.34
23:00 to 2	141.94	14.3	231.47	56.28	12.56	1.27	-1.33	7.36
95 Percent	189.4	16.98	261.23	96.31	13.92	1.38	4.33	7.46
Daily Avera	160.35	-5.8	239.54	67.19	12.98	1.23	-0.36	6.69

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	138.8	-9.24	203.13	49.59	12.5	1.25	-2.29	7.34
01:00 to 0	136.95	-23.8	185.74	51.25	12.41	1.24	-1.78	7.39
02:00 to 0	143.1	-29.79	189.15	53.53	12.38	1.3	-1.59	7.41
03:00 to 0	145.17	-29.51	192.61	49.22	12.48	1.24	-3.71	7.39
04:00 to 0	144.42	-30.24	190.73	51.48	12.35	1.3	-1.69	7.41
05:00 to 0	143.55	-32.6	187.03	51.49	12.41	1.31	-1.64	7.39
06:00 to 0	139.45	-3.03	210.34	51.44	12.46	1.26	-2.59	7.44
07:00 to 0	155.01	16.25	253.41	46.67	12.69	1.25	-2.41	7.27
08:00 to 0	156.39	2.02	241.31	52.24	12.55	1.3	-2.39	7.37
09:00 to 0	146.68	9.43	233.85	50.24	12.56	1.26	-2.35	7.35
10:00 to 1	145.66	5.25	228.11	44.73	12.67	1.19	-3.37	7.33
11:00 to 1	152.53	1.26	234.64	46.08	12.6	1.18	-1.57	7.31
12:00 to 1	157.88	-5.36	236.2	46.36	12.65	1.09	-3.01	7.27
13:00 to 1	163.03	2.11	251.54	44.79	12.62	1.11	-1.62	7.25
14:00 to 1	158.6	5.97	248.62	43.94	12.67	1.08	-1.09	7.16
15:00 to 1	158.09	-20.43	221.46	44.5	12.56	1.09	-0.81	7.14
16:00 to 1	159.8	-23.48	221.01	44.33	12.55	1.16	-0.67	7.13
17:00 to 1	160.71	-28.82	217.08	45.92	12.58	1.23	2.2	6.85
18:00 to 1	152.53	5.09	238.47	46.6	12.75	1.27	4.12	6.67
19:00 to 1	156.79	1.16	241.05	50.93	12.75	1.27	0.76	6.9
20:00 to 2	158.25	0.37	242.49	44.14	12.7	1.29	2.99	6.82
21:00 to 2	151.38	-6.62	224.98	39.86	12.77	1.23	-1.11	6.98
22:00 to 2	149.8	9.64	238.84	45.35	12.8	1.22	-0.86	7.04
23:00 to 2	152.71	0.15	233.79	43.35	12.66	1.25	1.52	7.01
95 Percent	160.71	9.64	251.54	52.24	12.77	1.3	2.99	7.41
Daily Avera	151.14	-7.67	223.57	47.42	12.59	1.22	-1.04	7.19

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	146.76	8.96	233.51	43.18	12.76	1.23	4.37	6.69
01:00 to 0	146.72	3.73	228.22	50.32	12.63	1.27	5.11	6.76
02:00 to 0	144.84	10.49	232.1	53.04	12.66	1.25	1.58	6.99
03:00 to 0	145.87	8.73	231.9	50.11	12.65	1.26	4.12	6.81
04:00 to 0	147.82	1.86	228.03	47.14	12.68	1.29	7.45	6.57
05:00 to 0	146.96	-8.92	215.92	48.81	12.68	1.25	3.99	6.76
06:00 to 0	149.99	5.24	234.72	52.59	12.62	1.29	4.86	6.78
07:00 to 0	154.62	-12.99	223.58	44.73	12.65	1.27	6.08	6.63
08:00 to 0	161.5	-16.01	231.07	48.03	12.59	1.24	5.03	6.78
09:00 to 0	146.72	-3.19	221.29	41.95	12.15	1.24	7.67	6.91
10:00 to 1	125.77	-0.14	192.29	38.78	7.26	2.07	21.57	9.04
11:00 to 1	175.09	4.98	272.87	50.55	10.94	1.22	-6.27	9.21
12:00 to 1	147.6	2.66	228.48	104.99	11	1.47	9.16	7.51
13:00 to 1	162.1	2.02	250.04	58.14	12.94	1.31	-4.03	7.05

14:00 to 1	137.26	26.21	236.21	41.15	13.72	3.59	-0.48	6.11
15:00 to 1	148.22	-12.62	214.16	41.66	13.64	1.01	-1.26	5.99
16:00 to 1	156.91	-22.78	217.3	46.01	13.59	0.99	0.23	5.91
17:00 to 1	154	-20.19	215.43	43.21	13.67	0.98	-0.8	5.89
18:00 to 1	147.15	1.86	227	47.91	13.85	1.02	-1.99	5.9
19:00 to 1	151.73	-8.2	223.95	49.3	13.77	1.06	0.17	5.85
20:00 to 2	155.18	-7.16	230.28	47.64	13.83	1.08	0.11	5.84
21:00 to 2	153.69	1.35	236.5	48.25	13.76	1.09	0.11	5.88
22:00 to 2	153.24	-5.15	229.3	39.41	13.64	1.65	-0.07	6.01
23:00 to 2	162.07	12.13	260.1	45.49	13.84	1.12	0.36	5.85
95 Percent	162.1	12.13	260.1	58.14	13.84	2.07	9.16	9.04
Daily Avera	150.91	-1.13	229.76	49.27	12.73	1.34	2.8	6.66

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	160.63	-3.67	242.09	44.77	13.7	1.14	-0.45	5.93
01:00 to 0	158.95	-3.88	239.32	46.96	13.67	1.16	-0.25	6.03
02:00 to 0	152.36	20.23	253.35	51.48	13.76	1.14	-2.03	6.17
03:00 to 0	147.02	-0.98	223.96	49.59	13.55	1.19	-5.3	6.39
04:00 to 0	143.42	-3.66	215.77	49.04	13.62	1.23	-5.1	6.39
05:00 to 0	143.13	1.58	220.57	51.3	13.61	1.27	-4.63	6.47
06:00 to 0	146.09	-5.25	218.26	50.81	13.52	1.31	-3.8	6.31
07:00 to 0	148.52	-7.97	219.25	48.18	13.53	1.33	-4.94	6.44
08:00 to 0	145.87	0.6	223.79	48.81	13.65	1.28	-3.88	6.33
09:00 to 0	152.28	-2.1	230.9	49.1	13.7	1.1	-4.92	6.16
10:00 to 1	155.22	-6.15	231.33	48.81	13.65	1.12	-3.93	6.21
11:00 to 1	153.83	-0.7	234.66	49	13.68	1.08	-3.08	6.24
12:00 to 1	146.01	17.66	241.05	43.81	13.8	2.2	-4.48	6.22
13:00 to 1	154.36	-19.17	216.99	46.26	13.61	1.07	-2.55	6.07
14:00 to 1	158.34	-33.34	208.92	50.18	13.58	1.05	-3.55	6.05
15:00 to 1	158.58	-8.58	234.05	51.45	13.77	1.03	-3.4	5.97
16:00 to 1	160.35	-7.33	238.01	54.44	13.84	1.08	-2.74	5.88
17:00 to 1	166.28	-32.24	222.16	50.8	13.64	1.19	-1.85	5.96
18:00 to 1	161.91	-5.53	242.2	63.1	13.72	1.29	-3.35	6.06
19:00 to 1	158.68	8.29	251.08	63.54	13.85	1.33	-2.33	6
20:00 to 2	174.86	-4.5	263.04	56.83	13.74	1.39	-2.51	6.13
21:00 to 2	174.58	-32.89	234.22	50.24	13.64	1.4	-3.09	6.04
22:00 to 2	179.18	-36.6	237.54	50.56	13.54	1.48	2.79	5.76
23:00 to 2	182.68	-33.97	245.53	53.31	13.32	1.81	5.9	5.83
95 Percent	179.18	17.66	253.35	63.1	13.84	1.81	2.79	6.44
Daily Avera	157.63	-8.34	232.84	50.93	13.65	1.28	-2.64	6.13

CDAS 2004  
Report prir



17:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	131.83	-87.58	114.11	1848.56	3.05	34.97	-13.46	18.67
21:00 to 2	181.21	-9.77	267.48	1232.44	6.64	2.8	-24.09	16.8
22:00 to 2	167.42	2.61	258.77	21.06	11.32	1.45	-32.73	11.21
23:00 to 2	162.76	13.97	262.99	27.4	13.15	1.53	-13.32	7.48
95 Percent	181.21	13.97	267.48	1848.56	13.15	34.97	-13.32	18.67
Daily Avera	160.81	-20.19	225.84	782.36	8.54	10.19	-20.9	13.54

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	168.45	-10.04	247.69	33.39	13.12	1.63	-8.91	7.1
01:00 to 0	170.19	-20.64	239.75	27.6	10.48	2.16	9.13	8.64
02:00 to 0	160.62	3.03	248.79	20.38	11.92	1.57	-8.78	8.66
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
10:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
11:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
12:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
13:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
14:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
15:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
16:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
17:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
21:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
22:00 to 2	145.27	-41.25	181.02	363.9	6.33	14.21	-25.74	16.86
23:00 to 2	147.61	-22.5	203.34	17	11.67	1.3	-30.81	10.51
95 Percent	170.19	3.03	248.79	363.9	13.12	14.21	9.13	16.86
Daily Avera	158.43	-18.28	224.12	92.46	10.7	4.17	-13.02	10.36

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	148.91	12.37	240.2	830.19	5.48	4.53	20.8	11.31
01:00 to 0	145.57	-39.1	183.62	5027.69	3.19	11.08	1.72	16.42

02:00 to C	162.95	-3.62	245.7	43.85	11.05	10.06	-40.74	11.99
03:00 to C	148.66	-5.64	221.81	42.51	13.16	1.77	-10.22	7.11
04:00 to C	149.54	-5.04	223.75	78.22	13.42	2.27	-7.13	6.7
05:00 to C	150.5	-10.73	219.53	110.18	13.24	1.97	-5.52	6.85
06:00 to C	153.21	-4.63	229.78	72.64	13.27	1.76	-7.6	6.8
07:00 to C	164.58	-8.01	243.8	65.31	13.17	1.75	-5.83	6.88
08:00 to C	143.07	-1.59	217.31	179.35	13.35	1.61	-7.95	6.82
09:00 to C	145.19	-9.72	212.42	76.24	13.25	1.15	-7.63	6.76
10:00 to 1	148.76	-5.28	222.33	64.14	13.26	1.06	-7.42	6.85
11:00 to 1	144.2	-5.57	215.06	59.82	13.37	1.01	-7.39	6.79
12:00 to 1	132.27	11.82	214.19	96.67	13.29	2.49	-7.65	6.87
13:00 to 1	152.29	-8.97	224.04	82.41	13.29	0.94	-7.06	6.73
14:00 to 1	149.02	-14.71	213.29	102.08	13.32	1.07	-5.98	6.64
15:00 to 1	140.01	7.33	221.55	221.39	13.53	1.1	-8.62	6.63
16:00 to 1	133.81	7.44	212.16	371.56	13.54	1.12	-7.95	6.55
17:00 to 1	139.2	1.48	214.46	172.77	13.46	1.19	-5.78	6.54
18:00 to 1	130.3	10.36	209.72	241.72	13.4	1.33	-7.4	6.69
19:00 to 1	126.28	10.05	203.26	285.73	13.4	1.28	-5.35	6.61
20:00 to 2	130.69	8.4	208.35	119.83	13.41	1.27	-5.23	6.64
21:00 to 2	130.81	-29.2	170.94	129.78	13.19	1.33	-7.52	6.73
22:00 to 2	127.37	-43.22	151.65	236.45	13.19	1.36	-4.98	6.65
23:00 to 2	136.23	-39.11	169.32	84.93	13.2	1.37	-5.02	6.73
95 Percent	162.95	11.82	243.8	830.19	13.53	10.06	1.72	11.99
Daily Avera	143.06	-6.87	212.01	366.48	12.48	2.33	-6.81	7.55

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	139.43	-8.68	204.65	73.68	13.25	1.39	-6.07	6.72
01:00 to C	135.62	-6.15	201.34	82.26	13.31	1.42	-4.52	6.76
02:00 to C	132.16	2.66	204.87	109.67	13.38	1.41	-4.63	6.73
03:00 to C	135.32	-13.51	193.53	74.43	13.22	1.42	-5.19	6.74
04:00 to C	135.75	-10.7	196.99	85.82	13.33	1.44	-5.09	6.77
05:00 to C	125.15	-13.48	177.99	116.04	13.41	1.45	-3.74	6.65
06:00 to C	126.32	-13.78	179.49	97.15	13.27	1.45	-6.24	6.76
07:00 to C	133.87	-4.98	199.83	77.44	13.29	1.5	-2.9	6.74
08:00 to C	120.71	-7.6	177.08	111.05	13.32	1.43	-4.13	6.77
09:00 to C	117.43	8.27	187.93	137.09	13.3	1.07	-4.59	6.69
10:00 to 1	121.05	9.54	194.75	116.6	13.47	0.99	-5.42	6.71
11:00 to 1	126.66	9.44	203.23	99.83	13.52	1.03	-4.88	6.69
12:00 to 1	109.51	11.57	179.12	207.49	13.37	2.43	-5.75	6.68
13:00 to 1	127.88	-12.43	183.22	90.3	13.34	1.13	-5.46	6.63
14:00 to 1	139.82	-13.1	200.83	84.77	13.25	1.16	-4.65	6.68
15:00 to 1	128.11	2.03	198.05	182.41	13.48	1.01	-6.81	6.62
16:00 to 1	128.48	2.71	199.29	135.93	13.42	1.08	-4.71	6.58
17:00 to 1	127.32	-8.34	186.45	138.38	13.42	1.17	-5.2	6.56
18:00 to 1	126.92	1.55	195.74	167.03	13.35	1.36	-4.34	6.55
19:00 to 1	122.43	0.15	187.47	305.93	13.23	1.41	-2.88	6.59

20:00 to 2	124.78	1.43	192.35	117.87	13.37	1.4	-4.22	6.6
21:00 to 2	124.04	-10.37	179.4	119.52	13.26	1.38	-5.05	6.68
22:00 to 2	116.89	-0.09	178.75	210.69	13.41	1.35	-5.57	6.64
23:00 to 2	117.49	-14.7	165.07	161.34	13.26	1.45	-3.26	6.68
95 Percent	139.43	9.54	204.65	210.69	13.48	1.5	-2.9	6.77
Daily Avera	126.8	-3.69	190.31	129.28	13.34	1.35	-4.8	6.67

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	123.73	-26.75	162.55	117.69	13.24	1.41	-6.28	6.71
01:00 to 0	132.99	-35.4	168.07	134.76	13.14	1.55	-3.13	6.7
02:00 to 0	136.8	-58.18	151.13	154.08	13.08	1.63	-3.73	6.73
03:00 to 0	131.8	15.14	216.79	148.07	13.33	1.63	-4.22	6.71
04:00 to 0	132.23	19.34	221.66	139.87	13.31	1.62	-3.54	6.78
05:00 to 0	121.8	39.55	225.91	250.56	13.56	1.53	-3.98	6.66
06:00 to 0	134.76	-17.57	188.61	149.85	13.15	1.58	-4.77	6.74
07:00 to 0	133.59	-21.77	182.63	194.84	13.24	1.63	-4.17	6.72
08:00 to 0	139.08	-13.52	199.27	130.38	13.26	1.54	-3.18	6.69
09:00 to 0	125.84	21.53	214.06	342.52	13.36	1.22	-5.23	6.7
10:00 to 1	133.41	18.17	222.28	120.76	13.46	1.2	-3.88	6.67
11:00 to 1	130.32	16.54	215.92	158.51	13.49	1.25	-4.96	6.7
12:00 to 1	120.77	6.68	191.46	185.93	13.37	1.98	-5.08	6.65
13:00 to 1	128.54	-22.33	174.33	122.78	13.35	2.1	-5.62	6.68
14:00 to 1	137.32	-16.24	193.87	115.47	13.34	1.32	-4.29	6.65
15:00 to 1	124.67	-4.44	186.3	208.45	13.26	1.32	-5.74	6.7
16:00 to 1	119.06	3.19	185.35	329.96	13.33	1.39	-3.78	6.67
17:00 to 1	124.39	-1.14	189.18	191.38	13.32	1.47	-3.77	6.74
18:00 to 1	123.03	22.42	210.65	144.24	13.35	1.55	-4.72	6.72
19:00 to 1	117.14	11.62	190.85	344.06	13.39	1.56	-3.61	6.61
20:00 to 2	127.32	-4.36	190.44	133.25	13.27	1.61	-3.7	6.75
21:00 to 2	129.34	-13.06	184.83	126.06	13.16	1.61	-4.7	6.67
22:00 to 2	126.27	-4.18	189.02	146.15	13.22	1.63	-3.63	6.77
23:00 to 2	126.02	-15.86	176.95	241.17	13.23	1.66	-2.22	6.66
95 Percent	137.32	22.42	222.28	342.52	13.49	1.98	-3.13	6.77
Daily Avera	128.34	-3.36	193	180.45	13.3	1.54	-4.25	6.7

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	126.74	-3.21	190.7	156.19	13.18	1.64	-4.43	6.7
01:00 to 0	131.52	-4.77	196.46	120.52	13.24	1.7	-2.53	6.64
02:00 to 0	128.81	-1.16	195.92	227.04	13.33	1.71	-1.28	6.46
03:00 to 0	132.9	-12.44	190.91	115.54	13.21	1.66	-5.31	6.68
04:00 to 0	132.28	12.06	214.46	120.57	13.23	1.78	-2.28	6.64

05:00 to 0	129.99	-8.15	190.73	120.81	13.2	1.77	-0.91	6.52
06:00 to 0	119.84	-13.73	169.62	148.61	13.16	1.75	-1.43	6.49
07:00 to 0	125.45	-11.48	180.46	142.04	13.07	1.76	-2.87	6.71
08:00 to 0	123.16	3.8	192.23	137.25	13.26	1.64	-3.28	6.63
09:00 to 0	118.65	2.2	183.73	204.71	13.29	1.6	-1.4	6.39
10:00 to 1	121.17	8.09	193.48	152.78	13.35	1.52	-4	6.57
11:00 to 1	126.51	40.67	234.23	148.88	13.37	1.63	-2.41	6.61
12:00 to 1	123.32	-0.89	187.78	188.74	13.36	1.37	-5.72	6.64
13:00 to 1	125.43	-6.09	185.81	131.13	13.15	2	-4.03	6.7
14:00 to 1	123.98	-19.57	170.12	88.68	13.19	2.34	-4.95	6.72
15:00 to 1	129.39	2.62	200.59	95.59	13.23	1.54	-4.96	6.68
16:00 to 1	121.17	10.49	195.88	290.6	13.26	1.52	-3.47	6.65
17:00 to 1	124.6	-17.15	173.49	153.7	13.26	1.61	-4.92	6.69
18:00 to 1	124.41	-5.98	184.36	115.19	13.18	1.65	-4.78	6.7
19:00 to 1	121.06	7.93	193.15	175.47	13.35	1.63	-4.33	6.65
20:00 to 2	125.29	-14.55	177.15	140.33	13.17	1.66	-3.36	6.73
21:00 to 2	129.08	-2	195.49	125.65	13.2	1.62	-5.43	6.72
22:00 to 2	132.72	8.31	211.37	99.17	13.26	1.69	-3.65	6.67
23:00 to 2	123.28	13.13	201.75	305.49	13.2	1.75	-2.41	6.66
95 Percent	132.72	13.13	214.46	290.6	13.36	2	-1.28	6.72
Daily Avera	125.86	-0.49	192.08	154.36	13.24	1.69	-3.51	6.63

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	127.74	-36.32	159.12	116.86	13.08	1.72	-4.47	6.7
01:00 to 0	126.43	-52.48	140.96	97.32	13	1.75	-4.24	6.8
02:00 to 0	117.12	-42.31	136.89	197.29	13.24	1.71	-4.25	6.65
03:00 to 0	112.27	-11.18	160.58	188.01	13.13	1.71	-5.25	6.73
04:00 to 0	116.7	-18.74	159.81	198.39	13.14	1.74	-3.95	6.72
05:00 to 0	126.99	-16.34	177.96	110.75	13.09	1.8	-3.21	6.76
06:00 to 0	118.84	-6.08	175.74	224.49	13.27	1.73	-5.76	6.74
07:00 to 0	130.27	10.44	209.75	131.25	13.25	1.83	-3.06	6.75
08:00 to 0	131.83	26.15	227.85	103.16	13.34	1.8	-3.95	6.78
09:00 to 0	119.71	2.98	186.14	342.11	13.28	1.53	-5.98	6.68
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.75
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.83
12:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.93
13:00 to 1	138.35	5.7	217.37	147.98	13.26	1.54	-6.21	6.72
14:00 to 1	146.73	-2.01	222.48	97.76	13.19	1.63	-1.97	6.69
15:00 to 1	146.02	-3.76	219.65	102.57	13.14	1.62	-5.09	6.71
16:00 to 1	136.57	-16.41	192.54	177.4	13.11	1.75	-2.7	6.64
17:00 to 1	143.51	-27.16	192.41	116.23	13.01	1.82	-2.93	6.77
18:00 to 1	144	-6.69	213.63	78.15	13.07	1.82	-4.26	6.73
19:00 to 1	141.72	-9.22	207.61	84.96	13.05	1.9	-2.84	6.77
20:00 to 2	147.59	-17	208.82	86.01	13.05	1.93	-3.31	6.76
21:00 to 2	152.55	-6.15	227.25	77.23	12.98	1.94	-4.1	6.81
22:00 to 2	153.76	1.42	236.67	79.11	13.05	1.97	-3.09	6.79

23:00 to 2	146.52	8.45	232.62	86.65	13.11	1.94	-2.82	6.7
95 Percent	152.55	10.44	232.62	224.49	13.28	1.94	-2.7	6.83
Daily Avera	134.53	-10.32	195.52	135.41	13.13	1.77	-3.97	6.75

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.1	483.5	N/A	0	0	85.03	151.77	998.52
0	6.2	614.2	N/A	0	0	84.56	152.51	999.21
0	6.3	657	N/A	0	0	85.17	153.54	1000.31
0	6.2	470.2	N/A	0	0	86.5	154.21	1000.51
0	6	623.2	N/A	0	0	84.09	153.97	1001.58
0	6.2	721.6	N/A	0	0	85.79	154.16	1002.52
0	6	484.7	N/A	0	0	85.39	154.46	1003.24
0	6.2	621.9	N/A	0	0	85.48	154.12	1003.74
0	6.3	689.6	N/A	0	0	86.37	155.27	1004.57
0	6.1	554	N/A	0	0	87.85	155.81	1005.36
0	6.1	799.4	N/A	0	0	85.73	155.25	1006.52
0	6	934	N/A	0	0	83.96	153.8	1006.97
0	5.8	692.8	N/A	0	0	83.72	153.96	1006.94
0	6	756.5	N/A	0	0	83.79	151.88	1006.44
0	6.2	749.3	N/A	0	0	82.39	149.2	1006.58
0	6	508.9	N/A	0	0	82.15	150.04	1006.76
0	6.1	685.8	N/A	0	0	81.89	150.15	1007.4
0	6.2	707.9	N/A	0	0	81.67	150.33	1008.12
0	6	496.4	N/A	0	0	80.44	149.68	1008.37
0	6	601.8	N/A	0	0	80.4	149.97	1008.94
0	6	674.9	N/A	0	0	80	149.55	1009.65
0	6.1	495.3	N/A	0	0	80.51	149.98	1009.9
0	6.1	629.7	N/A	0	0	80.29	150.12	1010.31
0	6.3	693.8	N/A	0	0	81.89	150.56	1010.46
0	6.3	799.4	N/A	0	0	86.5	155.27	1010.31
0	6.1	639.4	N/A	0	0	83.54	152.26	1005.54

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6	508.9	N/A	0	0	80.84	150.38	1010.76
0	6.1	632	N/A	0	0	80.58	150.95	1011.12
0	6	719.8	N/A	0	0	79.73	151.49	1011.8
0	5.9	545.8	N/A	0	0	79.68	151.65	1011.89
0	6.1	692.9	N/A	0	0	81.91	152.01	1011.99
0	6	736.4	N/A	0	0	81.36	152.33	1011.8
0	6.1	538.8	N/A	0	0	80.71	152.3	1011.89
0	6.2	682.1	N/A	0	0	82.29	152.99	1012.26
0	6.2	761	N/A	0	0	81.91	153.02	1012.45
0	5.9	537.2	N/A	0	0	82.08	153.29	1013.03
0	6	708.1	N/A	0	0	81.17	152.85	1013.29
0	6.1	919.2	N/A	0	0	83.4	153.22	1014.16
0	6.3	929.3	N/A	0	0	85.68	153.73	1014.86
0	6.3	911.3	N/A	0	0	85.04	151.89	1013.21

0	6.1	925.1 N/A	0	0	84.22	152.36	1012.22
0	6.1	630.9 N/A	0	0	83.24	152.42	1011.99
0	6	738.2 N/A	0	0	81.13	151.43	1011.91
0	6.1	743.2 N/A	0	0	80.8	150.73	1011.94
0	6.1	536 N/A	0	0	80.91	151.13	1011.96
0	6.1	692.4 N/A	0	0	80.7	151.01	1012.22
0	6.1	776.6 N/A	0	0	80.15	150.99	1012.29
0	5.9	577 N/A	0	0	77.93	150.7	1011.91
0	6.1	757.3 N/A	0	0	81.52	150.47	1011.68
0	5.9	853.1 N/A	0	0	78.9	147.74	1011.18
0	6.3	925.1 N/A	0	0	85.04	153.29	1014.16
0	6.1	710.5 N/A	0	0	81.49	151.71	1012.24

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combus	tio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.1	634.2 N/A	0	0	80.45	148.51	1010.34		
0	6	815.3 N/A	0	0	80.03	149.31	1009.42		
0	6	883.8 N/A	0	0	79.95	149.61	1008.21		
0	6.1	517.6 N/A	0	0	80.46	150.05	1006.07		
0	5.9	635.4 N/A	0	0	78.8	149.95	1005.09		
0	6	722.8 N/A	0	0	79.07	150.44	1004.67		
0	5.9	539.6 N/A	0	0	79.15	150.5	1004.3		
0	6.1	667.7 N/A	0	0	79.48	150.42	1004.16		
0	6.1	724.6 N/A	0	0	81.1	151.58	1003.97		
0	6.2	543.1 N/A	0	0	82.5	153.68	1004.51		
0	6.1	723.7 N/A	0	0	84.47	155.1	1004.88		
0	6	793 N/A	0	0	83.12	154.69	1004.73		
0	6.2	617.2 N/A	0	0	85.91	154.05	1004.75		
0	5.9	751.7 N/A	0	0	82.99	150.68	1004.67		
0	5.9	843.6 N/A	0	0	84.77	151.29	1004.75		
0	5.9	616.1 N/A	0	0	84.98	152.07	1005.25		
0	5.8	687.9 N/A	0	0	84.24	151.74	1005.67		
0	5.8	738.2 N/A	0	0	81.84	151.06	1006.43		
0	5.6	543.1 N/A	0	0	83.48	151.26	1006.96		
0	5.9	654.9 N/A	0	0	83.56	151.3	1007.9		
0	6	736.2 N/A	0	0	84.39	151.94	1008.61		
0	6	543.2 N/A	0	0	84.57	152.34	1009.76		
0	6	697.3 N/A	0	0	84.78	152.05	1010.96		
0	6	789.9 N/A	0	0	82.83	151.28	1012.09		
0	6.2	843.6 N/A	0	0	84.98	154.69	1010.96		
0	6	684.2 N/A	0	0	82.37	151.45	1006.59		

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	5.7	574.6	N/A	0	0	82.8	150.87	1013.31
0	5.9	688.8	N/A	0	0	83.43	150.49	1014.69
0	5.9	732.9	N/A	0	0	83.65	150.93	1015.63
0	6	502.3	N/A	0	0	83.35	150.93	1016.66
0	5.8	620.8	N/A	0	0	81.95	150.67	1017.96
0	5.6	675.5	N/A	0	0	82.02	150.48	1019.3
0	5.6	507.2	N/A	0	0	81.65	150.51	1020.81
0	5.9	618.7	N/A	0	0	82.71	150.71	1021.95
0	6	693.8	N/A	0	0	82.96	151.02	1023.37
0	5.9	548.2	N/A	0	0	84.03	151.79	1024.79
0	5.8	793.1	N/A	0	0	83.74	151.61	1025.81
0	5.6	912.6	N/A	0	0	81.31	151.62	1026.22
0	5.9	671.4	N/A	0	0	82.71	151.43	1026.58
0	6	804.9	N/A	0	0	84.97	150.83	1026.1
0	6	838.5	N/A	0	0	83.31	148.66	1026.6
0	5.8	597.9	N/A	0	0	83.12	149.34	1027.17
0	5.9	700.1	N/A	0	0	81.45	148.66	1027.21
0	5.7	716.8	N/A	0	0	81.87	148.51	1027.37
0	5.9	485.6	N/A	0	0	82.16	149.01	1027.46
0	6	579.5	N/A	0	0	82.36	149.47	1027.63
0	6.1	622.8	N/A	0	0	83.06	149.95	1027.6
0	5.8	437.6	N/A	0	0	82.24	150.32	1027.56
0	6.2	554.4	N/A	0	0	83.35	150.4	1027.5
0	6	600	N/A	0	0	82.88	149.58	1027.53
0	6.1	838.5	N/A	0	0	84.03	151.62	1027.6
0	5.9	644.9	N/A	0	0	82.79	150.32	1023.62

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.2	424.1	N/A	0	0	83.78	150.33	1027.1
0	6.1	539.8	N/A	0	0	82.2	150.14	1026.97
0	6.1	626	N/A	0	0	82.33	150.52	1027.13
0	5.9	470.4	N/A	0	0	81.83	150.33	1026.99
0	5.8	577.7	N/A	0	0	81.03	150.53	1026.63
0	6	622.7	N/A	0	0	82.39	150.71	1026.36
0	6	459.2	N/A	0	0	83.8	151.96	1026.04
0	6.1	577.5	N/A	0	0	82.97	151.63	1026.09
0	6.1	645.9	N/A	0	0	83.5	151.91	1026.25
0	5.8	483.1	N/A	0	0	81.59	150.94	1026.12
0	5.6	651.4	N/A	0	0	80.66	150.18	1026.26
0	5.8	882.2	N/A	0	0	82.1	150.39	1026.44
0	5.8	558.8	N/A	0	0	82.27	151.12	1025.3
0	5.9	693.2	N/A	0	0	83.3	151.74	1024.69
0	5.9	744.7	N/A	0	0	82.96	151.23	1023.86
0	5.7	541.4	N/A	0	0	81.05	148.04	1023.19
0	5.8	634.9	N/A	0	0	81.52	148.16	1022.92



Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
0	10	482.2	N/A	0	0	56.32	135.28	1021.41
0	8	746.6	N/A	0	0	57.9	134.9	1021.96
0	8	899.3	N/A	0	0	55.34	129.19	1021.85
0	7.6	791.1	N/A	0	0	53.88	126.75	1022.14
0	7.2	860.1	N/A	0	0	52.56	125.2	1021.18
0	7	822.3	N/A	0	0	63.48	127.16	1020.37
0	6.1	543.7	N/A	0	0	82.26	144.42	1020
0	6	652.6	N/A	0	0	80.46	148.01	1020.07
0	5.8	701.4	N/A	0	0	81.13	148.6	1020.12
0	5.8	513	N/A	0	0	80.72	148.91	1020.02
0	6	683.4	N/A	0	0	80.79	149.25	1020.22
0	5.8	775.2	N/A	0	0	79.89	149.06	1020.31
0	5.5	535.2	N/A	0	0	80.52	148.63	1019.84
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	5.8	345.1	N/A	0	0	80.61	148.55	1019.17
0	10	899.3	N/A	0	0	82.26	149.25	1022.14
0	6.8	668	N/A	0	0	70.42	140.28	1020.62

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.1	385.1	N/A	0	0	82.12	148.21	1019.21
0	5.9	599.5	N/A	0	0	81.27	148.68	1019.17
0	5.8	756.8	N/A	0	0	80.28	148.36	1018.59
0	5.5	595.8	N/A	0	0	78.45	148.34	1017.72
0	5.9	751.7	N/A	0	0	80.31	148.69	1017.14
0	6.2	868.8	N/A	0	0	80.92	149.18	1016.78
0	5.7	651.5	N/A	0	0	78.97	149.2	1016.58
0	5.5	835.3	N/A	0	0	78.65	148.79	1016.34
0	5.9	939.6	N/A	0	0	80.14	148.85	1015.92
0	6	712	N/A	0	0	80.81	149.56	1015.76
0	5.8	952.4	N/A	0	0	80.9	150.17	1015.78
0	5.9	1084.5	N/A	0	0	81.21	150.4	1015.59
0	5.9	820.6	N/A	0	0	82.27	149.84	1015.08
0	6	1068.9	N/A	0	0	83.48	148.7	1014.36
0	5.9	1163.7	N/A	0	0	82.33	149.73	1013.24
0	5.8	833.6	N/A	0	0	81.59	150.12	1012.3
0	5.7	1040.9	N/A	0	0	81.53	149.93	1011.79
0	5.9	1036.7	N/A	0	0	82.07	150.37	1010.39
0	5.9	718.3	N/A	0	0	82.47	150.68	1009.18
0	5.8	843.4	N/A	0	0	80.62	150.38	1008.31

0	5.6	858.2 N/A	0	0	80	149.83	1007.14
0	6	628.6 N/A	0	0	82.05	150.17	1006.11
0	6.1	813.5 N/A	0	0	81.64	149.1	1005.57
0	6	828.2 N/A	0	0	80.57	149.8	1004.87
0	6.1	1084.5 N/A	0	0	82.47	150.4	1019.17
0	5.9	824.5 N/A	0	0	81.03	149.46	1013.45

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow	Nm3/	Temperatu	Static Press
0	5.7	580.6 N/A		0	0	79.27	149.71	1004.85
0	5.8	684.2 N/A		0	0	79.2	149.01	1004.43
0	5.9	711 N/A		0	0	79.14	149.46	1003.71
0	5.9	485.1 N/A		0	0	80.05	149.9	1004.01
0	5.9	594.9 N/A		0	0	79.45	149.41	1004.93
0	5.7	602.6 N/A		0	0	79.12	149.16	1005.54
0	5.9	432.4 N/A		0	0	80.17	150.18	1006.02
0	6	509.4 N/A		0	0	80.21	149.95	1006.56
0	6	517.3 N/A		0	0	80.42	150.47	1007.71
0	5.8	465.2 N/A		0	0	78.93	149.73	1009.43
0	5.8	629.1 N/A		0	0	80.42	150.05	1010.77
0	5.9	744.1 N/A		0	0	80.03	150.32	1011.78
0	6	594.7 N/A		0	0	81.93	150.76	1012.58
0	5.7	673.8 N/A		0	0	80.72	148.39	1012.97
0	6	711 N/A		0	0	81.59	148.08	1013.35
0	6.1	502.9 N/A		0	0	81.4	149.37	1013.77
0	5.8	634.7 N/A		0	0	82.48	149.96	1014.2
0	6	640.6 N/A		0	0	81.13	149.72	1015.02
0	5.7	458.2 N/A		0	0	79.74	149.37	1015.8
0	5.9	575.1 N/A		0	0	81.25	149.6	1016.78
0	6	632.9 N/A		0	0	79.88	149.92	1016.81
0	5.7	480 N/A		0	0	77.18	148.75	1016.94
0	5.7	611.7 N/A		0	0	78.09	147.82	1016.99
0	5.9	708.1 N/A		0	0	78.9	147.08	1017.38
0	6	711 N/A		0	0	81.93	150.47	1016.99
0	5.9	590.8 N/A		0	0	80.03	149.42	1010.93

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow	Nm3/	Temperatu	Static Press
0	5.8	513.6 N/A		0	0	78.93	148.32	1016.56
0	5.7	662.2 N/A		0	0	77.81	148.21	1015.84
0	5.5	795.7 N/A		0	0	77.68	147.91	1015.62
0	5.7	611 N/A		0	0	78.33	148.36	1014.88
0	5.6	794.8 N/A		0	0	78.53	149.26	1014.43

0	5.7	844.8 N/A	0	0	78.97	150	1013.48
0	5.6	553 N/A	0	0	79.3	150.44	1012.03
0	5.8	697.2 N/A	0	0	79.65	150.58	1011.48
0	5.8	763.3 N/A	0	0	79.78	151.11	1010.34
0	5.8	579.3 N/A	0	0	79.24	151.27	1009.05
0	5.6	770.5 N/A	0	0	79.28	150.89	1008.13
0	5.8	892.8 N/A	0	0	79.72	150.92	1007.29
0	5.8	648.6 N/A	0	0	79.5	149	1006.05
0	6.1	823 N/A	0	0	81.22	148.52	1004.99
0	5.7	903.2 N/A	0	0	78.95	148.72	1004.17
0	5.7	624.5 N/A	0	0	79.09	148.89	1003.73
0	5.9	792.8 N/A	0	0	80.32	149.31	1003.17
0	5.9	831.8 N/A	0	0	80.59	150.02	1002.38
0	5.8	606.3 N/A	0	0	78.9	150.62	1000.93
0	5.7	810.5 N/A	0	0	80.41	150.4	999.77
0	5.7	914 N/A	0	0	80.69	150.57	998.55
0	5.9	653.9 N/A	0	0	81.4	151.9	997.54
0	6.1	846.6 N/A	0	0	82.99	151.28	998.49
0	6	847.9 N/A	0	0	81.99	151.03	999.55
0	6.1	903.2 N/A	0	0	81.99	151.28	1015.84
0	5.8	740.9 N/A	0	0	79.72	149.9	1007.02

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	5.7	571.8 N/A	0	0	80.2	151.39	999.89	
0	6.1	699.3 N/A	0	0	81.55	151.4	999.93	
0	6.1	737.8 N/A	0	0	81.75	151.66	1000.25	
0	5.9	487 N/A	0	0	80.37	151.27	1000.49	
0	5.7	590.8 N/A	0	0	79.94	150.65	1000.82	
0	6	633.4 N/A	0	0	81.23	150.49	1001.3	
0	5.9	472.6 N/A	0	0	80.04	151	1001.64	
0	5.9	567.1 N/A	0	0	80.51	150.92	1002.14	
0	6	606.4 N/A	0	0	78.98	150.08	1002.61	
0	6	490.8 N/A	0	0	79.07	149.73	1003.87	
0	6	670.4 N/A	0	0	79.94	150.36	1004.49	
0	6	756.6 N/A	0	0	80.56	150.94	1005	
0	6.1	523.8 N/A	0	0	82.5	150.76	1005.15	
0	5.9	639.9 N/A	0	0	79.51	147.55	1005.43	
0	6.1	667.8 N/A	0	0	80.85	148.15	1005.78	
0	6	478.7 N/A	0	0	80.43	148.8	1006.27	
0	6	576 N/A	0	0	80.42	148.77	1007.1	
0	6	601.9 N/A	0	0	80.02	148.95	1007.93	
0	6.1	432.2 N/A	0	0	80.63	149.4	1008.85	
0	6.1	518.3 N/A	0	0	79.86	149.23	1009.79	
0	6	554.3 N/A	0	0	80.45	149	1010.43	
0	6	416.5 N/A	0	0	81.18	149.09	1011.2	
0	6.1	517.4 N/A	0	0	80.94	148.64	1011.71	

0	6.1	547.4	N/A	0	0	82.27	149.29	1011.97
0	6.1	737.8	N/A	0	0	82.27	151.4	1011.71
0	6	573.2	N/A	0	0	80.55	149.9	1005.17

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	5.9	394	N/A	0	0	80.75	150.1	1011.86
0	6.1	486.2	N/A	0	0	80.87	149.93	1012.03
0	6	549	N/A	0	0	80.42	150.32	1012.47
0	6	403.5	N/A	0	0	81.51	150.88	1012.38
0	6.2	502.5	N/A	0	0	81.73	151.13	1012.63
0	6	553.8	N/A	0	0	80.47	150.67	1012.72
0	5.9	418.1	N/A	0	0	80.55	150.7	1012.57
0	6.2	530.3	N/A	0	0	82.56	151.59	1012.83
0	6.1	647	N/A	0	0	81	151.75	1013.76
0	5.8	615.7	N/A	0	0	79.63	151.29	1014.9
0	5.8	819.7	N/A	0	0	81.51	151.51	1014.84
0	6	774.5	N/A	0	0	82.48	152.45	1013.97
0	7.8	573.2	N/A	0	0	83.67	154.16	1012.28
0	6.3	469.2	N/A	0	0	84.88	154.93	1012.49
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	81.14	151.69	1011.29
0	6.2	421.7	N/A	0	0	83.58	150.74	1010.92
0	6.2	514.8	N/A	0	0	82.75	150.73	1009.38
0	6	466.9	N/A	0	0	81.04	150.18	1008.28
0	6	683.3	N/A	0	0	80.3	150.07	1008.05
0	6	731.1	N/A	0	0	80.48	150.16	1006.76
0	6.2	493.4	N/A	0	0	81.45	150.74	1004.91
0	6	645.7	N/A	0	0	79.76	150.38	1003.71
0	5.9	800.7	N/A	0	0	79.02	149.85	1002.68
0	6.3	800.7	N/A	0	0	83.67	154.16	1014.84
0	6.1	567.9	N/A	0	0	81.37	151.13	1010.77

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.2	639.3	N/A	0	0	80.57	149.55	1000.7
0	6.2	795.9	N/A	0	0	81.08	150.38	998.94
0	6.2	958.9	N/A	0	0	80.69	151.32	997.63
0	5.9	784.9	N/A	0	0	80.09	151.09	995.77
0	5.9	993.8	N/A	0	0	79.24	150.86	994.29
0	6	955.5	N/A	0	0	79.9	151.52	992.78
0	5.9	626.5	N/A	0	0	80.91	152.15	991.68
0	5.7	625.1	N/A	0	0	78.43	151.2	990.9

0	5.8	610.9	N/A	0	0	77.29	150.71	991.05
0	6.1	469	N/A	0	0	80.47	151.7	993.12
0	6.3	574.2	N/A	0	0	81.23	152.24	994.19
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.2	288	N/A	0	0	79.81	148.89	999.59
0	6.1	330.8	N/A	0	0	78.62	149.03	1000.92
0	5.9	496.3	N/A	0	0	78.57	148.51	1002.1
0	6	582.7	N/A	0	0	77.42	148.42	1003.37
0	6.1	426.2	N/A	0	0	79.7	149.12	1004.51
0	6.2	548.2	N/A	0	0	80.14	149.77	1004.81
0	6	612.9	N/A	0	0	79.11	149.4	1005.27
0	5.7	443.7	N/A	0	0	78.06	148.72	1005.44
0	6.1	547.7	N/A	0	0	80.39	149.36	1004.94
0	6.3	590.3	N/A	0	0	81.16	150.16	1004.61
0	6.3	958.9	N/A	0	0	81.16	152.15	1005.27
0	6	614.3	N/A	0	0	79.66	150.2	998.89

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6	457.7	N/A	0	0	81.09	149.81	1004.15
0	5.8	565.7	N/A	0	0	78.15	148.78	1003.78
0	6	610	N/A	0	0	80.84	149.45	1003.18
0	6.1	456.1	N/A	0	0	80.43	150.07	1001.93
0	6.1	588	N/A	0	0	80.56	150.68	1000.87
0	5.7	668.6	N/A	0	0	80.44	150.3	999.7
0	5.9	527	N/A	0	0	79.21	150.03	999.09
0	6	617.9	N/A	0	0	79.94	150.92	998.54
0	5.9	667.2	N/A	0	0	80.01	150.94	998.15
0	5.7	546.2	N/A	0	0	79.25	150.69	997.87
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.2	386.5	N/A	0	0	82.97	151.82	996.63
0	6	632.7	N/A	0	0	79.88	149.36	996.17
0	5.8	802	N/A	0	0	82.01	150.94	995.26
0	6.1	567.5	N/A	0	0	82.18	151.48	995
0	6.1	743.4	N/A	0	0	82.32	151.74	994.84
0	5.9	837.7	N/A	0	0	81.34	152.04	995.2
0	5.7	623.9	N/A	0	0	80.46	151.52	996.06
0	5.9	814.3	N/A	0	0	81.2	150.98	997.05
0	6	903.3	N/A	0	0	80.86	151.36	997.35
0	6	656.1	N/A	0	0	81.46	151.97	998.02
0	5.9	806.6	N/A	0	0	78.94	150.9	998.42
0	5.8	898.9	N/A	0	0	79.02	150.58	998.8
0	6.1	898.9	N/A	0	0	82.32	151.97	1003.78
0	5.9	653.5	N/A	0	0	80.57	150.74	998.46

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6	654	N/A	0	0	80.61	151.07	999.29
0	6.3	818	N/A	0	0	80.81	150.41	999.59
0	5.8	816.1	N/A	0	0	79.49	150.58	999.33
0	5.5	604.8	N/A	0	0	77.83	149.95	1000.06
0	6	749.8	N/A	0	0	79.52	150.27	1000.82
0	6.2	783.3	N/A	0	0	81.17	151.4	1002.31
0	5.8	563.4	N/A	0	0	80.07	151.68	1003.46
0	5.7	655.9	N/A	0	0	79.88	151.08	1004.52
0	6	689.3	N/A	0	0	80.12	150.96	1006.01
0	6.1	572.7	N/A	0	0	80.86	151.38	1007.67
0	6.1	788.7	N/A	0	0	81.05	151.82	1008.62
0	6	1026.9	N/A	0	0	81.84	152.42	1009.99
0	5.7	720.3	N/A	0	0	81.43	152.99	1010.72
0	6.3	790.7	N/A	0	0	85.9	154.18	1010.77
0	6.3	826.1	N/A	0	0	82.96	151.53	1011.2
0	6.3	561.1	N/A	0	0	83.89	151.53	1012.01
0	6	665.1	N/A	0	0	82.92	151.23	1012.3
0	6.2	685.2	N/A	0	0	84.21	151.95	1013
0	6.1	527.2	N/A	0	0	82.78	152.51	1014.03
0	6	623.6	N/A	0	0	81.27	151.82	1014.61
0	5.7	692.8	N/A	0	0	80.39	150.36	1014.95
0	6	520.1	N/A	0	0	80.68	150.17	1015.72
0	6.2	628.7	N/A	0	0	82.82	151.36	1016.72
0	6.1	677.9	N/A	0	0	83.12	152.32	1017.47
0	6.3	826.1	N/A	0	0	84.21	152.99	1016.72
0	6	693.4	N/A	0	0	81.48	151.46	1008.55

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.1	494	N/A	0	0	83.18	152.56	1017.74
0	6.2	621.2	N/A	0	0	84.17	151.91	1018.49
0	6.3	681.9	N/A	0	0	85.44	152.36	1019.52
0	6.1	497.3	N/A	0	0	83.15	152.45	1019.58
0	6	647.7	N/A	0	0	80.82	151.74	1020.39
0	5.9	749.5	N/A	0	0	81.86	151.37	1021.28
0	6	564.8	N/A	0	0	81.33	151.69	1021.58
0	6.2	643.3	N/A	0	0	83.48	152.39	1021.5
0	6.2	777.1	N/A	0	0	84.22	153.02	1022.22
0	5.9	659.4	N/A	0	0	84.11	154.06	1022.97
0	6	1017.5	N/A	0	0	85.14	154.29	1023.9

0	6.2	1261.9 N/A	0	0	85.46	155.31	1024.3
0	6.1	1169.4 N/A	0	0	85.67	156.01	1025.07
0	6.1	1093.2 N/A	0	0	84.32	152.74	1022.69
0	6.2	1052.3 N/A	0	0	82.14	150.38	1021.68
0	6.2	729 N/A	0	0	83.15	151.08	1020.99
0	6.1	870.1 N/A	0	0	84.13	152.15	1020.23
0	6	912.5 N/A	0	0	84.26	152.46	1020.19
0	5.9	624.3 N/A	0	0	84.18	153.14	1019.79
0	6.2	752.2 N/A	0	0	85.13	153.6	1019.66
0	6.3	815.5 N/A	0	0	83.2	153.71	1019.64
0	6	587.5 N/A	0	0	82.18	153.04	1019.07
0	5.9	722.9 N/A	0	0	81.3	152.53	1018.59
0	6.3	812.9 N/A	0	0	83.66	152.28	1018.63
0	6.3	1169.4 N/A	0	0	85.46	155.31	1024.3
0	6.1	781.6 N/A	0	0	83.57	152.76	1020.82

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.2	578.5 N/A	0	0	84.55	153.45	1018.41	
0	6.2	716.2 N/A	0	0	84.81	154.6	1017.99	
0	5.9	801.1 N/A	0	0	83.13	154.25	1017.91	
0	6	594.6 N/A	0	0	82.64	153.74	1017.63	
0	6.2	746.8 N/A	0	0	82.64	154.3	1017.45	
0	6.1	785.4 N/A	0	0	83.59	154.63	1017.6	
0	5.6	570.8 N/A	0	0	81.04	154.01	1017.76	
0	5.6	695.6 N/A	0	0	82.67	153.46	1017.99	
0	5.9	719.1 N/A	0	0	83.84	154.14	1018.36	
0	6	567.7 N/A	0	0	82.41	154.18	1019.31	
0	5.7	985.9 N/A	0	0	81.64	153.83	1021.15	
0	6.7	1336.3 N/A	0	0	71.52	149.34	1021.91	
0	8.3	1045 N/A	0	0	66.88	140.34	1022.14	
0	7.8	1120.4 N/A	0	0	72.64	141.95	1021.52	
0	7.4	1033.9 N/A	0	0	74.29	145.63	1020.33	
0	7.4	723.2 N/A	0	0	74.04	145.7	1020.21	
0	7.3	895.1 N/A	0	0	75.77	146.03	1020.2	
0	7.2	966.7 N/A	0	0	73.06	145.93	1020.29	
0	7.1	727.8 N/A	0	0	74.3	146.09	1020.57	
0	7.2	881.6 N/A	0	0	73.7	146.15	1020.31	
0	7.2	934.4 N/A	0	0	74.69	146.25	1019.92	
0	7.2	653.3 N/A	0	0	73.95	146.78	1019.33	
0	7.2	819.8 N/A	0	0	75.07	147.17	1019.21	
0	7.3	891.5 N/A	0	0	74.3	147.59	1019.16	
0	7.8	1120.4 N/A	0	0	84.55	154.6	1021.91	
0	6.7	824.6 N/A	0	0	77.8	149.56	1019.44	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	7.2	655.8	N/A	0	0	75.21	147.96	1019.05
0	7.3	838.9	N/A	0	0	76.04	147.71	1018.87
0	7.3	899.9	N/A	0	0	74.73	148.09	1017.86
0	7.1	650.8	N/A	0	0	74.57	148.43	1017.31
0	7.3	811.7	N/A	0	0	75.86	148.27	1017.01
0	7.3	885.6	N/A	0	0	75.02	148.3	1016.9
0	7.2	657.8	N/A	0	0	74.91	148.52	1017.23
0	7.1	823.3	N/A	0	0	73.79	147.42	1017.38
0	7.2	897	N/A	0	0	75.58	147.66	1017.57
0	7.2	662.1	N/A	0	0	74.41	147.52	1017.28
0	7.1	855.5	N/A	0	0	74.77	147.14	1017.6
0	7.2	994.1	N/A	0	0	73.94	146.66	1018.06
0	7.1	793.1	N/A	0	0	74.59	147.2	1018.22
0	7.1	1010.8	N/A	0	0	73.63	147.43	1018.29
0	7.1	1162.4	N/A	0	0	73.74	147.56	1018.57
0	7.1	838.7	N/A	0	0	73.86	147.72	1018.79
0	7.1	991.3	N/A	0	0	73.85	147.5	1018.55
0	7	994.4	N/A	0	0	73.05	147.57	1018.62
0	7	668.3	N/A	0	0	73.22	147.18	1018.25
0	7	789	N/A	0	0	72.25	146.78	1017.87
0	7	853.8	N/A	0	0	72.54	146.54	1017.85
0	6.9	611.9	N/A	0	0	71.85	145.67	1017.55
0	7	760.5	N/A	0	0	71.36	144.76	1017.51
0	7.1	841.8	N/A	0	0	70.05	144.76	1017.47
0	7.3	1010.8	N/A	0	0	75.86	148.43	1018.87
0	7.1	831.2	N/A	0	0	73.87	147.26	1017.9

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	7	658.6	N/A	0	0	71.73	145.32	1017.51
0	7.1	841.5	N/A	0	0	71.1	145.41	1017.31
0	7.1	920.9	N/A	0	0	72.36	145.6	1016.97
0	7.1	689.5	N/A	0	0	72.44	146.34	1017.08
0	7.1	916.7	N/A	0	0	72.17	146.16	1017.25
0	7	993.9	N/A	0	0	72.18	146.27	1016.99
0	7.1	747.8	N/A	0	0	73.17	146.89	1017.57
0	7.1	948.4	N/A	0	0	72.28	146.89	1017.74
0	7.1	1077.9	N/A	0	0	73.12	147.15	1017.92
0	7.5	765.3	N/A	0	0	68.32	146.7	1018.05
0	11.8	976.9	N/A	0	0	52.29	135.48	1018.43
0	9	1184	N/A	0	0	67.96	139.43	1018.95
0	8.9	844	N/A	0	0	61.52	143.53	1018.77
0	6.8	1124.5	N/A	0	0	77.1	146.64	1018.6

0	6.1	1263.1 N/A	0	0	78.6	150.98	1018.47
0	5.9	904.6 N/A	0	0	75.67	148.26	1018.54
0	5.9	1148.8 N/A	0	0	75.58	147.57	1018.6
0	5.9	1202.5 N/A	0	0	74.74	147.38	1018.72
0	5.8	810 N/A	0	0	75.42	147.39	1018.88
0	5.9	991.5 N/A	0	0	75.03	147.5	1019.03
0	5.8	1073 N/A	0	0	75.66	147.79	1019.32
0	5.9	754.2 N/A	0	0	74.69	147.75	1019.21
0	6	907.2 N/A	0	0	75.89	146.99	1019.34
0	5.9	957.7 N/A	0	0	75.54	147.33	1019.77
0	9	1202.5 N/A	0	0	77.1	148.26	1019.34
0	7	945.9 N/A	0	0	72.27	146.11	1018.29

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combus	tio	Live Stream Flow Nm3/	Temperatu	Static Press
0	5.9	685.5 N/A	0	0	75.1	147.46	1019.83	
0	6	857.9 N/A	0	0	75.29	147.51	1019.61	
0	6	956.5 N/A	0	0	74.61	147.68	1019.56	
0	6.1	638.1 N/A	0	0	76.12	147.93	1018.8	
0	6.1	771.3 N/A	0	0	75.08	147.94	1019.17	
0	6.2	799.5 N/A	0	0	74.86	148.09	1019.88	
0	6.1	557.2 N/A	0	0	75.59	148.4	1020.37	
0	6.1	711.5 N/A	0	0	76.91	148.47	1021.31	
0	6.1	803.8 N/A	0	0	76.1	148.61	1022.13	
0	5.9	646.9 N/A	0	0	77.3	149.91	1023.24	
0	6	837 N/A	0	0	76.92	150.04	1023.76	
0	6.1	1184.6 N/A	0	0	77.99	150.26	1025	
0	6	1234.2 N/A	0	0	79.13	148.69	1026.25	
0	5.9	1117.5 N/A	0	0	76.92	146.88	1024.44	
0	5.9	1076.5 N/A	0	0	76.43	146.67	1023.57	
0	5.8	750.6 N/A	0	0	77.56	147.25	1023.62	
0	5.7	896.3 N/A	0	0	76.49	147.77	1023.81	
0	5.9	919.8 N/A	0	0	77.51	148.51	1023.89	
0	5.9	592 N/A	0	0	77.91	149.06	1024.2	
0	5.9	706.3 N/A	0	0	77.2	149.5	1024.82	
0	6	767.5 N/A	0	0	77.19	149.3	1024.79	
0	5.8	561 N/A	0	0	77.67	150.33	1025.2	
0	5.9	708 N/A	0	0	78.1	150.14	1025.38	
0	6.2	763.7 N/A	0	0	78.39	149.83	1025.34	
0	6.2	1184.6 N/A	0	0	78.39	150.26	1025.38	
0	6	814.3 N/A	0	0	76.77	148.59	1022.83	



Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
	0	16.8	436.7 N/A		0	0	49.25	101.62	1019.22
	0	13.5	348.3 N/A		0	0	52.8	110.41	1018.71
	0	8.5	496.7 N/A		0	0	58.43	139.38	1018.24
	0	6.6	568.4 N/A		0	0	65.83	138.97	1018.22
	0	16.8	568.4 N/A		0	0	65.83	139.38	1019.22
	0	11.3	462.5 N/A		0	0	56.58	122.59	1018.6

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press	
	0	6.5	405.3 N/A		0	0	68.94	138.77	1018.37
	0	9.6	502.7 N/A		0	0	57.36	135.16	1018.06
	0	8.1	556.8 N/A		0	0	58.82	135.82	1017.78
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
Off	Off	Off	Off	Off	Off	Off	Off	Off	
	0	13.7	390 N/A		0	0	52.69	117.91	1014.36
	0	8.1	492.1 N/A		0	0	55.71	127.43	1014.73
	0	13.7	556.8 N/A		0	0	68.94	138.77	1018.37
	0	9.2	469.4 N/A		0	0	58.7	131.02	1016.66

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press	
	0	14.7	378.1 N/A		0	0	51.4	133.43	1015.26
	0	17	445.7 N/A		0	0	49.67	135.45	1015.22

0	8.7	556.5 N/A	0	0	63.47	146.89	1014.69
0	6.4	412.8 N/A	0	0	74.8	142.17	1014.52
0	6.3	490.5 N/A	0	0	82.83	147.33	1014.24
0	6.5	531.7 N/A	0	0	83.52	149.62	1014.68
0	6.3	392.8 N/A	0	0	80.94	149.69	1015.45
0	6.5	493.4 N/A	0	0	80.79	148.18	1016.41
0	6.3	579.3 N/A	0	0	81.8	148.21	1016.94
0	6.3	558.1 N/A	0	0	78.98	147.46	1017.81
0	6.4	831 N/A	0	0	79.87	147.09	1018.52
0	6.3	1126.9 N/A	0	0	79.18	147.11	1019.27
0	6.4	917.2 N/A	0	0	79.91	146.2	1019.66
0	6.3	1006.3 N/A	0	0	77.83	143.97	1018.67
0	6.3	1003.1 N/A	0	0	78.1	144.06	1018.12
0	6.1	640.8 N/A	0	0	76.53	144.23	1017.78
0	6.1	778.1 N/A	0	0	76.87	143.95	1017.67
0	6.2	854.3 N/A	0	0	77.35	144.12	1017.96
0	6.2	522.9 N/A	0	0	78.2	145.08	1017.71
0	6.3	656.6 N/A	0	0	78.09	145.38	1018.46
0	6.3	732.3 N/A	0	0	78.02	145.59	1018.66
0	6.3	507.7 N/A	0	0	78.31	146.15	1019.06
0	6.3	617.3 N/A	0	0	78.44	146.17	1019.63
0	6.4	651.5 N/A	0	0	78.14	146.07	1019.75
0	14.7	1006.3 N/A	0	0	82.83	149.62	1019.66
0	7.2	653.5 N/A	0	0	75.96	145.15	1017.34

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.4	461.4 N/A	0	0	78.53	146.07	1019.74	
0	6.5	571.9 N/A	0	0	79.59	146.07	1019.97	
0	6.4	617.2 N/A	0	0	78.12	146.22	1019.82	
0	6.4	446 N/A	0	0	77.61	146.21	1019.96	
0	6.5	556.3 N/A	0	0	77.79	146.39	1020.13	
0	6.4	580.6 N/A	0	0	77.71	146.45	1020.19	
0	6.4	419.6 N/A	0	0	77.9	146.99	1020.32	
0	6.6	530.4 N/A	0	0	78.18	146.45	1021.34	
0	6.5	620.2 N/A	0	0	79.39	147.11	1021.93	
0	6.4	541.7 N/A	0	0	77.47	147.09	1023.16	
0	6.4	782.1 N/A	0	0	77.79	146.8	1024.09	
0	6.4	1029.2 N/A	0	0	77.09	146.73	1024.82	
0	6.3	844.5 N/A	0	0	79.35	146.41	1025.16	
0	6.3	836 N/A	0	0	76.25	143.69	1023.91	
0	6.4	835.2 N/A	0	0	76.47	143.47	1023.43	
0	6.2	655.5 N/A	0	0	76.54	144.05	1023.4	
0	6.3	810.7 N/A	0	0	75.97	144.11	1023.67	
0	6.3	853.8 N/A	0	0	76.47	144.18	1023.99	
0	6.3	513.7 N/A	0	0	77.11	145.07	1023.84	
0	6.4	604.4 N/A	0	0	77.49	145.38	1024.12	

0	6.3	644.2 N/A	0	0	77.26	146.04	1024.34
0	6.4	478.3 N/A	0	0	78.54	146.68	1024.88
0	6.3	601.8 N/A	0	0	78.01	146.52	1025.44
0	6.5	616.9 N/A	0	0	78.14	146.87	1025.49
0	6.5	853.8 N/A	0	0	79.39	147.09	1025.44
0	6.4	643.8 N/A	0	0	77.7	145.88	1022.8

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.3	431.4 N/A	0	0	78.02	146.58	1025.73	
0	6.5	503.2 N/A	0	0	76.99	146.1	1025.67	
0	6.5	502.7 N/A	0	0	76.32	145.78	1025.16	
0	6.5	364 N/A	0	0	76.58	145.65	1025.08	
0	6.6	469.7 N/A	0	0	77.38	145.74	1025.35	
0	6.4	525.2 N/A	0	0	76.55	146.11	1025.51	
0	6.5	368.3 N/A	0	0	76.64	146.33	1025.43	
0	6.5	442.7 N/A	0	0	76.33	146.03	1025.49	
0	6.5	541.5 N/A	0	0	76.42	146.04	1026.15	
0	6.4	461.5 N/A	0	0	76.1	145.73	1027.01	
0	6.4	653.2 N/A	0	0	76.41	145.57	1027.59	
0	6.4	834.6 N/A	0	0	77.32	146.09	1028.29	
0	6.3	679.8 N/A	0	0	76.8	146.31	1028.85	
0	6.3	659.5 N/A	0	0	76.83	144.08	1027.84	
0	6.4	717.2 N/A	0	0	75.97	142.88	1027.27	
0	6.4	513.4 N/A	0	0	77.54	144.02	1027.12	
0	6.4	593.1 N/A	0	0	77.65	144.58	1026.6	
0	6.5	643 N/A	0	0	78.32	144.91	1026.77	
0	6.4	396.1 N/A	0	0	76.83	145.17	1026.47	
0	6.4	483.3 N/A	0	0	77.32	145.25	1026.29	
0	6.5	509.2 N/A	0	0	78.38	145.67	1026.03	
0	6.4	368.9 N/A	0	0	77.44	145.77	1025.73	
0	6.5	450.7 N/A	0	0	78.45	145.81	1025.66	
0	6.5	491.9 N/A	0	0	77.66	145.81	1025.85	
0	6.5	717.2 N/A	0	0	78.38	146.33	1028.29	
0	6.4	525.2 N/A	0	0	77.09	145.5	1026.37	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.4	354.2 N/A	0	0	76.16	145.53	1025.18	
0	6.5	433.1 N/A	0	0	76.74	145.58	1025.28	
0	6.4	475.2 N/A	0	0	75.95	145.24	1025.08	
0	6.3	346.2 N/A	0	0	75.56	145.2	1024.53	
0	6.5	415.3 N/A	0	0	76.47	145.54	1024	

0	6.5	463.5	N/A	0	0	76.26	145.88	1023.8
0	6.4	337	N/A	0	0	75.97	145.69	1023.14
0	6.5	439.2	N/A	0	0	76.93	146.31	1022.52
0	6.4	524.1	N/A	0	0	76.69	146.64	1022.9
0	6.3	409.2	N/A	0	0	76.78	146.56	1022.66
0	6.3	561.8	N/A	0	0	75.22	146.46	1022.27
0	6.5	628.3	N/A	0	0	75.66	146.65	1021.7
0	6.2	625.3	N/A	0	0	76.85	147.91	1021.71
0	6.5	728.7	N/A	0	0	78.14	148.14	1020.72
0	6.4	731.4	N/A	0	0	79.59	146.17	1019.66
0	6.4	480	N/A	0	0	79.55	145.96	1018.99
0	6.4	578.1	N/A	0	0	79.17	145.8	1018.56
0	6.4	535.6	N/A	0	0	77.18	145.3	1017.75
0	6.4	357	N/A	0	0	77.16	144.63	1017.32
0	6.4	430.7	N/A	0	0	76.47	144.23	1017.07
0	6.5	456.4	N/A	0	0	76.05	143.91	1016.88
0	6.4	329.2	N/A	0	0	75.77	143.89	1016.84
0	6.4	394.3	N/A	0	0	76.02	144.18	1016.43
0	6.5	417.9	N/A	0	0	75.34	144.15	1015.71
0	6.5	728.7	N/A	0	0	79.55	147.91	1025.18
0	6.4	477.2	N/A	0	0	76.74	145.65	1020.86

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.4	303.9	N/A	0	0	75.42	144.31	1015.04
0	6.5	373.7	N/A	0	0	75.79	144.42	1014.3
0	6.4	406.6	N/A	0	0	75.35	144.84	1013.63
0	6.4	294.4	N/A	0	0	75.2	145.19	1012.86
0	6.5	372.8	N/A	0	0	75.43	144.97	1012.27
0	6.6	410.4	N/A	0	0	75.1	145.2	1011.85
0	6.3	303.3	N/A	0	0	75.23	145.12	1011.38
0	6.6	379.3	N/A	0	0	75.33	145.27	1010.92
0	6.5	423.1	N/A	0	0	75.52	145.3	1010.77
0	6.3	356.1	N/A	0	0	74.43	145.44	1011.53
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.3	113	N/A	0	0	77.91	145.96	1010.43
0	6.6	254.3	N/A	0	0	78.59	146.35	1009.98
0	6.4	238.8	N/A	0	0	79.54	147.13	1008.92
0	6.5	323.7	N/A	0	0	79.14	147.38	1008.24
0	6.6	365.5	N/A	0	0	77.86	147.05	1007.77
0	6.5	250.7	N/A	0	0	75.4	145.76	1007.46
0	6.6	310.7	N/A	0	0	76.68	145.58	1007.16
0	6.5	329	N/A	0	0	77.08	145.49	1006.89
0	6.6	236.7	N/A	0	0	76.37	145.27	1005.73
0	6.6	289.3	N/A	0	0	75.32	145.2	1005

0	6.5	321.4 N/A	0	0	75.02	145.2	1004.49
0	6.6	410.4 N/A	0	0	79.14	147.13	1014.3
0	6.5	317 N/A	0	0	76.27	145.54	1009.84

Velocity m/s

18.54  
18.46  
18.62  
18.93  
18.38  
18.74  
18.65  
18.65  
18.87  
19.21  
18.7  
18.24  
18.2  
18.14  
17.72  
17.69  
17.63  
17.58  
17.29  
17.28  
17.16  
17.29  
17.24  
17.6  
18.93  
18.12

Velocity m/s

17.36  
17.32  
17.15  
17.14  
17.64  
17.53  
17.39  
17.75  
17.67  
17.71  
17.49  
17.97  
18.47  
18.28

18.14  
17.94  
17.45  
17.34  
17.39  
17.33  
17.21  
16.73  
17.49  
16.83  
18.28  
17.53

Velocity m/s

17.21  
17.16  
17.18  
17.34  
17  
17.08  
17.11  
17.18  
17.58  
17.96  
18.45  
18.14  
18.72  
17.94  
18.35  
18.42  
18.24  
17.68  
18.03  
18.03  
18.23  
18.26  
18.27  
17.8  
18.45  
17.81

Velocity m/s

17.75  
17.85  
17.9  
17.82  
17.48  
17.47  
17.37  
17.58  
17.62  
17.86  
17.77  
17.25  
17.53  
17.99  
17.54  
17.52  
17.14  
17.22  
17.3  
17.36  
17.53  
17.37  
17.61  
17.47  
17.9  
17.55

Velocity m/s

17.7  
17.36  
17.4  
17.29  
17.14  
17.44  
17.79  
17.6  
17.72  
17.28  
17.05  
17.36  
17.44  
17.7  
17.62  
17.1  
17.21

17.51  
17.42  
17.35  
17  
16.86  
16.87  
17.37  
17.72  
17.36

Velocity m/s

18.03  
18.03  
17.77  
17.49  
17.43  
17.69  
17.95  
17.7  
17.48  
17.34  
17.15  
17.43  
17.57  
16.93  
17.09  
17  
17.44  
17.43  
17.72  
17.43  
17.1  
16.92

Off

10.48  
18.03  
17.16

Velocity m/s

Off

Off

Off  
Off  
Off  
Off  
Off  
Off  
Off

11.54  
11.85  
11.17  
10.8  
10.51  
12.78  
17.26  
17.02  
17.19  
17.12  
17.14  
16.94  
17.07

N/A

17.09  
17.26  
14.68

Velocity m/s

17.4  
17.24  
17.03  
16.65  
17.07  
17.22  
16.81  
16.73  
17.06  
17.23  
17.28  
17.36  
17.57  
17.79  
17.61  
17.48  
17.47  
17.63  
17.75  
17.35

17.22  
17.69  
17.57  
17.38  
17.75  
17.32

Velocity m/s

17.1  
17.06  
17.08  
17.29  
17.12  
17.03  
17.29  
17.28  
17.32  
16.94  
17.26  
17.16  
17.58  
17.21  
17.38  
17.39  
17.63  
17.32  
17  
17.31  
17.03  
16.41  
16.56  
16.7  
17.58  
17.14

Velocity m/s

16.77  
16.54  
16.5  
16.67  
16.76

16.9  
17.01  
17.1  
17.17  
17.08  
17.09  
17.2  
17.1  
17.46  
17  
17.04  
17.34  
17.44  
17.12  
17.46  
17.55  
17.77  
18.08  
17.83  
17.83  
17.17

Velocity m/s

17.45  
17.74  
17.79  
17.47  
17.35  
17.61  
17.37  
17.46  
17.09  
17.07  
17.27  
17.42  
17.83  
17.05  
17.36  
17.28  
17.27  
17.17  
17.31  
17.12  
17.22  
17.37  
17.29

17.6  
17.79  
17.37

Velocity m/s

17.31  
17.32  
17.24  
17.49  
17.55  
17.26  
17.28  
17.74  
17.4  
17.07  
17.48  
17.74  
18.1  
18.39

N/A

17.47  
17.96  
17.81  
17.44  
17.28  
17.34  
17.61  
17.25  
17.08  
18.1  
17.5

Velocity m/s

17.44  
17.62  
17.59  
17.49  
17.32  
17.51  
17.78  
17.21

16.94  
17.64  
17.81

N/A

N/A

N/A

17.27  
16.99  
16.94  
16.67  
17.17  
17.29  
17.04  
16.78  
17.32  
17.53  
17.78  
17.3

Velocity m/s

17.5  
16.83  
17.45  
17.41  
17.48  
17.46  
17.19  
17.4  
17.42  
17.25

N/A

N/A

18.13  
17.36  
17.91  
17.97  
18.02  
17.81  
17.58  
17.7  
17.64  
17.78  
17.18  
17.18  
18.02  
17.53

Velocity m/s

17.54  
17.55  
17.27  
16.87  
17.24  
17.62  
17.37  
17.29  
17.31  
17.46  
17.5  
17.67  
17.59  
18.61  
17.86  
18.04  
17.81  
18.11  
17.81  
17.44  
17.19  
17.23  
17.72  
17.81  
18.11  
17.58

Velocity m/s

17.83  
18  
18.27  
17.79  
17.25  
17.44  
17.33  
17.82  
17.99  
18  
18.21

18.32  
18.38  
18  
17.45  
17.71  
17.97  
18.01  
18.03  
18.26  
17.85  
17.61  
17.41  
17.91  
18.32  
17.87

Velocity m/s

18.15  
18.26  
17.89  
17.77  
17.79  
18.01  
17.43  
17.75  
18.03  
17.71  
17.49  
15.16  
13.86  
15.13  
15.63  
15.58  
15.96  
15.38  
15.64  
15.52  
15.74  
15.61  
15.86  
15.72  
18.15  
16.54

Velocity m/s

15.93  
16.1  
15.85  
15.84  
16.11  
15.93  
15.91  
15.63  
16.02  
15.77  
15.83  
15.63  
15.78  
15.59  
15.61  
15.64  
15.63  
15.46  
15.49  
15.28  
15.33  
15.15  
15.02  
14.74  
16.1  
15.64

Velocity m/s

15.12  
14.99  
15.27  
15.31  
15.25  
15.26  
15.48  
15.29  
15.47  
14.44  
10.75  
14.11  
12.9  
16.29

16.77  
16.04  
16  
15.81  
15.95  
15.87  
16.01  
15.81  
16.03  
15.96  
16.29  
15.26

Velocity m/s

15.87  
15.92  
15.78  
16.12  
15.9  
15.85  
16  
16.27  
16.09  
16.38  
16.29  
16.51  
16.67  
16.16  
16.07  
16.32  
16.12  
16.36  
16.46  
16.32  
16.31  
16.44  
16.52  
16.57  
16.57  
16.22

Velocity m/s

17.15

17.11

11.38

11.86

10.38

Off

Off

Off

Off

Off

9.89

13.87

15.65

14.6

12.54

11.41

12.14

11.34

11.1

Off

Off

Off

Off

Off

17.15

12.89

Velocity m/s

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off

Off  
Off  
Off

9.29  
10.19  
12.14  
13.65  
13.65  
11.32

Velocity m/s

14.29  
11.79  
12.12

Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off

10.41  
11.27  
14.29  
11.97

Velocity m/s

10.55  
10.25

13.46  
15.69  
17.6  
17.83  
17.27  
17.16  
17.37  
16.73  
16.89  
16.73  
16.84  
16.33  
16.4  
16.08  
16.15  
16.25  
16.47  
16.45  
16.44  
16.51  
16.53  
16.46  
17.6  
16.02

Velocity m/s

16.54  
16.76  
16.46  
16.35  
16.4  
16.38  
16.44  
16.46  
16.73  
16.31  
16.35  
16.19  
16.64  
15.91  
15.95  
15.99  
15.87  
15.97  
16.14  
16.23

16.2  
16.49  
16.36  
16.4  
16.73  
16.31

Velocity m/s

16.36  
16.13  
15.98  
16.03  
16.2  
16.04  
16.07  
15.99  
16  
15.91  
15.96  
16.16  
16.05  
15.98  
15.77  
16.14  
16.19  
16.34  
16.05  
16.15  
16.4  
16.21  
16.42  
16.25  
16.4  
16.12

Velocity m/s

15.94  
16.06  
15.88  
15.81  
16.02

16  
15.94  
16.17  
16.13  
16.15  
15.82  
15.93  
16.23  
16.53  
16.77  
16.77  
16.69  
16.26  
16.24  
16.08  
15.98  
15.92  
16  
15.86  
16.77  
16.13

Velocity m/s

15.9  
15.99  
15.92  
15.92  
15.97  
15.91  
15.94  
15.98  
16.02  
15.78  
N/A  
N/A  
N/A  
16.56  
16.73  
16.98  
16.92  
16.64  
16.07  
16.34  
16.42  
16.28  
16.07

16.01

16.92

16.21

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	153.65	-0.2	234.89	73.46	13.1	1.87	-5.25	6.78
01:00 to C	158.48	9.06	251.53	77.38	13	1.99	-1.79	6.81
02:00 to C	153.9	0.91	236.38	75.94	13.06	1.91	-2.96	6.78
03:00 to C	155.48	11.43	249.31	66.5	13.04	1.89	-3.78	6.76
04:00 to C	163.67	-2.27	248.14	74.31	13	1.95	-2.83	6.75
05:00 to C	161.75	-2.48	244.99	72.62	12.99	1.94	-2.65	6.78
06:00 to C	159.01	-2.82	240.47	82.82	13	1.94	-3.24	6.71
07:00 to C	152.91	-2.23	231.73	89.49	13.04	1.93	-2.51	6.7
08:00 to C	159.44	4.53	248.48	96.95	13.03	1.99	-2.39	6.73
09:00 to C	148.57	1.5	228.81	104.24	13.15	1.84	-4.79	6.71
10:00 to 1	150.68	4.6	235.13	98.64	13.04	1.89	-2.06	6.68
11:00 to 1	152.05	5.75	238.38	91.99	13.07	1.9	-2.17	6.7
12:00 to 1	133.98	4.72	209.71	91	13.05	3.61	-4.8	6.84
13:00 to 1	145.22	3.04	225.23	117.27	13.05	1.95	-1.82	6.69
14:00 to 1	154.99	3.6	240.72	76.39	13.13	1.87	-2.27	6.66
15:00 to 1	155.41	6.04	243.82	90.46	13.02	1.86	-3.86	6.73
16:00 to 1	149.31	-1.5	226.94	97.28	13.11	1.85	-2.96	6.66
17:00 to 1	156.21	-5.44	233.57	73.82	13.04	1.89	-2.14	6.7
18:00 to 1	157.6	-1.54	239.58	83.82	13.02	1.87	-3.47	6.66
19:00 to 1	159.96	-4.06	240.68	78.46	12.99	1.94	-1.54	6.68
20:00 to 2	157.67	-10.04	231.19	82.84	12.96	1.96	-1.39	6.71
21:00 to 2	160.09	-1.8	243.13	76.26	13.04	1.93	-3.29	6.64
22:00 to 2	166.78	-6.39	248.78	81.33	12.91	2	-2.14	6.75
23:00 to 2	157.2	16.96	257.48	81.5	13.2	1.87	-2.35	6.59
95 Percent	163.67	11.43	251.53	104.24	13.15	2	-1.54	6.81
Daily Avera	155.17	1.31	238.71	84.78	13.04	1.98	-2.85	6.72

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	162.38	-8.97	239.47	67.27	13.01	1.8	-3.98	6.69
01:00 to C	162.51	-12.84	235.8	81.45	13.03	1.84	-2.07	6.59
02:00 to C	161.41	-8.12	238.85	84.11	13.02	1.86	-1.76	6.66
03:00 to C	153.11	2.72	236.97	87.94	13.06	1.78	-3.86	6.67
04:00 to C	156.95	0.38	240.51	96.31	13.06	1.84	-2.03	6.63
05:00 to C	160.45	6.17	251.66	108.63	13.05	1.86	-2.55	6.71
06:00 to C	147.29	-16.03	209.32	115.56	13.05	1.8	-2.97	6.56
07:00 to C	149.58	-12.06	216.79	97.86	13.01	1.85	-2.48	6.67
08:00 to C	153.39	-5.47	229.21	96.72	13.05	1.84	-1.78	6.63
09:00 to C	145.95	7.7	231	99.3	13.05	1.78	0.05	6.43
10:00 to 1	149.26	8.16	236.54	91.94	12.99	1.77	2.18	6.43
11:00 to 1	154.59	4.15	240.66	99.37	13.06	1.82	1.88	6.43
12:00 to 1	153.18	-15.54	218.83	101.17	12.9	1.96	1.04	6.43
13:00 to 1	137.69	-8.69	201.97	105.04	12.93	3.56	2.21	6.52

14:00 to 1	150.68	-15.59	214.95	82.23	13	1.74	-2.75	6.78
15:00 to 1	153.36	-5.85	228.78	104.79	13.01	1.66	-3.81	6.68
16:00 to 1	150.95	0.13	231.08	100.91	13.04	1.7	-3.26	6.75
17:00 to 1	153.86	-6.66	228.74	95.89	13.03	1.7	-2.98	6.73
18:00 to 1	154.75	-3.57	233.2	99.92	13.03	1.64	-3.98	6.7
19:00 to 1	165.71	-6.09	247.44	87.77	13.04	1.66	-3.27	6.74
20:00 to 2	154.44	2.56	238.85	110.79	13.17	1.67	-1.18	6.6
21:00 to 2	160.17	-7.61	237.45	75.29	13.04	1.65	-4.67	6.71
22:00 to 2	167.49	-10.45	245.82	74.38	13.01	1.7	-1.97	6.66
23:00 to 2	158.54	-3.92	238.65	90	13.05	1.67	-3.01	6.72
95 Percent	165.71	7.7	247.44	110.79	13.06	1.96	2.18	6.75
Daily Avera	154.9	-4.81	232.19	93.94	13.03	1.84	-1.96	6.63

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	155.63	1.54	239.65	75.08	12.98	1.61	-4.01	6.71
01:00 to 0	156.18	-1.1	237.85	103.96	13.06	1.64	-3.17	6.68
02:00 to 0	152.95	9.92	243.93	112.3	13.08	1.65	-2.49	6.66
03:00 to 0	148.07	0.33	226.88	134.75	12.98	1.59	-3.52	6.64
04:00 to 0	148.47	9.47	236.63	124.83	13.16	1.54	-2.44	6.59
05:00 to 0	153.22	8.95	243.38	101.37	13.15	1.55	-1.51	6.61
06:00 to 0	143.73	-16.66	203.24	95.14	13.01	1.45	-4.76	6.68
07:00 to 0	154.5	-29.86	206.53	79.73	12.93	1.52	-2.47	6.71
08:00 to 0	139.34	-14.48	198.72	96.35	12.93	1.47	-2.2	6.78
09:00 to 0	137.14	2.01	211.83	88.99	12.82	1.46	-3.64	6.93
10:00 to 1	133.48	6.59	210.81	102.62	12.92	1.39	-3	6.84
11:00 to 1	141.91	4.3	221.42	95.39	12.89	1.44	-2.48	6.87
12:00 to 1	131.21	-5.68	195.07	113.26	12.76	3.18	-3.81	7.02
13:00 to 1	138.78	-15.88	196.45	93.55	12.91	1.27	-4.65	6.85
14:00 to 1	149.21	-9.48	218.81	76.84	12.82	1.32	-3.67	6.91
15:00 to 1	136.47	-3.18	205.62	97.7	13.02	1.31	-4.77	6.74
16:00 to 1	144.88	-0.02	221.65	103.19	12.85	1.43	-2.89	6.85
17:00 to 1	142.83	11.42	229.96	97.83	12.92	1.4	-3.14	6.86
18:00 to 1	140.81	-16.68	198.77	124.49	12.96	1.48	-4.75	6.74
19:00 to 1	150.93	-15.45	215.47	104.89	13	1.51	-4.44	6.77
20:00 to 2	147.64	-9.74	216.15	130.14	13.02	1.45	-2.8	6.71
21:00 to 2	151.71	5.91	238.02	100.78	13.02	1.39	-4.69	6.77
22:00 to 2	147.09	2.21	227.26	127.08	13.14	1.44	-3.94	6.65
23:00 to 2	149.1	-1.5	226.63	102.44	13.03	1.51	-2.73	6.72
95 Percent	155.63	9.92	243.38	130.14	13.15	1.65	-2.2	6.93
Daily Avera	145.64	-3.21	219.61	103.45	12.97	1.54	-3.41	6.76

CDAS 2004  
Report prir



17:00 to 1	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	Off	Off	Off	Off	Off	Off	Off
21:00 to 2	Off	Off	Off	Off	Off	Off	Off
22:00 to 2	Off	Off	Off	Off	Off	Off	Off
23:00 to 2	Off	Off	Off	Off	Off	Off	Off
95 Percent	Off	Off	Off	Off	Off	Off	Off
Daily Average	Off	Off	Off	Off	Off	Off	Off

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
01:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
02:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
10:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
11:00 to 1	94.61	-35.19	109.56	39.94	3.4	11.44	-20.74	19.65
12:00 to 1	97.03	158.53	306.99	819.09	2.61	21.22	-0.26	17.55
13:00 to 1	118.01	15.38	195.94	5.6	4.31	6.53	-14.13	16.94
14:00 to 1	120.88	-38.24	146.71	-0.84	5.56	4.12	-16.37	14.93
15:00 to 1	132.47	21.24	223.92	54.3	6.63	10.29	-10.38	13.61
16:00 to 1	164.69	20.56	272.54	37.91	10.9	1.16	-13.53	10.11
17:00 to 1	184.36	-11.36	270.71	38.87	10.16	1.25	-1.68	9.94
18:00 to 1	174.35	0.52	267.27	34.97	10.45	1.26	-9.18	10.25
19:00 to 1	168.98	2.21	260.75	31.04	10.65	1.28	-7.45	9.89
20:00 to 2	165.71	7.72	261.26	29	10.8	1.3	-8.19	9.81
21:00 to 2	163.24	16.74	266.5	32.4	10.72	1.36	-7.86	9.84
22:00 to 2	163.22	12.61	262.34	33.61	10.78	1.32	-8.26	9.84
23:00 to 2	167.93	20.4	277.33	74.27	11.47	2.13	-6.79	8.93
95 Percent	184.36	158.53	306.99	819.09	11.47	21.22	-0.26	19.65
Daily Average	147.35	14.7	240.14	94.63	8.34	4.97	-9.6	12.41

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	157.73	18.47	259.8	74.31	12.38	1.52	-6.05	7.77
01:00 to 0	142.61	25.15	243.34	64.01	13.03	1.35	-6.51	7.04

02:00 to C	143.55	13.33	232.96	56.46	13.33	1.26	-7.5	6.71
03:00 to C	138.52	5.32	217.25	66.96	13.27	1.27	-7.37	6.61
04:00 to C	137.22	2.31	212.25	56.82	13.43	1.26	-5.96	6.41
05:00 to C	132.59	10.66	213.52	65.99	13.61	1.24	-7.15	6.31
06:00 to C	134.5	-22.58	183.21	60.62	13.42	1.31	-7.58	6.37
07:00 to C	134.92	-16.86	189.57	63.43	13.39	1.28	-5.59	6.33
08:00 to C	131.7	3.47	204.97	65.14	13.56	1.22	-7.54	6.37
09:00 to C	133.95	-15.9	189.03	60.11	13.52	0.94	-9.4	6.44
10:00 to 1	132.83	-33.64	169.59	62.7	13.39	0.82	-6.55	6.48
11:00 to 1	134.33	-11.3	194.23	57.35	13.59	0.93	-8.05	6.44
12:00 to 1	134.27	4.35	209.78	65.54	13.58	1.03	-8.23	6.42
13:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.66
14:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.59
15:00 to 1	133.62	-4.37	200.07	69.67	13.51	1.06	-6.07	6.36
16:00 to 1	135.37	-13.57	193.54	63.5	13.5	1.03	-4.94	6.28
17:00 to 1	139.29	-28.48	184.63	71.8	13.3	1.29	-4.45	6.43
18:00 to 1	132.45	4.63	207.28	58.8	13.41	1.35	-6.15	6.52
19:00 to 1	138.58	5.62	217.65	61.72	13.44	1.3	-5.14	6.43
20:00 to 2	133.77	26.85	231.52	70.78	13.55	1.28	-2.23	6.24
21:00 to 2	139.71	-15.05	198.7	59.43	13.36	1.3	-7.63	6.54
22:00 to 2	137.52	-4.72	205.68	63.95	13.47	1.31	-6.73	6.42
23:00 to 2	136.71	1.45	210.62	64.14	13.46	1.3	-5.61	6.41
95 Percent	143.55	25.15	243.34	71.8	13.59	1.35	-4.45	7.04
Daily Avera	137.08	-2.04	207.69	63.78	13.39	1.21	-6.47	6.52

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	136.15	-3.64	204.67	66.54	13.38	1.26	-7.31	6.52
01:00 to C	137.1	-1.08	208.69	62.82	13.39	1.33	-6.01	6.46
02:00 to C	140.55	2.69	217.73	64.2	13.33	1.36	-4.94	6.47
03:00 to C	136.5	-10.17	198.67	70.67	13.35	1.33	-6.02	6.42
04:00 to C	141.13	-23.65	192.27	59.16	13.29	1.34	-6.52	6.51
05:00 to C	141.8	-21.16	195.79	60.04	13.36	1.34	-5.4	6.45
06:00 to C	137.27	-12.47	197.56	62.87	13.32	1.34	-6.27	6.47
07:00 to C	136.12	-8.54	199.72	69.59	13.38	1.36	-4.86	6.55
08:00 to C	138.3	-6.99	204.6	63.23	13.45	1.34	-5.03	6.5
09:00 to C	137.88	9.98	220.93	64.75	13.45	1.04	-6.13	6.47
10:00 to 1	136.01	8.24	216.34	65.22	13.41	1.05	-5.39	6.48
11:00 to 1	136.96	0.42	209.97	59.11	13.48	0.97	-6.41	6.47
12:00 to 1	142.61	-2.95	215.25	58.1	13.53	1.02	-6.7	6.37
13:00 to 1	143.15	-12.27	206.75	58.29	13.3	1.15	-5.47	6.47
14:00 to 1	134.52	-4.92	200.9	57.12	13.22	2.55	-5.45	6.59
15:00 to 1	135.18	19.89	226.72	54.81	13.49	1.08	-5.21	6.44
16:00 to 1	142.81	-4.94	213.55	59.03	13.39	1.17	-4.68	6.39
17:00 to 1	137.01	-3.37	206.26	70.73	13.41	1.22	-3.33	6.31
18:00 to 1	139.01	-18.3	194.38	53.08	13.43	1.25	-3.76	6.33
19:00 to 1	139.89	1.84	215.87	58.69	13.49	1.25	-2.69	6.31

20:00 to 2	140.64	3.78	218.95	68.43	13.51	1.25	-3.04	6.33
21:00 to 2	147.93	-16.6	209.73	58.25	13.39	1.2	-5.29	6.37
22:00 to 2	150.28	-8.64	221.29	68.45	13.41	1.24	-3.91	6.29
23:00 to 2	154.59	-10.19	226.33	63.16	13.42	1.23	-2.32	6.19
95 Percent	150.28	9.98	226.33	70.67	13.51	1.36	-2.69	6.55
Daily Avera	140.14	-5.13	209.29	62.35	13.4	1.28	-5.09	6.42

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	150.45	5.23	235.42	65.41	13.41	1.24	-3.56	6.27
01:00 to 0	155	3.56	240.71	74.49	13.12	1.4	2.14	6.18
02:00 to 0	181.1	-0.84	276.24	34.38	10.03	1.72	11.2	8.79
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
10:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
11:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
12:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
13:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
14:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
15:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
16:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
17:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	110.09	-15.36	153.07	150.84	4.26	23.47	-39.3	20.31
20:00 to 2	151.74	-7.95	224.21	158.33	6.14	2.34	-17.46	15.68
21:00 to 2	160.58	-10.86	234.83	28.76	12.09	1.05	-27.46	10.07
22:00 to 2	150.74	-9.48	221.15	38.72	12.77	1	-8.64	7.31
23:00 to 2	146.61	-8.58	215.73	62.77	13.34	1.12	-10.25	6.74
95 Percent	181.1	5.23	276.24	158.33	13.41	23.47	11.2	20.31
Daily Avera	150.79	-5.53	225.17	76.71	10.64	4.17	-11.67	10.17

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	152.85	-0.33	233.53	66.04	13.48	1.12	-8.56	6.41
01:00 to 0	151	12.93	243.96	95.21	13.54	1.12	-6.17	6.34
02:00 to 0	159.05	10.62	253.96	75.82	13.52	1.08	-6.42	6.37
03:00 to 0	158.95	-7.17	236.02	63.16	13.43	1.05	-6.89	6.37
04:00 to 0	153.45	-10.32	224.46	84.95	13.5	1.04	-6.82	6.32

05:00 to 0	153.32	-8.87	225.72	117.95	13.59	0.97	-6.88	6.24
06:00 to 0	155.6	-12.98	225.09	68.26	13.54	0.97	-8.11	6.31
07:00 to 0	155.74	-21.67	216.6	67.55	13.53	0.94	-8.06	6.35
08:00 to 0	151.97	-17.37	215.14	103.26	13.56	0.98	-6.92	6.31
09:00 to 0	147.06	-0.93	224.07	89.15	13.58	0.98	-8.24	6.32
10:00 to 1	150.16	0.67	230.41	79.53	13.52	1.01	-6.14	6.35
11:00 to 1	140.59	4.95	220.05	130.83	13.66	0.94	-7.82	6.28
12:00 to 1	133.45	-19.47	184.71	119.79	13.33	2.66	-6.02	6.4
13:00 to 1	142.9	-22.35	196.29	73.73	13.39	1.14	-4.09	6.26
14:00 to 1	143.38	8.93	228.3	80.2	13.64	0.97	-2.67	6.09
15:00 to 1	145.43	-9.7	212.8	99.55	13.43	1.01	-4.59	6.23
16:00 to 1	146.92	-16.8	208	79.88	13.52	1.01	-5.11	6.18
17:00 to 1	149.14	-17.99	210.19	71.5	13.37	1.03	-4.54	6.33
18:00 to 1	139.95	4.77	218.89	123.03	13.6	1.06	-5.36	6.16
19:00 to 1	145	2.71	224.55	111.01	13.54	1.11	-2.18	6.09
20:00 to 2	146.38	-3.6	220.36	76.84	13.53	1.07	-4.26	6.22
21:00 to 2	139.23	-4.15	208.87	119.32	13.54	1.08	-4.47	6.15
22:00 to 2	136.06	17.3	225.46	184.86	13.66	1.1	-4.33	6.14
23:00 to 2	142.23	6.92	224.52	98.51	13.64	1.09	-4.12	6.12
95 Percent	158.95	12.93	243.96	130.83	13.66	1.14	-2.67	6.4
Daily Average	147.49	-4.33	221.33	95	13.53	1.11	-5.78	6.26

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	143.66	-4.99	214.81	85.12	13.47	1.1	-4.94	6.22
01:00 to 0	143.34	-2.82	216.49	115.31	13.53	1.11	-4.19	6.16
02:00 to 0	145.8	-12.28	210.8	116.82	13.51	1.15	-4.61	6.17
03:00 to 0	147.48	2.62	228.27	81.39	13.54	1.12	-5.93	6.26
04:00 to 0	146.89	2.44	227.18	96.64	13.49	1.14	-4.53	6.26
05:00 to 0	146.78	-0.8	223.78	134.03	13.54	1.17	-5.08	6.21
06:00 to 0	149.91	-2.95	226.4	89.23	13.56	1.11	-5.62	6.17
07:00 to 0	150.29	7.89	237.82	92.58	13.53	1.12	-4.22	6.26
08:00 to 0	143.92	4.24	224.44	143.76	13.62	1.09	-4.66	6.17
09:00 to 0	149.1	-25.58	202.54	107.2	13.48	1.06	-5.5	6.17
10:00 to 1	147.57	-8.5	217.28	98.8	13.57	0.92	-4.75	6.16
11:00 to 1	138.71	1.15	213.38	137.36	13.43	1.73	-3.45	6.3
12:00 to 1	139.56	-1.89	211.64	141.4	13.67	1.46	-5.63	6.13
13:00 to 1	143.96	1.01	221.27	123.01	13.6	1.03	-4.18	6.08
14:00 to 1	146.24	-1	222.74	113.3	13.59	0.96	-3.8	6.08
15:00 to 1	138.48	-26.35	185.52	212.04	13.41	1.08	-3.97	6.09
16:00 to 1	147.65	-21.56	204.33	130.98	13.51	1.13	-5.3	6.15
17:00 to 1	146.76	-1.48	223.06	108.03	13.56	1.06	-2.88	6.08
18:00 to 1	133.69	-17.06	187.48	230.11	13.55	1.06	-6.1	6.14
19:00 to 1	137.86	-21.95	188.98	234.91	13.5	1.07	-4.19	6.07
20:00 to 2	143.52	-17.03	202.55	126.25	13.44	1.06	-3.66	6.13
21:00 to 2	141.01	-12.21	203.53	123.97	13.5	1.06	-5.27	6.16
22:00 to 2	141.45	-17.54	198.89	153.02	13.42	1.12	-3.97	6.14

23:00 to 2	153.24	-22.99	211.47	98.78	13.44	1.13	-5.29	6.17
95 Percent	150.29	4.24	228.27	230.11	13.62	1.46	-3.45	6.26
Daily Avera	144.45	-8.32	212.69	128.92	13.52	1.13	-4.66	6.16

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	150.12	-13.58	216.11	86.8	13.42	1.14	-4.46	6.22
01:00 to 0	151.33	0.29	231.83	89.87	13.51	1.17	-4.93	6.28
02:00 to 0	152.04	-1.11	231.51	106.53	13.62	1.15	-4.68	6.15
03:00 to 0	149.55	-5	223.82	81.7	13.51	1.13	-5.5	6.2
04:00 to 0	148.02	-9.57	216.9	86.98	13.47	1.15	-1.98	6.09
05:00 to 0	145.85	-4.53	218.62	110.76	13.5	1.2	4.49	5.69
06:00 to 0	143.21	-6.82	212.29	97.91	13.55	1.21	4.96	5.51
07:00 to 0	142.83	-11.72	206.81	91.99	13.44	1.21	1.03	5.89
08:00 to 0	142.25	-4.51	213.14	101.26	13.52	1.18	-0.46	5.94
09:00 to 0	145.65	-6.28	216.57	106.26	13.58	1.09	2.78	5.71
10:00 to 1	143.07	0.52	219.42	83.94	13.66	0.99	1.59	5.77
11:00 to 1	146.25	0.23	224	94.13	13.55	1.08	-1.46	6.09
12:00 to 1	143.99	-25.8	194.51	91.4	13.36	2.17	-1.09	6.14
13:00 to 1	157.44	-34.1	206.78	69.18	13.35	1.93	-1.41	6.23
14:00 to 1	161.53	-28.2	218.94	75.75	13.43	1.1	-0.84	6.18
15:00 to 1	156.43	3.88	243.22	91.27	13.6	1.06	-3.3	6.03
16:00 to 1	159.82	3.6	248.13	95.37	13.6	1.1	-2.09	6.03
17:00 to 1	159.93	-1.41	243.27	78.61	13.45	1.13	-0.57	6.15
18:00 to 1	157.18	-10.56	229.93	73.44	13.46	1.15	-3.48	6.19
19:00 to 1	158.1	-11.58	230.32	79	13.54	1.18	-2.77	6.13
20:00 to 2	159.29	-8.84	234.87	72.74	13.52	1.22	-0.43	6.08
21:00 to 2	151.28	-7.33	224.13	67.65	13.41	1.24	-0.69	6.1
22:00 to 2	151.71	-1.16	230.95	69.51	13.52	1.26	3.96	5.79
23:00 to 2	155.25	9.08	246.61	69.28	13.61	1.24	2	5.88
95 Percent	159.93	3.88	246.61	106.53	13.62	1.93	4.49	6.23
Daily Avera	151.34	-7.27	224.28	86.3	13.51	1.23	-0.8	6.02

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	148.68	-5.82	221.66	73.08	13.46	1.22	-0.08	6.03
01:00 to 0	149.49	-5.82	222.9	72.19	13.47	1.24	0.87	6.03
02:00 to 0	150.54	0.43	230.76	74.15	13.6	1.19	0.64	5.93
03:00 to 0	150.78	4.71	235.41	73.93	13.5	1.22	1.26	5.96
04:00 to 0	144.3	-0.24	220.55	72.44	13.46	1.21	-1.06	6.15
05:00 to 0	137.78	23.63	234.44	78.59	13.65	1.21	-0.83	6.06
06:00 to 0	137.43	-12.87	197.4	72.03	13.48	1.21	-0.95	6.03
07:00 to 0	132.9	-23.29	180.05	69.58	13.41	1.22	0.82	6.03









14:00 to 1	Off	Off	Off	Off	Off	Off	Off
15:00 to 1	Off	Off	Off	Off	Off	Off	Off
16:00 to 1	Off	Off	Off	Off	Off	Off	Off
17:00 to 1	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	Off	Off	Off	Off	Off	Off	Off
21:00 to 2	Off	Off	Off	Off	Off	Off	Off
22:00 to 2	Off	Off	Off	Off	Off	Off	Off
23:00 to 2	Off	Off	Off	Off	Off	Off	Off
95 Percent	Off	Off	Off	Off	Off	Off	Off
Daily Avera	Off	Off	Off	Off	Off	Off	Off

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
01:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
02:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
10:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
11:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
12:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
13:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
14:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
15:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
16:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
17:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
21:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
22:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
23:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
95 Percent	Off	Off	Off	Off	Off	Off	Off	Off
Daily Avera	Off	Off	Off	Off	Off	Off	Off	Off

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
01:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
02:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
08:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
09:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
10:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
11:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
12:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
13:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
14:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
15:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
16:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
17:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
18:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
19:00 to 1	Off	Off	Off	Off	Off	Off	Off	Off
20:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
21:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
22:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
23:00 to 2	Off	Off	Off	Off	Off	Off	Off	Off
95 Percent	Off	Off	Off	Off	Off	Off	Off	Off
Daily Average	Off	Off	Off	Off	Off	Off	Off	Off

CDAS 2004  
Report print

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
01:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
02:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
03:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
04:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
05:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
06:00 to 0	Off	Off	Off	Off	Off	Off	Off	Off
07:00 to 0	75.36	6.17	121.47	249.77	3.22	18.34	-26.23	20.76
08:00 to 0	96.56	26.34	174.07	491.3	3.11	11.52	-8.81	18.06
09:00 to 0	95.85	-43.56	103.08	1015.13	2.49	10.46	-4.18	18.02
10:00 to 1	118.49	-17.14	164.15	3.01	4.85	2.83	-22.38	17.13
11:00 to 1	125.5	-30.79	161.22	37.39	5.93	3.71	-14.97	14.62
12:00 to 1	160.91	-3.12	243.08	68.74	8.03	4.24	-3.4	12.29
13:00 to 1	161.62	-0.32	246.96	53.53	9.36	1.27	-7.59	11.45
14:00 to 1	143.74	-4.8	215.12	39.64	10.04	1.12	-6.94	10.59
15:00 to 1	136.97	-11.88	197.69	33.61	10.27	1.09	-6.34	10.27
16:00 to 1	139.03	-16.42	196.3	33.48	10.18	1.13	-5.87	10.33

17:00 to 1	137.62	-19.73	190.83	40.08	10.37	1.23	-8.34	10.26
18:00 to 1	132.91	6.03	209.38	73.99	12.65	1.24	-11.91	8.01
19:00 to 1	128.12	3.23	199.25	67.87	13.36	1.2	-9.6	6.86
20:00 to 2	126.5	-4.35	189.19	65.5	13.45	1.18	-10.23	6.75
21:00 to 2	130.21	0.11	199.33	72.1	13.4	1.18	-9.47	6.74
22:00 to 2	134.8	10.74	216.97	71.04	13.32	1.18	-7.82	6.84
23:00 to 2	136.33	8.05	216.64	68.46	13.21	1.19	-7.68	6.92
95 Percent	161.62	26.34	246.96	1015.13	13.45	18.34	-3.4	20.76
Daily Avera	128.27	-5.38	190.87	146.15	9.25	3.77	-10.1	11.52

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	137.24	5.72	215.71	68.58	13.15	1.14	-8.71	6.98
01:00 to 0	136.3	3.93	212.47	63.72	13.32	1.15	-8.68	6.8
02:00 to 0	136.74	10.53	219.75	75.67	13.34	1.14	-7.44	6.7
03:00 to 0	145.13	-5.64	216.42	67.2	13.3	1.13	-8.28	6.66
04:00 to 0	140.58	0.48	215.57	69.11	13.24	1.16	-7.35	6.76
05:00 to 0	145.55	-6.21	216.48	65.79	13.11	1.17	-6.62	6.84
06:00 to 0	143.4	-0.6	218.8	67.43	13.19	1.15	-8.33	6.84
07:00 to 0	143.42	0.34	219.77	66.56	13.27	1.16	-7.05	6.71
08:00 to 0	141.48	0.83	217.29	70	13.31	1.14	-7.37	6.69
09:00 to 0	145.21	3.48	225.65	69.34	13.25	1.1	-7.19	6.69
10:00 to 1	140.8	-1.82	213.61	64.52	13.27	1	-6.6	6.71
11:00 to 1	146.6	-10.01	214.3	69.18	13.15	0.93	-4.12	6.72
12:00 to 1	148.29	-2.09	224.79	66.43	13.28	0.93	-5.17	6.57
13:00 to 1	144.51	-10.33	210.77	60.77	13.22	1.21	-2.62	6.43
14:00 to 1	145.23	-4.09	218.11	53.88	13.29	1.9	-2.82	6.38
15:00 to 1	155.29	-2.32	235.28	77.35	13.14	0.92	-2.13	6.42
16:00 to 1	145.73	9.28	232.25	68.36	13.13	0.98	-4.44	6.67
17:00 to 1	156.78	-8.33	231.54	69.34	12.99	1.04	-5.15	6.77
18:00 to 1	153.6	6.64	241.65	62.1	13.25	1.06	-6.18	6.62
19:00 to 1	146.77	16.38	240.94	75.24	13.43	1.07	-6.33	6.49
20:00 to 2	155.69	15.37	253.59	68.73	13.4	1.05	-4.84	6.48
21:00 to 2	150.01	2.16	231.68	67.65	13.22	1.09	-5.38	6.61
22:00 to 2	151.04	3.43	234.52	77.52	12.99	1.18	-4.56	6.88
23:00 to 2	157.59	-8.04	233.06	83.15	12.91	1.19	-5.3	6.95
95 Percent	156.78	15.37	241.65	77.52	13.4	1.21	-2.62	6.95
Daily Avera	146.37	0.8	224.75	68.65	13.21	1.13	-5.94	6.68

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	151.58	3.95	235.87	64.67	13.23	1.11	-7.26	6.68
01:00 to 0	146.47	5.33	229.42	69.66	13.34	1.12	-5.81	6.5

02:00 to C	155.63	6.43	244.53	71.97	13.21	1.19	-4.65	6.62
03:00 to C	144.73	10.42	231.86	72.9	13.21	1.15	-6.91	6.73
04:00 to C	141.92	1.92	219.05	84.04	12.99	1.19	-4.01	6.8
05:00 to C	143.6	0.25	219.96	80.5	13.1	1.21	-4.57	6.72
06:00 to C	147.55	-42.25	183.5	59.99	13.07	1.21	-6.46	6.72
07:00 to C	148.65	-27.95	199.48	62.63	13.21	1.22	-5.88	6.61
08:00 to C	158.53	-21.15	221.4	67.93	13.25	1.17	-2.88	6.44
09:00 to C	148.4	-0.4	226.65	81.44	13.21	1.11	-0.98	6.36
10:00 to 1	146.94	1.44	226.26	88.64	13.14	1.04	-3.22	6.64
11:00 to 1	144.21	-8.23	212.42	77.08	13.1	1.56	-3.16	6.67
12:00 to 1	132.37	-11.51	191.02	62.45	13.38	1.65	-2.91	6.23
13:00 to 1	149.32	-13.93	214.53	76.13	13.29	1.05	-2.14	6.23
14:00 to 1	154.24	-24.32	211.67	79.82	13.16	1.1	-1.97	6.32
15:00 to 1	151.4	6.13	237.77	86.55	13.29	1.17	-2.44	6.41
16:00 to 1	152.36	13.9	247.01	88.48	13.29	1.18	-1.09	6.43
17:00 to 1	150.44	3.59	233.77	79.38	13.4	1.17	3.83	5.99
18:00 to 1	140.19	-4.98	209.51	86.02	13.53	1.15	3.76	5.74
19:00 to 1	150.75	-4.1	226.55	81.94	13.39	1.14	-0.96	6.18
20:00 to 2	150.89	0.58	231.44	92.82	13.24	1.16	-4.11	6.57
21:00 to 2	145.47	1.13	223.69	107.01	13.11	1.14	-2.41	6.58
22:00 to 2	152.83	-2.47	231.36	90.31	13.23	1.16	0.48	6.31
23:00 to 2	152.5	-5.2	228.12	78.08	13.36	1.17	3.14	6
95 Percent	155.63	10.42	244.53	92.82	13.4	1.56	3.76	6.73
Daily Avera	148.37	-4.64	222.37	78.77	13.24	1.19	-2.61	6.44

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to C	139.53	8.33	221.81	73.65	13.32	1.84	2.94	6
01:00 to C	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
02:00 to C	159.64	9.04	253.29	71.81	13.28	1.16	-2.68	6.46
03:00 to C	159.57	4.42	248.56	81.82	13.23	1.19	0.56	6.31
04:00 to C	163.01	-3.84	245.57	91.55	13.07	1.28	3.81	6.24
05:00 to C	168.09	-4.7	252.49	81.76	13.19	1.29	1.8	6.26
06:00 to C	165.21	-2.98	249.79	80.59	13.32	1.28	-0.77	6.28
07:00 to C	157.72	-8.31	233	76.91	13.39	1.31	0.56	6.01
08:00 to C	162.82	1.56	250.68	80.96	13.28	1.3	4.04	6.04
09:00 to C	154.33	-9	227.12	91.48	13.17	1.26	5.2	6.1
10:00 to 1	151.46	19.01	250.75	97.1	13.35	0.94	5.24	5.95
11:00 to 1	141.92	27.39	244.53	77.78	13.42	1.93	-0.13	6.27
12:00 to 1	142.71	41.71	260.06	81.77	13.94	0.76	0.69	5.82
13:00 to 1	153.04	6.9	241.06	86.04	13.7	0.82	0.19	5.87
14:00 to 1	165.7	-62.53	190.98	81.09	13.12	0.92	-6.5	6.55
15:00 to 1	155.01	-70.48	166.69	90.97	13.06	0.86	-6.07	6.57
16:00 to 1	151.82	8.55	240.84	99.04	13.45	0.95	-5.79	6.53
17:00 to 1	152.96	16.23	250.25	96.41	13.54	1.03	-5.2	6.46
18:00 to 1	145.66	14.51	237.37	104.63	13.78	1.03	-1.83	6.02
19:00 to 1	164.95	-18.82	233.55	89.45	13.41	1.13	-0.33	6.06

20:00 to 2	167.47	-33.02	223.21	84.83	13.23	1.22	0.35	6.18
21:00 to 2	166.93	-42.88	212.53	94.67	13.02	1.31	3.02	6.22
22:00 to 2	158.92	-9.02	234.13	85.76	13.37	1.3	0.57	6.15
23:00 to 2	156.94	-22.32	217.8	76.26	13.37	1.5	1.99	6.05
95 Percent	167.47	27.39	253.29	99.04	13.78	1.84	5.2	6.55
Daily Avera	156.76	-5.66	234.18	85.93	13.35	1.2	0.07	6.19

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	144.19	-25.51	195.1	70.78	13.5	1.83	1.61	6.01
01:00 to 0	164.41	-12.46	239.09	83.97	13.38	1.36	1.35	6.07
02:00 to 0	157.94	-15.02	226.63	105.53	13.22	1.36	3.13	6.16
03:00 to 0	156.57	-2.36	237.19	117.16	13.23	1.38	5.72	6.05
04:00 to 0	160.69	-0.6	245.26	93.06	13.43	1.33	-1.76	6.18
05:00 to 0	153.89	-4.18	231.27	92.9	13.52	1.35	-1.19	6.1
06:00 to 0	161.29	2.35	249.12	93.43	13.61	1.34	3.54	5.8
07:00 to 0	162.28	-4.79	243.5	89.86	13.31	1.29	2.39	6.07
08:00 to 0	149.92	-13.21	216.17	114.34	13.22	1.29	4.6	6.07
09:00 to 0	148.37	-11.66	215.35	117.89	13.26	1.22	1.4	6.26
10:00 to 1	143.85	11.09	231.18	99.3	13.65	1.11	-0.99	6.04
11:00 to 1	138.16	11.05	222.43	121.02	13.79	1.03	-0.74	5.95
12:00 to 1	149.13	6.5	234.66	91.8	13.57	1.29	-2.13	6.26
13:00 to 1	147.33	-4.87	220.55	81.72	13.23	1.93	-3.27	6.52
14:00 to 1	159.75	-10.64	233.77	99.04	13.16	1.06	-3.09	6.59
15:00 to 1	163.55	-11.72	238.51	81.19	13.31	1.05	-3.53	6.46
16:00 to 1	156.82	-16.28	223.65	72.79	13.46	1.04	-2.79	6.22
17:00 to 1	151.68	-20.42	211.65	79.12	13.56	1.09	-2.69	6.07
18:00 to 1	167.92	-18.07	238.85	76.27	13.3	1.2	1.77	6.1
19:00 to 1	152.92	16.5	250.47	85.47	13.38	1.26	-2.84	6.37
20:00 to 2	153.19	7.58	241.96	84.53	13.19	1.34	-2.92	6.62
21:00 to 2	151.39	21.79	253.42	82.97	13.44	1.27	-4.34	6.46
22:00 to 2	144.41	-10.81	210.14	72.02	13.51	1.16	-5.91	6.37
23:00 to 2	148.27	-27.41	199.44	73.29	13.51	1.25	-5.33	6.3
95 Percent	164.41	16.5	250.47	117.89	13.65	1.83	4.6	6.59
Daily Avera	153.66	-5.55	229.56	90.81	13.41	1.28	-0.75	6.21

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	162.16	-26.74	221.36	75.62	13.33	1.29	-4.16	6.52
01:00 to 0	155.45	-14.42	223.42	79.48	13.14	1.3	-5.31	6.68
02:00 to 0	157.98	-5.83	235.88	79.75	13.13	1.31	-4.41	6.74
03:00 to 0	155.45	-3.91	233.93	77.96	13.41	1.25	-4.99	6.5
04:00 to 0	148.51	-5.23	221.98	78.65	13.42	1.25	-5.57	6.36

05:00 to 0	153.22	-7.85	226.57	77.99	13.45	1.24	-2.88	6.2
06:00 to 0	154.32	-25.51	210.6	80.83	13.17	1.28	-1.98	6.46
07:00 to 0	147.58	8.69	234.49	85.66	13.24	1.27	-4.21	6.59
08:00 to 0	154.84	8.39	245.3	82.54	13.33	1.29	-3.85	6.56
09:00 to 0	148.59	5.73	233.06	79.85	13.57	1.24	-3.96	6.29
10:00 to 1	140.56	1.83	216.89	80.22	13.49	1.18	-4.82	6.28
11:00 to 1	155.14	-6.21	231.16	80.2	13.42	1.12	-1.54	6.28
12:00 to 1	142.16	-9.75	207.75	73.89	13.18	2.79	-0.18	6.47
13:00 to 1	150.32	-3.46	226.53	68.82	13.17	1.05	-2.33	6.46
14:00 to 1	157.4	3.29	244.12	65.75	13.37	0.97	-3.35	6.38
15:00 to 1	158.02	-3.3	238.46	109.21	13.4	1.21	-3.9	6.34
16:00 to 1	153.87	-25.56	209.86	77.81	13.58	1.19	-5.68	6.31
17:00 to 1	163.07	-30.93	218.56	78.29	13.54	1.2	-4.58	6.37
18:00 to 1	165.81	-29.98	223.71	83.95	13.31	1.25	-3.14	6.59
19:00 to 1	165.65	6.22	259.66	87.18	13.36	1.25	-5.31	6.59
20:00 to 2	169.37	-0.9	258.24	89.61	13.53	1.29	-3.62	6.33
21:00 to 2	168.66	3.61	261.66	93.11	13.63	1.28	-3.44	6.23
22:00 to 2	163.82	2.3	252.94	88.81	13.51	1.25	-4.09	6.2
23:00 to 2	170.02	1.6	261.72	96.54	13.38	1.36	-0.35	6.25
95 Percent	169.37	8.39	261.66	96.54	13.58	1.36	-0.35	6.68
Daily Average	156.75	-6.58	233.24	82.16	13.38	1.3	-3.65	6.42

CDAS 2004  
Report prior

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	160.42	-2.94	242.5	109.24	13.16	1.4	-0.36	6.48
01:00 to 0	159.69	-29.66	214.66	88.83	13.1	1.34	-4.56	6.56
02:00 to 0	163.99	-32.44	218.47	87.6	13.44	1.37	-1.84	6.18
03:00 to 0	154.55	-31.33	205.13	82.1	13.55	1.33	-1.69	6.04
04:00 to 0	161.19	4.03	250.64	94.86	13.46	1.39	2.4	5.94
05:00 to 0	159.58	8.15	252.31	96.42	13.28	1.44	4.26	6.04
06:00 to 0	155.37	11.04	248.75	107.82	13.12	1.5	5.79	6.12
07:00 to 0	156.49	-13.59	225.83	90.46	13.31	1.45	1.04	6.09
08:00 to 0	159.66	-39.44	204.84	78.74	13.31	1.44	-2.08	6.22
09:00 to 0	152.8	-37.42	196.36	87.54	13.47	1.45	-3.15	6.18
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.2
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.46
12:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.77
13:00 to 1	140.5	20.15	235.12	98.66	13.19	2.17	-2.97	6.6
14:00 to 1	141.94	22.48	239.66	71.2	13.56	1.96	-3.32	6.47
15:00 to 1	141.56	22.4	238.99	80.72	13.65	1.13	-2.94	6.37
16:00 to 1	147.86	-6.42	219.8	87.21	13.32	1.12	-5.17	6.44
17:00 to 1	140.47	-9.86	205.05	109.19	13.14	1.22	-3.96	6.63
18:00 to 1	137.16	-12.39	197.47	127.85	13.09	1.27	-4.88	6.75
19:00 to 1	139.43	0.36	213.69	92.22	13.33	1.32	-5.37	6.54
20:00 to 2	128.62	3.2	200	89.34	13.54	1.32	-3.82	6.26
21:00 to 2	135.46	0.52	207.77	80.12	13.41	1.37	-1.83	6.31
22:00 to 2	135.58	9.88	217.32	90.64	13.29	1.37	-3.46	6.48

23:00 to 2	132.37	22.06	224.58	113.81	13.1	1.43	1.53	6.46
95 Percent	161.19	22.4	250.64	113.81	13.56	1.96	4.26	6.75
Daily Avera	147.84	-4.34	221.85	93.55	13.33	1.42	-1.73	6.36

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	127.8	29.09	224.62	105.91	13.26	1.42	-0.39	6.43
01:00 to 0	129.54	6.26	204.46	76.98	13.37	1.32	-3.24	6.24
02:00 to 0	125	-8.78	182.47	82.73	13.39	1.37	-3.01	6.18
03:00 to 0	135.34	-23.54	183.53	75.64	13.24	1.39	-2.62	6.27
04:00 to 0	132.05	-16.29	185.75	88.86	13.17	1.36	-3.9	6.45
05:00 to 0	132.43	-18.12	184.5	103.71	12.99	1.43	-2.76	6.65
06:00 to 0	130.29	-17.13	182.22	82.41	13.1	1.38	-3.7	6.59
07:00 to 0	123.87	-2.93	186.58	76.08	13.34	1.33	-5.61	6.45
08:00 to 0	124.17	10.86	200.85	90.17	13.4	1.3	-2.96	6.38
09:00 to 0	126.06	5.81	198.68	89.15	13.44	1.13	-3.15	6.32
10:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.46
11:00 to 1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.62
12:00 to 1	140.42	-0.81	214.04	78.53	13.05	1.55	-4.6	6.64
13:00 to 1	127.07	3.34	197.76	72.19	13.32	2.01	-5.46	6.55
14:00 to 1	128.91	9.66	206.88	82.74	13.48	1.22	-2.92	6.31
15:00 to 1	134.95	15.43	221.9	97.62	13.39	1.22	-1.94	6.42
16:00 to 1	132.3	-1.26	201.17	100.92	13.06	1.25	-2.5	6.5
17:00 to 1	136.92	-7.22	202.27	97.23	13.03	1.32	-3.89	6.65
18:00 to 1	131.92	-7.54	194.3	94.31	13.29	1.23	-1.56	6.27
19:00 to 1	123.73	1.44	190.75	97.84	13.38	1.28	-2.85	6.2
20:00 to 2	132.26	0.3	202.66	99.02	13.29	1.35	-2.19	6.26
21:00 to 2	135.62	-2.85	204.65	99.77	13.18	1.41	-2.23	6.41
22:00 to 2	131.19	-5.36	195.35	117.36	12.96	1.45	-2.48	6.62
23:00 to 2	131.08	-0.07	200.48	100.42	13.12	1.45	-2.77	6.51
95 Percent	136.92	15.43	221.9	105.91	13.44	1.55	-1.56	6.65
Daily Avera	130.59	-1.35	198.45	91.35	13.24	1.37	-3.03	6.43

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	131.39	6.81	207.83	97.94	13.3	1.46	-1.09	6.26
01:00 to 0	128.75	-4.1	192.88	100.78	13.42	1.43	-3.33	6.23
02:00 to 0	142.52	-9.73	208.32	85.91	13.3	1.44	-2.2	6.28
03:00 to 0	141.07	-16.02	199.82	89.61	13.19	1.46	-2.34	6.43
04:00 to 0	141.84	10.44	227.44	102.94	13.06	1.46	-3.7	6.67
05:00 to 0	137.1	4.75	214.52	96.17	13.2	1.44	-3.62	6.53
06:00 to 0	133.51	-0.54	203.74	91.99	13.3	1.44	-3.71	6.41
07:00 to 0	131.07	1.42	201.97	91.45	13.38	1.44	-4.76	6.33

08:00 to 0	138.6	9.44	221.5	94.39	13.28	1.38	-2.82	6.42
09:00 to 0	131.76	26.74	228.33	105.95	13.2	1.34	-2.24	6.55
10:00 to 1	131.13	17.85	218.47	110.17	13.14	1.26	-2.92	6.63
11:00 to 1	130.69	-1.89	198.06	86.45	13.35	1.17	-4.56	6.43
12:00 to 1	125.31	-11.04	180.68	102.32	13.48	1.15	-3.08	6.21
13:00 to 1	127.67	6.8	202.13	89.51	13.26	2.2	0.72	6.2
14:00 to 1	130.69	3.37	203.31	81.38	13.29	1.94	-0.6	6.3
15:00 to 1	127.64	-5.04	190.24	128.11	13.05	1.4	-1.1	6.52
16:00 to 1	129.09	16.63	214.13	121.8	13.23	1.43	0.28	6.34
17:00 to 1	130.36	15.53	214.98	99.82	13.41	1.39	2.08	6.06
18:00 to 1	128.1	12.32	208.31	134.47	13.48	1.4	-1.3	6.17
19:00 to 1	138.13	17.42	228.75	103.56	13.31	1.48	1	6.15
20:00 to 2	127.03	19.9	214.25	108.55	13.38	1.47	1.91	6.08
21:00 to 2	124.32	30.28	220.49	118.4	13.28	1.52	4.29	6.1
22:00 to 2	133.51	-13.34	190.93	100.79	13.32	1.46	-1.51	6.19
23:00 to 2	138.75	-21.99	190.3	91.39	13.35	1.48	-0.51	6.15
95 Percent	141.84	26.74	228.33	128.11	13.48	1.94	2.08	6.63
Daily Avera	132.5	4.83	207.56	101.41	13.29	1.46	-1.46	6.32

CDAS 2004  
Report prir

	NO mg/m3	NO2 mg/m	NOx mg/m	CO mg/m3	CO2 %	Dust mg/m	Moisture %	Wet O2 Sta
00:00 to 0	133.08	6.77	210.39	103.24	13.48	1.48	-0.02	6.11
01:00 to 0	157.27	-11.79	228.84	87.01	13.18	1.49	-0.48	6.27
02:00 to 0	167.08	-17.74	237.9	86.62	12.92	1.54	0.05	6.58
03:00 to 0	164.34	-12.25	239.2	89.73	12.93	1.54	0.65	6.68
04:00 to 0	138.97	-4.61	208.02	78.4	13.25	1.41	-1.8	6.33
05:00 to 0	136.18	-9.33	199.02	78.78	13.34	1.47	0.34	6.2
06:00 to 0	136.41	-23.06	185.64	78.42	13.3	1.48	1.45	6.13
07:00 to 0	138.92	-12.94	199.61	83.11	13.14	1.46	-0.78	6.31
08:00 to 0	136.91	-19.59	189.88	87.43	13.01	1.53	0.84	6.56
09:00 to 0	144.84	-23.25	198.35	80.03	13.06	1.54	-0.44	6.63
10:00 to 1	139.47	-12.23	201.16	78.18	13.23	1.44	-2.35	6.38
11:00 to 1	149.65	-5.5	223.46	78.7	13.32	1.42	-0.59	6.3
12:00 to 1	157.01	-4.93	235.3	80.55	13.34	1.36	0.44	6.26
13:00 to 1	159.61	9.64	253.84	83.6	13.24	1.32	-0.76	6.32
14:00 to 1	162.95	5.44	254.75	79.2	13.2	1.32	0.48	6.44
15:00 to 1	162.17	-1.22	246.9	71.53	13.04	2.42	2.07	6.5
16:00 to 1	154.67	4.42	241.06	79.25	13.26	1.3	-0.65	6.3
17:00 to 1	144.87	-0.9	220.74	113.64	13.42	1.31	0.47	6.16
18:00 to 1	147.27	-4.02	221.31	88.01	13.21	1.37	2.81	6.27
19:00 to 1	136.56	7.36	216.3	91.69	13.25	1.28	-0.05	6.27
20:00 to 2	143.32	1.4	220.67	93.21	13.07	1.32	2.3	6.33
21:00 to 2	150.45	-3.77	226.42	89.34	13.14	1.33	1.2	6.37
22:00 to 2	144.58	-0.05	221.15	83.62	13.32	1.31	1.13	6.13
23:00 to 2	140.93	0.52	216.14	91.97	13.43	1.33	2.86	5.94
95 Percent	164.34	7.36	253.84	103.24	13.43	1.54	2.81	6.63
Daily Avera	147.81	-5.48	220.67	85.64	13.21	1.45	0.38	6.32

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.4	246.8	N/A	0	0	75.68	145.36	1004.01
0	6.7	308.8	N/A	0	0	76.05	145.35	1003.14
0	6.6	345.2	N/A	0	0	76.11	145.81	1002.27
0	6.5	254.1	N/A	0	0	75.89	146.01	1000.22
0	6.6	320.7	N/A	0	0	76.75	146.38	999.59
0	6.6	356.6	N/A	0	0	77.12	146.59	998.78
0	6.5	266.4	N/A	0	0	78.48	147.28	997.57
0	6.5	338.5	N/A	0	0	77.33	147.86	996.98
0	6.6	375.3	N/A	0	0	78.45	148.35	996.29
0	6.4	298.5	N/A	0	0	77.34	149.17	995.15
0	6.5	396.3	N/A	0	0	79.42	148.89	994.33
0	6.6	439.2	N/A	0	0	77.76	148.96	993.79
0	6.6	304.9	N/A	0	0	79.75	148.12	992.22
0	6.6	398.8	N/A	0	0	77.72	145.71	991.29
0	6.5	443.8	N/A	0	0	77.48	145.68	990.86
0	6.5	324.5	N/A	0	0	77.2	146.14	989.29
0	6.5	409.7	N/A	0	0	76.35	146.18	987.85
0	6.6	437.6	N/A	0	0	76.4	146.14	987
0	6.5	322.7	N/A	0	0	76.37	146.22	986.21
0	6.6	419.5	N/A	0	0	76.62	146.34	985.27
0	6.6	454.8	N/A	0	0	76.92	146.27	984.85
0	6.4	325.9	N/A	0	0	74.94	146.35	984.65
0	6.6	417.4	N/A	0	0	75.36	146.37	983.91
0	6.4	470.1	N/A	0	0	75.6	146.64	983.6
0	6.6	454.8	N/A	0	0	79.42	148.96	1003.14
0	6.5	361.5	N/A	0	0	76.96	146.76	992.88

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.5	354.2	N/A	0	0	75.25	146.56	983.49
0	6.5	449.9	N/A	0	0	74.45	146.27	982.82
0	6.6	473.3	N/A	0	0	74.22	146.44	983.01
0	6.4	343.9	N/A	0	0	75.18	146.73	983.41
0	6.5	425.4	N/A	0	0	75.41	147.08	983.24
0	6.6	459.5	N/A	0	0	75.32	147.27	982.52
0	6.4	340.9	N/A	0	0	74.1	147.22	981.54
0	6.5	434.2	N/A	0	0	74.42	146.89	981.54
0	6.5	485.9	N/A	0	0	74.12	146.58	981.82
0	6.4	382.6	N/A	0	0	75.29	146.88	982.76
0	6.6	512.9	N/A	0	0	76.94	147.68	983.14
0	6.6	543.1	N/A	0	0	76.01	148.73	983.67
0	6.5	400.4	N/A	0	0	77.52	149.44	984.43
0	6.7	492.6	N/A	0	0	78.19	148.37	984.63

0	6.6	518.5 N/A	0	0	76.35	146.12	984.07
0	6.5	384.8 N/A	0	0	76.01	145.97	984.36
0	6.5	458.7 N/A	0	0	75.89	145.57	984.44
0	6.5	491 N/A	0	0	75.65	145.31	984.1
0	6.4	359.4 N/A	0	0	74.13	145.33	984.73
0	6.5	465.5 N/A	0	0	74.92	145.61	984.88
0	6.5	507.1 N/A	0	0	74.9	146	985
0	6.4	372.7 N/A	0	0	75.13	147.15	984.36
0	6.5	477.2 N/A	0	0	75.95	147.48	984.46
0	6.5	525.3 N/A	0	0	77.91	148.54	984.18
0	6.6	525.3 N/A	0	0	77.91	148.73	984.88
0	6.5	444.1 N/A	0	0	75.55	146.88	983.61

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combus	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.5	392.6 N/A	0	0	76.9	149.07	983.54	
0	6.5	513.6 N/A	0	0	77.5	149.24	982.44	
0	6.5	574.8 N/A	0	0	77.47	149.87	981.93	
0	6.5	431.5 N/A	0	0	78.97	150.84	981.68	
0	6.4	587.8 N/A	0	0	76.93	150.77	982.29	
0	6.5	655.3 N/A	0	0	77.13	150.61	983.53	
0	6.3	461.5 N/A	0	0	77.06	150.9	984.21	
0	6.6	573.4 N/A	0	0	76.12	150.4	984.65	
0	6.6	648.3 N/A	0	0	73.83	149.22	985.14	
0	6.7	503.8 N/A	0	0	77.47	148.36	985.34	
0	6.6	668.4 N/A	0	0	77.55	150.52	986.19	
0	6.7	717.2 N/A	0	0	76.79	150.58	985.83	
0	6.8	681.3 N/A	0	0	77.79	149.92	986.39	
0	6.6	795.3 N/A	0	0	76.56	147.27	986.03	
0	6.7	809.8 N/A	0	0	77.19	147.2	985.5	
0	6.5	525.9 N/A	0	0	74.41	145.62	985.25	
0	6.7	627.3 N/A	0	0	76.54	147.09	985.24	
0	6.7	696.2 N/A	0	0	76.87	147.64	985.75	
0	6.4	440 N/A	0	0	75.52	147.53	985.16	
0	6.5	536.4 N/A	0	0	75.95	147.45	985.49	
0	6.5	649.6 N/A	0	0	74.91	147.99	986.19	
0	6.5	496.4 N/A	0	0	75.27	148.5	986.65	
0	6.4	606.9 N/A	0	0	76.79	148.8	986.36	
0	6.5	630.8 N/A	0	0	76.71	148.95	985.99	
0	6.7	795.3 N/A	0	0	77.79	150.84	986.39	
0	6.5	592.7 N/A	0	0	76.59	148.93	984.86	



Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
0	16.3	990.9	N/A	0	0	42.22	58.7	988.57
0	17.5	1028.8	N/A	0	0	41.89	64.37	990.27
0	14.9	1110.8	N/A	0	0	42.27	74.09	989.46
0	12.8	1091.4	N/A	0	0	42.36	90.64	988.57
0	12.5	885.8	N/A	0	0	54.1	100.19	988.85
0	8.9	1208.8	N/A	0	0	58.93	123.29	988.87
0	9.8	1122.4	N/A	0	0	58.87	129.3	988.89
0	9.4	691.8	N/A	0	0	58.13	132.13	988.48
0	9.2	812.1	N/A	0	0	56.53	131.55	988.3
0	9.1	858	N/A	0	0	56.11	131.53	988.63
0	9.1	557.4	N/A	0	0	57.36	131.48	988.21
0	9.1	734.3	N/A	0	0	58.35	131.64	989
0	8.4	816.4	N/A	0	0	75.48	139.15	989.89
0	17.5	1208.8	N/A	0	0	75.48	139.15	990.27
0	11.3	916.1	N/A	0	0	54.05	110.62	988.92

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	7.3	590.7	N/A	0	0	79.18	149.42	990.55
0	6.6	763.6	N/A	0	0	77.42	149.08	990.57

0	6.3	847.7	N/A	0	0	75.02	147.49	990.75
0	6.2	628.7	N/A	0	0	75.72	147.58	991
0	6.1	786.6	N/A	0	0	75	147.51	991.24
0	5.9	845.2	N/A	0	0	75.09	147.11	991.51
0	5.9	523.5	N/A	0	0	75.58	147.23	991.33
0	6	709.7	N/A	0	0	76.2	147.39	992.61
0	5.9	790.8	N/A	0	0	75.81	147.42	993.18
0	5.9	644	N/A	0	0	75.61	147.92	994.16
0	6.1	921.8	N/A	0	0	77.25	148.48	994.95
0	6	1058.6	N/A	0	0	75.07	148.63	995.33
0	5.9	861.2	N/A	0	0	75.85	148.15	995.85
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6	444.1	N/A	0	0	75.57	145.44	995.46
0	6	767.8	N/A	0	0	75.95	145.42	995.42
0	6.2	818.9	N/A	0	0	74.55	145.32	995.04
0	6.1	508.4	N/A	0	0	70.73	144.6	994.4
0	6.1	630.7	N/A	0	0	73.71	142.53	994.32
0	6.1	744.2	N/A	0	0	74.67	144.06	994.46
0	6.1	487.4	N/A	0	0	73.76	144.63	993.28
0	6	624.2	N/A	0	0	73.88	144.26	992.52
0	6.1	715.9	N/A	0	0	73.88	144.46	991.61
0	6.6	921.8	N/A	0	0	77.42	149.08	995.46
0	6.1	714.3	N/A	0	0	75.25	146.55	993.16

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.1	531.3	N/A	0	0	73.69	145.17	990.62
0	6.1	631.7	N/A	0	0	73.33	145.08	989.34
0	6.2	673.9	N/A	0	0	74.46	145.06	988.67
0	6.1	523	N/A	0	0	73.31	145.4	988.74
0	6.1	634.2	N/A	0	0	73.12	145.27	988.9
0	6.1	717.1	N/A	0	0	74.46	145.08	989.59
0	6.1	493.8	N/A	0	0	74.39	145.53	990.34
0	6.3	634.8	N/A	0	0	74.5	145.73	991.3
0	6.2	705.8	N/A	0	0	73.53	145.78	992.59
0	6.1	567.7	N/A	0	0	75.08	146.17	994.55
0	6.2	774.5	N/A	0	0	74.52	146.58	995.16
0	6.1	1001.8	N/A	0	0	74.83	147.05	996.42
0	6	830.2	N/A	0	0	74.61	147.06	997.2
0	6.1	862.9	N/A	0	0	74.63	147.19	996.43
0	6.3	934	N/A	0	0	76.87	146.99	996.61
0	6.1	770.8	N/A	0	0	75.91	145.05	997.52
0	6.1	836.8	N/A	0	0	76.68	145.43	997.88
0	6.1	833.6	N/A	0	0	75.44	145.25	998.05
0	6.1	577.7	N/A	0	0	75.12	145.4	998.43
0	6.1	721.9	N/A	0	0	74.9	145.16	998.85

0	6.1	784.6	N/A	0	0	75.14	145.57	999.58
0	6.1	583.2	N/A	0	0	75.71	146.12	999.86
0	6.1	724	N/A	0	0	76.18	146.48	1000.56
0	6.1	814.6	N/A	0	0	76.6	147.05	1000.83
0	6.3	934	N/A	0	0	76.68	147.06	1000.56
0	6.1	715.2	N/A	0	0	74.88	145.86	994.92

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.1	593.3	N/A	0	0	76.49	148.12	1001.12
0	6.5	727.3	N/A	0	0	73.59	147.82	1001.1
0	9.9	844	N/A	0	0	56.47	138.78	1000.99
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
Off	Off	Off	Off	Off	Off	Off	Off	Off
0	14.8	668.8	N/A	0	0	41.65	106.79	991.2
0	13.5	790.3	N/A	0	0	49.13	113.26	991.21
0	7.4	663.1	N/A	0	0	61.96	140.06	991.16
0	6.7	905.9	N/A	0	0	63.74	137.29	991
0	6.1	1015.4	N/A	0	0	71.29	138.91	990.65
0	14.8	1015.4	N/A	0	0	76.49	148.12	1001.12
0	8.9	776	N/A	0	0	61.79	133.88	994.8

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	5.9	727.3	N/A	0	0	77.45	147.42	990
0	6	928.9	N/A	0	0	77.79	148.96	990.08
0	6	1033.7	N/A	0	0	77.7	148.65	990.16
0	6	752.7	N/A	0	0	77.39	148.63	989.85
0	5.9	975.9	N/A	0	0	76.3	148.6	989.71

0	5.8	1194.8 N/A	0	0	75.02	148.69	989.65
0	5.9	857 N/A	0	0	76.59	149.12	989.34
0	5.9	1107.7 N/A	0	0	76.18	149.11	989.5
0	5.9	1226.6 N/A	0	0	77.49	149.13	990.06
0	5.8	855.4 N/A	0	0	78.15	150.39	989.66
0	6	1128.3 N/A	0	0	79.42	151.01	989.97
0	5.8	1300.1 N/A	0	0	78.28	151.08	990.24
0	6.1	792.8 N/A	0	0	78.88	150.32	991.07
0	6	914.8 N/A	0	0	76.52	147.13	991.65
0	5.9	1157 N/A	0	0	76.78	146.68	992.9
0	6	818.1 N/A	0	0	76.54	146.72	993.14
0	5.9	1043.3 N/A	0	0	76.63	146.84	993.18
0	6.1	1164 N/A	0	0	76.42	146.8	993.58
0	5.8	747.3 N/A	0	0	76.27	147.26	994.02
0	6	956.2 N/A	0	0	76.28	147.5	994.89
0	6	1050.6 N/A	0	0	75.72	147.53	995.1
0	5.9	758.1 N/A	0	0	76.82	148.12	994.94
0	5.9	962.8 N/A	0	0	76.39	148.07	994.81
0	5.9	1063.2 N/A	0	0	76.53	148.38	994.01
0	6.1	1226.6 N/A	0	0	78.88	151.01	994.94
0	5.9	979.9 N/A	0	0	76.98	148.42	991.73

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	5.9	736.5 N/A	0	0	75.72	148.88	993.08	
0	5.9	932.1 N/A	0	0	76.25	148.59	992.67	
0	5.9	994.4 N/A	0	0	75.68	148.36	992.1	
0	5.9	697.5 N/A	0	0	76.07	149.01	991.19	
0	6	894.9 N/A	0	0	77.42	149.4	990.91	
0	5.9	972.5 N/A	0	0	77.41	149.78	990.48	
0	5.9	729.2 N/A	0	0	76.63	150.32	989.47	
0	6	994.2 N/A	0	0	79.09	150.89	989.58	
0	5.9	1129.9 N/A	0	0	78.12	151.64	989.24	
0	5.9	833.4 N/A	0	0	78.8	152.32	988.73	
0	5.9	1244.7 N/A	0	0	79.21	152.42	988.63	
0	6.1	1632.7 N/A	0	0	80.12	152.51	988.38	
0	5.8	1312.7 N/A	0	0	77.45	149.36	987.7	
0	5.8	1401.6 N/A	0	0	77.8	148.83	986.68	
0	5.9	1513.8 N/A	0	0	78.57	149.46	986.51	
0	5.9	834 N/A	0	0	76.93	149.75	985.15	
0	5.8	941.8 N/A	0	0	76.93	149.44	984.65	
0	5.9	1282.1 N/A	0	0	76.14	149.6	985.15	
0	5.8	810 N/A	0	0	74.51	149.67	984.84	
0	5.8	1040.3 N/A	0	0	75.49	149.51	984.9	
0	5.9	1146.6 N/A	0	0	76.24	149.47	984.6	
0	5.9	747.6 N/A	0	0	75.82	149.5	983.93	
0	5.9	891.2 N/A	0	0	74.64	148.9	983.52	

0	5.9	932.9 N/A	0	0	75.67	148.89	983.27
0	6	1513.8 N/A	0	0	79.21	152.42	992.67
0	5.9	1026.9 N/A	0	0	76.95	149.85	987.72

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6	665.4 N/A	0	0	74.4	149.2	983.22	
0	6	854.3 N/A	0	0	74.44	148.88	983.57	
0	5.9	953 N/A	0	0	73.75	148.18	983.67	
0	5.9	718.6 N/A	0	0	73.93	148.51	983.82	
0	6	941.7 N/A	0	0	75.12	148.79	984.61	
0	6	1073.4 N/A	0	0	74.86	149.29	985.23	
0	5.8	721 N/A	0	0	74.29	149.52	985.57	
0	6	859.9 N/A	0	0	74.18	149.52	985.78	
0	5.9	952.6 N/A	0	0	75.66	149.97	987.09	
0	5.9	773.8 N/A	0	0	75.32	150.17	988.74	
0	5.9	1041.6 N/A	0	0	74.91	149.86	989.62	
0	6	1094.7 N/A	0	0	75.79	150.59	990.1	
0	6.1	706.2 N/A	0	0	76.6	150.72	990.69	
0	6.2	894.8 N/A	0	0	76.89	148.29	991.02	
0	6.1	1038.6 N/A	0	0	77.6	148.63	991.95	
0	5.9	736.1 N/A	0	0	78.67	148.82	993.16	
0	5.9	898.6 N/A	0	0	77.13	148.18	994.41	
0	6.1	992 N/A	0	0	76.78	147.84	995.71	
0	6	628.8 N/A	0	0	75.44	147.37	996.77	
0	6	743.8 N/A	0	0	74.8	146.56	997.84	
0	6.1	794.8 N/A	0	0	75.64	146.62	998.76	
0	6.1	593.5 N/A	0	0	75.65	147.29	1000.02	
0	6	777.6 N/A	0	0	75.73	147.25	1000.93	
0	6	870.6 N/A	0	0	75.68	147.19	1001.62	
0	6.1	1073.4 N/A	0	0	77.6	150.59	1000.93	
0	6	846.9 N/A	0	0	75.55	148.64	991	

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6	600.5 N/A	0	0	76.17	147.67	1002.15	
0	6.1	790.5 N/A	0	0	76.46	147.71	1002.8	
0	6	887.7 N/A	0	0	77.47	147.58	1003.26	
0	6.1	653.9 N/A	0	0	76.98	147.81	1003.64	
0	6.1	789.4 N/A	0	0	75.94	147.69	1004.08	
0	6	836.9 N/A	0	0	75.92	147.69	1004.44	
0	6	617.1 N/A	0	0	76.34	147.56	1005.12	
0	6.1	750.3 N/A	0	0	74.97	147.65	1005.75	













0	9.5	1010.7	N/A	0	0	62.99	133.15	1012.68
0	7	697.1	N/A	0	0	82.89	142.74	1011.8
0	6.3	830.5	N/A	0	0	80.5	145.25	1010.64
0	6.1	824.1	N/A	0	0	79.42	145.02	1008.74
0	6.2	586.2	N/A	0	0	78.32	144.86	1007.01
0	6.4	749.3	N/A	0	0	79.43	145.09	1005.33
0	6.4	811.4	N/A	0	0	78.96	145.88	1003.91
0	17.5	1035.2	N/A	0	0	82.89	145.88	1022
0	10.4	796.9	N/A	0	0	63.57	112.94	1014.7

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.4	619.9	N/A	0	0	79.92	146.4	1002.54
0	6.3	769.3	N/A	0	0	78.04	146.36	1001.22
0	6.2	847.8	N/A	0	0	78.56	146.56	1000.76
0	6.2	645.8	N/A	0	0	77.14	146.42	1000.46
0	6.3	793.4	N/A	0	0	79.31	146.58	1000.06
0	6.4	876.1	N/A	0	0	79.26	146.84	999.96
0	6.3	636.1	N/A	0	0	78.95	147.21	999.14
0	6.3	805.4	N/A	0	0	78.51	146.76	998.81
0	6.2	891.5	N/A	0	0	78.81	146.66	998.62
0	6.2	659.3	N/A	0	0	78.89	147.66	998.6
0	6.3	918	N/A	0	0	79.22	148.31	999.08
0	6.5	1192.1	N/A	0	0	80.2	149.05	999.62
0	6.2	1004.3	N/A	0	0	79.7	149.27	999.41
0	6.3	1222.1	N/A	0	0	77.54	148.37	998.56
0	6.2	1225.3	N/A	0	0	77.2	145.9	997.17
0	6.3	839	N/A	0	0	76.25	144.51	996.18
0	6.4	1072.9	N/A	0	0	74.53	143.92	994.99
0	6.4	1038.9	N/A	0	0	75.15	144.06	994.3
0	6.2	661	N/A	0	0	73.57	144.27	993.3
0	6.1	849.5	N/A	0	0	74.59	144.11	993.17
0	6.2	959.6	N/A	0	0	73.98	144.23	992.91
0	6.3	679.5	N/A	0	0	75.27	145.24	992.92
0	6.6	801.4	N/A	0	0	76.27	145.77	992.61
0	6.6	861.5	N/A	0	0	77.75	147.04	992.52
0	6.6	1222.1	N/A	0	0	79.92	149.05	1001.22
0	6.3	869.6	N/A	0	0	77.44	146.31	997.37

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Strea	Flow Nm3/	Temperatu	Static Press
0	6.2	648.7	N/A	0	0	76.39	147.04	992.63
0	6.2	819.8	N/A	0	0	75.54	146.86	993.32

0	6.3	869	N/A	0	0	76	146.88	993.54
0	6.3	640.6	N/A	0	0	76.73	147.59	994.6
0	6.5	819.5	N/A	0	0	77.59	147.91	995.03
0	6.4	885.7	N/A	0	0	77.05	148.22	995.85
0	6.3	631.1	N/A	0	0	77.63	147.92	996.75
0	6.2	778.6	N/A	0	0	77.38	147.66	997.31
0	6.3	955	N/A	0	0	78.15	148.8	998.67
0	6.3	826.8	N/A	0	0	79.58	150.14	1000.27
0	6.4	1098.6	N/A	0	0	79.42	150.42	1000.94
0	6.5	1236.8	N/A	0	0	81.02	150.51	1001.26
0	6	821.6	N/A	0	0	78.9	148.29	1001.51
0	6.1	966.4	N/A	0	0	77.39	147.06	1001.41
0	6.2	1007	N/A	0	0	79.88	147.4	1001.68
0	6.3	724.8	N/A	0	0	78.88	147.77	1002.24
0	6.4	915.6	N/A	0	0	80.23	148.04	1002.86
0	6.2	1043.5	N/A	0	0	77.63	148	1003.69
0	5.9	751.1	N/A	0	0	77.76	148	1004.15
0	6.1	950.6	N/A	0	0	77.81	147.54	1004.37
0	6.3	1007.7	N/A	0	0	79.03	148.44	1004.52
0	6.4	747.7	N/A	0	0	79.46	149	1004.98
0	6.3	971.6	N/A	0	0	78.33	149.25	1005.95
0	6.2	1066.2	N/A	0	0	78.29	148.84	1006.58
0	6.5	1098.6	N/A	0	0	80.23	150.42	1005.95
0	6.3	882.7	N/A	0	0	78.17	148.23	1000.17

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.2	748.9	N/A	0	0	78.43	149.07	1006.32
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
0	6.3	906.3	N/A	0	0	78.96	148.12	1006.5
0	6.4	1000	N/A	0	0	78.81	149.16	1007
0	6.5	713.9	N/A	0	0	79.92	150.13	1007.38
0	6.4	859.3	N/A	0	0	79.23	150.1	1007.6
0	6.3	900.4	N/A	0	0	78.91	150.06	1007.92
0	6	624.9	N/A	0	0	78.52	149.5	1008.59
0	6.3	847.2	N/A	0	0	79.77	149.73	1009.93
0	6.5	1029.4	N/A	0	0	79.85	150.44	1011.33
0	6.3	989.6	N/A	0	0	79.04	151.2	1012.89
0	6.3	1434.9	N/A	0	0	80.34	150.24	1013.87
0	5.9	1989.2	N/A	0	0	78.31	147.38	1015.27
0	5.9	1548.8	N/A	0	0	79.7	147.22	1015.57
0	6.2	1283.2	N/A	0	0	79.72	147.53	1013.04
0	6.2	1237.7	N/A	0	0	78.8	147.94	1012.43
0	6.2	1067.7	N/A	0	0	78.36	148.32	1013.32
0	6.1	1109.6	N/A	0	0	79.05	148.44	1012.94
0	5.9	1179.2	N/A	0	0	77.32	148.52	1013.49
0	6.1	778.4	N/A	0	0	78.75	149.02	1013.82

0	6.2	847 N/A	0	0	78.8	149.56	1014.11
0	6.4	846.5 N/A	0	0	79.79	150.1	1014.6
0	6.2	588.4 N/A	0	0	79.59	150.19	1015.14
0	6.2	704.5 N/A	0	0	78.16	149.63	1015.45
0	6.5	1548.8 N/A	0	0	79.92	150.44	1015.45
0	6.2	1010.2 N/A	0	0	79.05	149.2	1011.67

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow	Nm3/	Temperatu	Static Press
0	6.1	753.7 N/A	0	0	78.87	148.32	1015.5	
0	6.2	553.2 N/A	0	0	79.49	149.18	1015.47	
0	6.4	728.1 N/A	0	0	80.98	150.4	1015.69	
0	6.4	895.7 N/A	0	0	80.93	151.57	1016.03	
0	6.1	621.8 N/A	0	0	80.29	151.54	1015.91	
0	6	780.2 N/A	0	0	79.23	151.34	1015.99	
0	6	901.2 N/A	0	0	79.19	150.92	1016.88	
0	6.2	696 N/A	0	0	80	151.75	1017.12	
0	6.4	938.6 N/A	0	0	80.47	152.47	1017.77	
0	6.3	1078.9 N/A	0	0	79.93	152.49	1018.01	
0	6	801.4 N/A	0	0	79.47	152.23	1018.16	
0	5.9	1089.8 N/A	0	0	77.88	151.8	1018.24	
0	6.1	1192.5 N/A	0	0	79.37	151.28	1018.15	
0	6.3	895.6 N/A	0	0	79.58	149.12	1017.93	
0	6.4	1057 N/A	0	0	79.86	148.23	1017.34	
0	6.3	1099.9 N/A	0	0	78.5	148.19	1016.51	
0	6	785.7 N/A	0	0	77.64	148.11	1015.65	
0	5.9	925.2 N/A	0	0	77.3	148.19	1015.35	
0	6.2	991.4 N/A	0	0	78.94	148.63	1015.01	
0	6.2	681.3 N/A	0	0	80.58	149.99	1014.16	
0	6.4	787.9 N/A	0	0	80	150.09	1012.78	
0	6.2	893.8 N/A	0	0	78.96	149.69	1012.03	
0	6	681.1 N/A	0	0	78.7	149	1011.41	
0	6	757.7 N/A	0	0	77.66	148.22	1009.59	
0	6.4	1099.9 N/A	0	0	80.93	152.47	1018.16	
0	6.2	857.8 N/A	0	0	79.32	150.12	1015.69	

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow	Nm3/	Temperatu	Static Press
0	6.3	813.4 N/A	0	0	78.67	148.39	1008.81	
0	6.4	574.6 N/A	0	0	79.5	149.34	1008.13	
0	6.5	744.7 N/A	0	0	79.82	149.73	1006.61	
0	6.2	819.1 N/A	0	0	78.32	149.8	1005.68	
0	6	600.2 N/A	0	0	78.36	149.58	1004.76	

0	6	793.6 N/A	0	0	78.37	149.57	1004.51
0	6.3	841.9 N/A	0	0	79.13	149.67	1003.86
0	6.3	605.7 N/A	0	0	79.61	149.91	1003.66
0	6.3	792.4 N/A	0	0	80.04	150.26	1003.65
0	6.1	900.6 N/A	0	0	79.1	149.92	1003.83
0	6	686.8 N/A	0	0	79.24	150.18	1004.42
0	6.2	979.6 N/A	0	0	80.4	150.37	1005.29
0	6.5	1086.4 N/A	0	0	79.97	150.95	1005.94
0	6.3	781.1 N/A	0	0	80.08	148.14	1006.09
0	6.2	1037.5 N/A	0	0	79.14	148.21	1006.4
0	6.1	1006.9 N/A	0	0	79.05	147.79	1006.21
0	6	670.5 N/A	0	0	78.28	147.41	1006.21
0	6.1	834.1 N/A	0	0	78.73	147.22	1006.32
0	6.4	899.2 N/A	0	0	80.13	147.6	1006.58
0	6.2	600.4 N/A	0	0	79.15	147.81	1006.74
0	6.1	724.7 N/A	0	0	78.65	147.62	1006.87
0	6	783.3 N/A	0	0	78.19	147.79	1006.86
0	6	583.4 N/A	0	0	78.33	147.73	1006.59
0	6.2	731.6 N/A	0	0	78.86	148.25	1006.53
0	6.5	1037.5 N/A	0	0	80.13	150.37	1008.13
0	6.2	787.2 N/A	0	0	79.13	148.89	1005.86

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Str	Flow Nm3/	Temperatu	Static Press
0	6.5	821.4 N/A	0	0	80.5	149.43	1006.31	
0	6.3	565.2 N/A	0	0	78.37	149.4	1005.06	
0	6.1	726.6 N/A	0	0	78.79	149.24	1004.57	
0	6	806.9 N/A	0	0	77.21	148.59	1004.2	
0	6.1	604.2 N/A	0	0	78.56	148.67	1003.57	
0	6.3	800.1 N/A	0	0	78.94	149.4	1003.45	
0	6.5	894.4 N/A	0	0	79.98	150.11	1003.14	
0	6.2	578.1 N/A	0	0	79.17	150.14	1002.3	
0	6.1	638.5 N/A	0	0	77.71	149.03	1001.78	
0	6	671.5 N/A	0	0	76.73	148.35	1001.89	
0 N/A	N/A	N/A	0	0 N/A	N/A	N/A	N/A	
0 N/A	N/A	N/A	0	0 N/A	N/A	N/A	N/A	
0 N/A	N/A	N/A	0	0 N/A	N/A	N/A	N/A	
0	6.4	175.2 N/A	0	0	78.77	150.02	1002.69	
0	6.3	512.9 N/A	0	0	78.2	147.11	1003.17	
0	6.2	776.2 N/A	0	0	77.98	146.34	1003.43	
0	6.2	693 N/A	0	0	77.08	146.67	1003.77	
0	6.4	897.6 N/A	0	0	77.72	146.93	1003.46	
0	6.4	872.5 N/A	0	0	78.07	147.61	1003.38	
0	6.2	568.5 N/A	0	0	77.59	147.88	1003.41	
0	6	687.5 N/A	0	0	75.56	147.55	1003.52	
0	6.2	738.9 N/A	0	0	75.74	147.28	1003.37	
0	6.3	558.1 N/A	0	0	77.22	148.29	1002.87	

0	6.6	719.4	N/A	0	0	79.72	148.97	1002.96
0	6.5	894.4	N/A	0	0	79.98	150.11	1005.06
0	6.2	681.3	N/A	0	0	78.08	148.43	1003.44

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow	Nm3/	Temperatu	Static Press
0	6.4	819.9	N/A	0	0	78.25	149.27	1002.67
0	6	627.6	N/A	0	0	76.14	148.68	1002.14
0	6	747.5	N/A	0	0	75.69	148.07	1001.19
0	6.1	776.9	N/A	0	0	76.57	147.93	1000.15
0	6.2	576.3	N/A	0	0	76.62	148.32	999.07
0	6.5	707.4	N/A	0	0	76.96	149	998.57
0	6.4	762	N/A	0	0	76.92	148.85	997.97
0	6.1	553.6	N/A	0	0	76.96	148.54	997.25
0	6.2	765.4	N/A	0	0	76.65	148.38	997.24
0	6.1	986.5	N/A	0	0	75.92	148.56	997.4
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	N/A	N/A	N/A	0	0	N/A	N/A	N/A
0	6.3	274.3	N/A	0	0	78.37	149.6	995.26
0	6.2	340.6	N/A	0	0	76.8	147.69	994.28
0	6.1	615	N/A	0	0	76.9	146.53	994.43
0	6.3	864.5	N/A	0	0	78.98	147.16	994.29
0	6.4	633.8	N/A	0	0	78.33	148.48	993.6
0	6.4	825.8	N/A	0	0	79.98	149.24	993.37
0	6.2	1075.8	N/A	0	0	78.4	149.27	994.49
0	6	669.4	N/A	0	0	77.1	148.82	994.14
0	6.1	755.3	N/A	0	0	76.61	148.4	994.3
0	6.3	753.9	N/A	0	0	78.3	148.48	993.95
0	6.5	547.2	N/A	0	0	77.98	148.77	994.01
0	6.3	653.8	N/A	0	0	77.59	149	993.98
0	6.5	986.5	N/A	0	0	78.98	149.27	1002.14
0	6.2	696.9	N/A	0	0	77.36	148.5	996.53

O2 After	Cc O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream Flow	Nm3/	Temperatu	Static Press
0	6.2	761.4	N/A	0	0	76.52	148.27	994.77
0	6	562.3	N/A	0	0	77.25	148.07	994.62
0	6.1	704	N/A	0	0	76.49	147.67	994.72
0	6.3	743.2	N/A	0	0	75.19	148.1	994.06
0	6.4	525.3	N/A	0	0	77.44	148.67	993.91
0	6.3	665.4	N/A	0	0	75.52	148.6	993.8
0	6.2	719.4	N/A	0	0	75.89	148.12	993.84
0	6	507	N/A	0	0	76.38	147.71	993.68

0	6.2	686.2 N/A	0	0	75.71	147.68	994.37
0	6.4	809.6 N/A	0	0	75.49	148.04	994.51
0	6.4	673.9 N/A	0	0	77.97	149.45	994.94
0	6.2	905.4 N/A	0	0	75.4	149.15	994.91
0	6	1062.2 N/A	0	0	75.6	149.15	994.93
0	6.3	772.4 N/A	0	0	76.52	149.34	994.87
0	6.3	950.3 N/A	0	0	77.9	147.54	994.86
0	6.5	879.2 N/A	0	0	78.62	146.86	993.88
0	6.3	581.6 N/A	0	0	77.92	147.89	992.94
0	6.2	751.3 N/A	0	0	77.76	148.01	992.93
0	6.1	813.5 N/A	0	0	77.42	148.01	992.84
0	6.2	570.7 N/A	0	0	78.04	148.7	993.04
0	6.2	730.8 N/A	0	0	78.55	149.6	993.33
0	6.4	785.1 N/A	0	0	79.42	150.31	993.31
0	6.1	556.8 N/A	0	0	78.47	150.15	992.58
0	6.1	692.6 N/A	0	0	78.59	149.33	992.59
0	6.4	950.3 N/A	0	0	78.62	150.15	994.93
0	6.2	725.4 N/A	0	0	77.09	148.52	993.93

O2 After Cc	O2 in Stack	H2O ppm	Spare -	Combustio	Live Stream	Flow Nm3/	Temperatu	Static Press
0	6.1	756.2 N/A	0	0	77.59	149.34	992.81	
0	6.3	520.7 N/A	0	0	78.15	149.3	992.85	
0	6.6	654.6 N/A	0	0	79.13	149.93	992.57	
0	6.7	729 N/A	0	0	79.72	149.99	992.66	
0	6.2	545.4 N/A	0	0	79.01	150.39	993.09	
0	6.2	669.3 N/A	0	0	79.46	150.2	993.53	
0	6.2	716.6 N/A	0	0	78.23	149.91	993.93	
0	6.3	524.7 N/A	0	0	78.93	150.07	994.71	
0	6.6	647.3 N/A	0	0	80.42	150.21	994.92	
0	6.6	696.3 N/A	0	0	81.15	150.94	995.72	
0	6.2	518.9 N/A	0	0	79.51	150.85	996.63	
0	6.3	719.5 N/A	0	0	81.67	151.61	997.96	
0	6.3	864.7 N/A	0	0	80.92	152.22	998.74	
0	6.3	650 N/A	0	0	83.07	153.34	999.71	
0	6.5	838.3 N/A	0	0	83.93	153.5	1000.43	
0	6.7	933.8 N/A	0	0	84.3	153.51	1001.03	
0	6.2	657.5 N/A	0	0	83.89	151.17	1002.21	
0	6.2	808.8 N/A	0	0	82.34	151.08	1002.86	
0	6.5	868.7 N/A	0	0	85.08	151.47	1003.43	
0	6.3	621 N/A	0	0	81.32	151.06	1004.19	
0	6.5	768.5 N/A	0	0	79.48	149.21	1005.12	
0	6.5	813 N/A	0	0	79.31	148.68	1005.86	
0	6.2	594.3 N/A	0	0	78.2	148.46	1006.56	
0	6.1	762.9 N/A	0	0	78.18	148.01	1007.3	
0	6.7	868.7 N/A	0	0	84.3	153.5	1006.56	
0	6.4	703.3 N/A	0	0	80.54	150.6	998.7	

Velocity m/s

16.17  
16.26  
16.3  
16.3  
16.51  
16.61  
16.95  
16.74  
17.01  
16.82  
17.27  
16.93  
17.35  
16.83  
16.78  
16.77  
16.61  
16.63  
16.64  
16.72  
16.79  
16.36  
16.47  
16.54  
17.27  
16.68

Velocity m/s

16.46  
16.28  
16.23  
16.45  
16.52  
16.51  
16.26  
16.32  
16.24  
16.49  
16.88  
16.7  
17.05  
17.15

16.67  
16.59  
16.54  
16.48  
16.14  
16.32  
16.33  
16.44  
16.63  
17.11  
17.11  
16.53

Velocity m/s

16.92  
17.08  
17.1  
17.48  
17.01  
17.03  
17.02  
16.78  
16.22  
16.98  
17.07  
16.91  
17.1  
16.73  
16.87  
16.21  
16.73  
16.82  
16.53  
16.61  
16.39  
16.48  
16.83  
16.83  
17.1  
16.82



Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off

Velocity m/s

Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off

7.26  
7.32  
7.6  
7.99  
10.48  
12.1  
12.28  
12.21  
11.86  
11.77  
12.03  
12.24  
16.12  
16.12  
10.87

Velocity m/s

17.31  
16.91

16.32  
16.47  
16.31  
16.31  
16.42  
16.55  
16.45  
16.41  
16.77  
16.3  
16.44

N/A  
N/A

16.29  
16.37  
16.07  
15.23  
15.79  
16.05  
15.9  
15.92  
15.94  
16.91  
16.3

Velocity m/s

15.95  
15.88  
16.14  
15.9  
15.85  
16.13  
16.12  
16.13  
15.9  
16.22  
16.11  
16.17  
16.11  
16.13  
16.61  
16.31  
16.48  
16.21  
16.14  
16.07

16.13  
16.27  
16.37  
16.48  
16.48  
16.16

Velocity m/s

16.49  
15.86  
11.91

Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off  
Off

8.18  
9.83  
13.24  
13.53  
15.2  
16.49  
13.03

Velocity m/s

16.86  
17  
16.96  
16.9  
16.66

16.39  
16.75  
16.66  
16.94  
17.14  
17.44  
17.19  
17.27  
16.62  
16.64  
16.58  
16.61  
16.55  
16.53  
16.53  
16.41  
16.67  
16.58  
16.63  
17.27  
16.77

Velocity m/s

16.49  
16.6  
16.48  
16.6  
16.92  
16.94  
16.81  
17.37  
17.19  
17.38  
17.47  
17.68  
16.98  
17.05  
17.25  
16.92  
16.92  
16.74  
16.39  
16.6  
16.77  
16.69  
16.41

16.64  
17.47  
16.89

Velocity m/s

16.38  
16.37  
16.19  
16.24  
16.5  
16.45  
16.33  
16.3  
16.62  
16.53  
16.41  
16.62  
16.8  
16.76  
16.91  
17.13  
16.75  
16.64  
16.31  
16.12  
16.29  
16.3  
16.3  
16.27  
16.91  
16.48

Velocity m/s

16.39  
16.44  
16.65  
16.55  
16.31  
16.3  
16.37  
16.08













12.95  
17.46  
17.08  
16.87  
16.66  
16.93  
16.89  
17.46  
12.67

Velocity m/s

17.14  
16.76  
16.88  
16.58  
17.06  
17.06  
17.02  
16.91  
16.98  
17.04  
17.13  
17.36  
17.26  
16.77  
16.63  
16.38  
16.01  
16.16  
15.84  
16.06  
15.94  
16.25  
16.5  
16.87  
17.26  
16.69

Velocity m/s

16.57  
16.37

16.47  
16.63  
16.83  
16.71  
16.81  
16.73  
16.92  
17.26  
17.22  
17.57  
17.01  
16.64  
17.19  
16.98  
17.27  
16.69  
16.71  
16.7  
17  
17.1  
16.85  
16.82  
17.27  
16.88

Velocity m/s

16.86

N/A

16.94  
16.94  
17.21  
17.06  
16.98  
16.86  
17.12  
17.14  
16.97  
17.19  
16.62  
16.91  
16.97  
16.8  
16.7  
16.86  
16.48  
16.8

16.83  
17.06  
17.01  
16.68  
17.19  
16.91

Velocity m/s

16.78  
16.94  
17.31  
17.34  
17.2  
16.96  
16.92  
17.13  
17.24  
17.13  
17.02  
16.66  
16.96  
16.92  
16.95  
16.67  
16.5  
16.44  
16.81  
17.23  
17.13  
16.91  
16.83  
16.61  
17.31  
16.94

Velocity m/s

16.85  
17.07  
17.18  
16.88  
16.89

16.9  
17.08  
17.2  
17.3  
17.08  
17.12  
17.36  
17.28  
17.18  
16.98  
16.95  
16.77  
16.85  
17.16  
16.96  
16.84  
16.75  
16.78  
16.92  
17.3  
17.01

Velocity m/s

17.32  
16.89  
16.98  
16.62  
16.92  
17.04  
17.29  
17.14  
16.78  
16.54

N/A

N/A

N/A

17.04  
16.79  
16.71  
16.52  
16.67  
16.78  
16.68  
16.23  
16.26  
16.63

17.2  
17.29  
16.81

Velocity m/s

16.9  
16.42  
16.32  
16.52  
16.56  
16.67  
16.67  
16.68  
16.6  
16.45

N/A

N/A

17.06  
16.66  
16.63  
17.11  
17.03  
17.43  
17.07  
16.77  
16.64  
17.02  
16.96  
16.89  
17.11  
16.78

Velocity m/s

16.61  
16.77  
16.58  
16.33  
16.84  
16.42  
16.48  
16.58

16.42  
16.38  
16.97  
16.4  
16.44  
16.65  
16.88  
17.03  
16.93  
16.9  
16.83  
16.99  
17.13  
17.35  
17.15  
17.14  
17.15  
16.76

Velocity m/s

16.92  
17.04  
17.28  
17.41  
17.27  
17.35  
17.06  
17.21  
17.54  
17.71  
17.33  
17.81  
17.66  
18.16  
18.34  
18.41  
18.2  
17.85  
18.45  
17.6  
17.11  
17.05  
16.79  
16.75  
18.41  
17.51

Permit Number: **EPR/ZP3939GL**

Operator: **PX Ltd**

Facility: **Western Wood Energy Plant**

Form Number: **Air 1 (Continuous Monitoring)**

Reporting of emissions to air for the period from: **01/02/2018 to 28/02/2018**

Emission Point	Substance / Parameter	Emission Limit Value <sup>(4)</sup>	Reference Period	Max	Av	Number of daily exceedences in period >ELV	Number of Hourly exceedences in period >200%ELV	Test Method <sup>(3)</sup>	Uncertainty <sup>(4)</sup>
				Maximum Result <sup>(1)</sup> mg/m <sup>3</sup>	Average Result <sup>(2)</sup> mg/m <sup>4</sup>				
A1	Particulate Matter	10 mg/m <sup>3</sup>	Hourly average (continuous)	6.02	0.98	n/a	0	MCERT CEMS	30%
A1	Particulate Matter	10 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	1.24	0.92	0	n/a	MCERT CEMS	30%
A1	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	250 mg/m <sup>3</sup>	Hourly average (continuous)	241.10	174.21	n/a	0	MCERT CEMS	20%
A1	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	250 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	194.19	163.17	0	n/a	MCERT CEMS	20%
A1	Carbon monoxide	250 mg/m <sup>3</sup>	Hourly average (continuous)	334.40	73.00	n/a	9	MCERT CEMS	10%
A1	Carbon monoxide	250 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	162.40	67.62	0	n/a	MCERT CEMS	10%

1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value.

2) For continuous measurements the percentage of the process operating time covered by the result is given. Method in accordance with BS EN 15267-3, but reference Note 2 of Table S4.1 in Permit.

3) For continuous measurements the percentage of the process operating time covered by the result is given. Method in accordance with BS EN 15267-3, but reference note 2 of Table S4.1 in Permit

4) 3) The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

5) 95% of the of validated hourly averages within a calendar year do not exceed 200% of ELV.

Signed M. Wall  
(Authorised on behalf of PX Ltd)

Date 26/4/18

Permit Number: **EPR/ZP3939GL**

Operator: **PX Ltd**

Facility: **Western Wood Energy Plant**

Form Number: **Air 1 (Continuous Monitoring)**

Reporting of emissions to air for the period from: **01/01/2018 to 31/01/2018**

Emission Point	Substance / Parameter	Emission Limit Value <sup>(4)</sup>	Reference Period	Max	Av	Number of daily exceedences in period >ELV	Number of Hourly exceedences in period >200%ELV	Test Method <sup>(3)</sup>	Uncertainty <sup>(4)</sup>
				Maximum Result <sup>(1)</sup> mg/m <sup>3</sup>	Average Result <sup>(2)</sup> mg/m <sup>4</sup>				
A1	Particulate Matter	10 mg/m <sup>3</sup>	Hourly average (continuous)	2.39	0.94	n/a	0	MCERT CEMS	30%
A1	Particulate Matter	10 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	1.16	0.94	0	n/a	MCERT CEMS	30%
A1	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	250 mg/m <sup>3</sup>	Hourly average (continuous)	236.34	173.25	n/a	0	MCERT CEMS	20%
A1	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	250 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	193.07	172.70	0	n/a	MCERT CEMS	20%
A1	Carbon monoxide	250 mg/m <sup>3</sup>	Hourly average (continuous)	438.61	95.23	n/a	14	MCERT CEMS	10%
A1	Carbon monoxide	250 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	136.21	94.71	0	n/a	MCERT CEMS	10%

1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value.

2) For continuous measurements the percentage of the process operating time covered by the result is given. Method in accordance with BS EN 15267-3, but reference Note 2 of Table S4.1 in Permit.

3) For continuous measurements the percentage of the process operating time covered by the result is given. Method in accordance with BS EN 15267-3, but reference note 2 of Table S4.1 in Permit

4) 3) The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

5) 95% of the of validated hourly averages within a calendar year do not exceed 200% of ELV.

Signed M. Wall  
(Authorised on behalf of PX Ltd)

Date 26/4/18

Permit Number: **EPR/ZP3939GL**

Operator: **PX Ltd**

Facility: **Western Wood Energy Plant**

Form Number: **Air 1** (Continuous Monitoring)

Reporting of emissions to air for the period from: **01/03/2018 to 31/03/2018**

Emission Point	Substance / Parameter	Emission Limit Value <sup>(4)</sup>	Reference Period	Max	Av	Number of daily exceedences in period >ELV	Number of Hourly exceedences in period >200%ELV	Test Method <sup>(3)</sup>	Uncertainty <sup>(4)</sup>
				Maximum Result <sup>(1)</sup> mg/m <sup>3</sup>	Average Result <sup>(2)</sup> mg/m <sup>4</sup>				
A1	Particulate Matter	10 mg/m <sup>3</sup>	Hourly average (continuous)	5.45	0.94	n/a	0	MCERT CEMS	30%
A1	Particulate Matter	10 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	1.39	0.65	0	n/a	MCERT CEMS	30%
A1	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	250 mg/m <sup>3</sup>	Hourly average (continuous)	221.86	172.15	n/a	0	MCERT CEMS	20%
A1	Oxides of nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	250 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	190.97	119.82	0	n/a	MCERT CEMS	20%
A1	Carbon monoxide	250 mg/m <sup>3</sup>	Hourly average (continuous)	211.42	74.92	n/a	0	MCERT CEMS	10%
A1	Carbon monoxide	250 mg/m <sup>3</sup>	Daily mean of hourly averages (continuous)	116.03	51.02	0	n/a	MCERT CEMS	10%

1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value.

2) For continuous measurements the percentage of the process operating time covered by the result is given. Method in accordance with BS EN 15267-3, but reference Note 2 of Table S4.1 in Permit.

3) For continuous measurements the percentage of the process operating time covered by the result is given. Method in accordance with BS EN 15267-3, but reference note 2 of Table S4.1 in Permit

4) 3) The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

5) 95% of the of validated hourly averages within a calendar year do not exceed 200% of ELV.

Signed m. wald  
(Authorised on behalf of PX Ltd)

Date 26/4/18