



Alison Soper
Natural Resources Wales
Chester Road
Buckley
Flintshire
CH7 3AJ

11th April 2014

Attn: Matthew Kelk

RE: SHOTTON WORKS PERMIT; Q2 RETURNS APR-JUNE 2014

Please find attached Quarter 2 returns for our site permit BR7321, for the period April – June 2014.

Form W1, Reporting of emissions to water (other than to sewer)

Yours sincerely

S Hughes
Environment Officer

MONITORING RETURNS N. WALES

CHECKED Vs AUTHORISATION

PACKING

OK FOR PUBLIC REGISTER

TYPE TO PEOPLE'S REGISTER

INITIALS DATE

MLK 23/07/14

JB 18.7.14

MLK 23/07/14

JB BDEM

TATA STEEL

Colors

Shotton Works Deeside Flintshire CH5 2NH

T: +44 (0) 1244 81 2345 T: +44 (0) 1244 89 2923 (direct) steve.hughes@tatasteel.com

STATE OF NEW YORK

IN SENATE

JANUARY 1, 1900

REPORT

OF THE

COMMISSIONERS OF THE LAND OFFICE

FOR THE YEAR 1899

ALBANY:

1900

WHELAN & SON, PRINTERS

ALBANY, N. Y.

Permit Reference Number: BR7321

Installation: Tata Steel Colors Shotton Works

Operator: Tata Steel UK Limited

Form Number: W1 (Page 1 of 3)



Reporting of Emissions to Water (other than to Sewer) for the period from ...30/03/14....to....28/06/14

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
W1	Flow	15,000 m ³ /day	Mean	Magnetic flow meter	100%	UKAS Lab	3.7%
			Max	Magnetic flow meter		UKAS Lab	
	pH	5 - 9	Min	Glass electrode laboratory pH meter	8am Every morning	UKAS Lab	+/- 0.12
			Max	Glass electrode laboratory pH meter		UKAS Lab	
	Suspended solids	100 mg/l	Mean	Gravimetric /Filtering/Balance	8am Every morning	UKAS Lab	+/- 2.1mg/l
			Max	Gravimetric /Filtering/Balance		UKAS Lab	
	Chemical Oxygen Demand	200 mg/l	Mean	Colorimetric - Hach Spectrophotometer	8am Every morning	UKAS Lab	+/- 1.2mg/l
			Max	Colorimetric - Hach Spectrophotometer		UKAS Lab	
	Iron	10 mg/l	Mean	Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
			Max	Laboratory ICP		UKAS Lab	

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) - {The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}

Signed S. Hughes
(authorised to sign as representative of the Operator)

Date.....11/07/14.....

Permit Reference Number: BR7321

Operator: Tata Steel UK Limited

Installation: Tata Steel Colors Shotton Works

Form Number: W1 (Page 2 of 3)

Reporting of Emissions to Water (other than to Sewer) for the period from ...30/03/14....to....28/06/14

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
W1	Chromium	0.3 mg/l	Mean 0.1 Max 0.1	Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
	Mercury	10 µg/l	0.1	Laboratory ICP	08/06/14	UKAS Lab	+/- 0.1µg/l
	Nickel	0.6 mg/l	Mean 0.1 Max 0.1	Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
	Zinc	0.8 mg/l	Mean 0.1 Max 0.1	Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
	Ammoniacal Nitrogen (mg/l)		Mean 0.76 Max 2.75	Colorimetric - Hach Spectrophotometer	8am Every morning	UKAS Lab	+/- 0.1mg/l
						UKAS Lab	
						UKAS Lab	
						UKAS Lab	

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. In other cases the principal technique is stated, e.g. colorimetry.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.
- [4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
- [5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) – {The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}

Signed S. Hughes
(authorised to sign as representative of the Operator)
Permit Reference Number: BR7321

Date.....11/07/14.....

Operator: Tata Steel UK Limited

Reporting of Emissions to Water (other than to Sewer) for the period from ...30/03/14.....to....28/06/14

Emission Point	Substance / Parameter	Result ^[1]		Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
		Min	Max				
Effluent Plant Discharge A41	pH	7.5		Glass electrode laboratory pH meter	8am Every morning	UKAS Lab	+/- 0.12
		10.0			8am Every morning	UKAS Lab	
	Iron (mg/l)	Mean		Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
		Max			8am Every morning	UKAS Lab	
	Mercury (µg/l)			Laboratory ICP	08/06/14	UKAS Lab	+/- 0.1 µg/l
	Chromium (mg/l)	Mean		Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
		Max			8am Every morning	UKAS Lab	
	Nickel (mg/l)	Mean		Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
		Max			8am Every morning	UKAS Lab	
	Zinc (mg/l)	Mean		Laboratory ICP	8am Every morning	UKAS Lab	+/- 0.1mg/l
		Max			8am Every morning	UKAS Lab	

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) – {The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}

Signed S. Hughes Date.....11/07/14.....
(authorised to sign as representative of the Operator)

