

Project Name: Mark Sealy - Energy Output Assessment (FDC below is for both watercourses combined)

% Exceedance Probability	Flow upstream of abstraction [l/s]	Abstraction [l/s]	Abstraction as percentage of upstream flow	Residual flow downstream of weir [l/s]	Residual flow as percentage of upstream flow	Penstock Headloss [m]	Combined Turbine & Generator Efficiency [%]	Power output [kW]	Yield [kWh]
5%	321	50.0	15.6%	271	84.4%	3.74	73%	33.86	14,830
10%	213	50.0	23.5%	163	76.5%	3.74	73%	33.86	14,830
15%	170	50.0	29.4%	120	70.6%	3.74	73%	33.86	14,830
20%	127	50.0	39.4%	77	60.6%	3.74	73%	33.86	14,830
25%	107	50.0	46.7%	57	53.3%	3.74	73%	33.86	14,830
30%	87	50.0	57.5%	37	42.5%	3.74	73%	33.86	14,830
35%	75	44.8	59.7%	30	40.3%	3.05	72%	30.14	13,201
40%	63	36.4	57.8%	27	42.2%	2.08	72%	24.74	10,836
45%	55	30.8	56.0%	24	44.0%	1.52	72%	21.05	9,221
50%	47	25.2	53.6%	22	46.4%	1.05	71%	17.07	7,476
55%	41	21.0	51.2%	20	48.8%	0.75	71%	14.27	6,250
60%	35	16.8	48.0%	18	52.0%	0.50	69%	11.12	4,871
65%	31	14.0	45.2%	17	54.8%	0.35	67%	9.01	3,948
70%	27	11.2	41.5%	16	58.5%	0.23	63%	6.79	2,973
75%	24	9.1	37.9%	15	62.1%	0.16	56%	4.91	2,149
80%	21	7.0	33.3%	14	66.7%	0.10	46%	3.10	1,359
85%	18	4.6	26.0%	13	74.0%	0.04	26%	1.14	499
90%	14	0.0	0.0%	14	100.0%	0.00	0%	0.00	0
95%	11	0.0	0.0%	11	100.0%	0.00	0%	0.00	0
100%	7	0.0	0.0%	7	100.0%	0.00	0%	0.00	0

Annual Totals 151,764
Turbine down time for maintenance in days per year 5
Estimated annual generation in kWh 149,685
Capacity Factor 50.47%

Aggregate statistics & abstraction quantities (both watercourses combined):

Catchment area: 1.820 km2
Run-off: 1579 mm
Gross Head (Static Head): 98.3 m
Net Head (Dynamic Head) at Design Flow: 94.6 m
Mean Flow (Qmean) 91 l/s
Abstraction regime (Percentage take above HOF) 70%
Hands Off Flow (HOF) Exceedance 95%
Hands Off Flow (HOF) 11 l/s
Design Flow (Aggregate Max Instantaneous Abstraction Flow) 50.0 l/s
Min Turbine Flow as %age of max flow 5%
Min Turbine Flow 3 l/s
Q95/Qmean Ratio (see FDC above) 0.12
Q10/Qmean Ratio (see FDC above) 2.34
Max hourly abstraction (Design flow x 3600 sec) 180.0 m3
Max daily abstraction (Max hourly abstract x 24h) 4,320.0 m3
Max Annual abstraction (Max Daily Abstraction x 365 days) 1,576,800 m3

Note the max instantaneous abstraction flows have be apportioned to each intake based on the fact that the tributary's mean flow (Intake 1) is 60% of Afon Alice's (Intake 2) and an aggregate design flow (max turbine flow) of 50 l/s is required]

Intake 1' (unnamed tributary) statistics & abstraction quantities:

Mean Flow (Qmean) 34 l/s
Q95/Qmean Ratio (see FDC over the page) 0.12
Q10/Qmean Ratio (see FDC over the page) 2.32
Max instantaneous abstraction flow 19 l/s
Max hourly abstraction (max instantaneous abstraction x 3600 sec) 67.5 m3
Max daily abstraction (Max hourly abstract x 24h) 1,620.0 m3
Max Annual abstraction (Max Daily Abstraction x 365 days) 591,300 m3

Intake 2' (Afon Alice) statistics & abstraction quantities:

Mean Flow (Qmean) 57 l/s
Q95/Qmean Ratio (see FDC over the page) 0.12
Q10/Qmean Ratio (see FDC over the page) 2.35
Max instantaneous abstraction flow 31 l/s
Max hourly abstraction (max instantaneous abstraction x 3600 sec) 112.5 m3
Max daily abstraction (Max hourly abstract x 24h) 2,700.0 m3
Max Annual abstraction (Max Daily Abstraction x 365 days) 985,500 m3

Flow Duration Curves for Mark Sealy (Afon Alice & one of its unnamed tributaries)

Annual Flow Duration Curve:
Low-Flow Estimates from LowFlows
www.hydrosolutions.co.uk

Intake 1&2' Combined				Intake 1' - Unnamed Tributary				Intake 2' - Afon Alice			
				Natural FD series at annual resolution Basin-nam: Sealy Intake 4 (Intake 1 very similar) Prelim Outlet at: SH 689 029				Natural FD series at annual resolution Basin-name: Sealy Intake 2 Prelim Outlet at: SH 694 030			
				(Based on catchment characteristics derived at grid-resolution of 20 m) Annual me 0.034 m³/s Q95 0.004 m³/s				(Based on catchment characteristics derived at grid-resolution of 20 m) Annual mean f 0.057 m³/s Q95 0.007 m³/s			
	P (%)	Q (m³/s)	Q (l/s)		P (%)	Q (m³/s)	Q (l/s)		P (%)	Q (m³/s)	Q (l/s)
1	5	0.321	321	1	5	0.119	119	1	5	0.202	202
2	10	0.213	213	2	10	0.079	79	2	10	0.134	134
3	20	0.127	127	3	20	0.047	47	3	20	0.08	80
4	30	0.087	87	4	30	0.032	32	4	30	0.055	55
5	40	0.063	63	5	40	0.023	23	5	40	0.04	40
6	50	0.047	47	6	50	0.017	17	6	50	0.03	30
7	60	0.035	35	7	60	0.013	13	7	60	0.022	22
8	70	0.027	27	8	70	0.01	10	8	70	0.017	17
9	80	0.021	21	9	80	0.008	8	9	80	0.013	13
10	90	0.014	14	10	90	0.005	5	10	90	0.009	9
11	95	0.011	11	11	95	0.004	4	11	95	0.007	7
12	99	0.007	7	12	99	0.003	3	12	99	0.004	4
LowFlows Runoff 1579 mm				1602 Intake 1 Runoff				1555 Intake 2 Runoff			
LowFlows Rainfall 2052 mm				2055 Intake 1 Rainfall				2049 Intake 2 Rainfall			
Catchment Area 1.82 km²				0.66 Intake 1 catchment area				1.16 Intake 2 catchment area			
BFI 0.37											
LowFlows Map 64											

