

RECEIVED

17 JUN 2013

Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_101
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	Between 09:20 and 17:30 on 11 th March 2013. Calculated emission prediction at 17:30 for 11 th March 2013.		

Any more accurate information on the matters for notification under Part A.	The actual Daily Average CO emission was 265.6mg/Nm ³ @8%O ₂ Dry Gas against a Daily Average limit of 80mg/Nm ³ @8%O ₂ Dry Gas.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The cause was believed to be that some of the control linkages were found to be loose. These were re-adjusted and tightened. Checking the condition and operation of this burner control equipment has been included in regular on-going maintenance routines.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	14/03/11, 28/04/11, 01/05/11, 02/06/11, 13/06/11, 27/06/11, 19/07/11, 26/07/11, 27/07/11, 07/09/11, 13/09/11, 10/11/11, 13/12/11, 03/01/12, 18/01/12, 23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13

Name*	B.K.Pratley
Post	Environmental Manager
Signature	<i>B. K. Pratley</i>
Date	17 th June 2013

* authorised to sign on behalf of Knauf Insulation Ltd

OK FOR PUBLIC REGISTER	INITIALS	DATE
	AS	18/6/13
COPIED TO PUBLIC REGISTER	JB	EDRM