

RECEIVED

21 JUN 2013

Schedule 6 - Notification**Part B - to be submitted as soon as practicable**

Permit Number	BR9383ID	Notification Reference	EP_EX_102
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	On the morning of 8 th April 2013 checking previous Daily Averages.		

Any more accurate information on the matters for notification under Part A.	The actual Daily Average CO emission was 202.67mg/Nm ³ @8%O ₂ Dry Gas against a Daily Average limit of 80mg/Nm ³ @8%O ₂ Dry Gas.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The cause was believed to be control linkages that were found to be loose in a different part of the control mechanism from that notified in EP_EX_101. These were re-adjusted and tightened. Checking the condition and operation of this burner control equipment has been included in regular on-going maintenance routines.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	28/04/11, 01/05/11, 02/06/11, 13/06/11, 27/06/11, 19/07/11, 26/07/11, 27/07/11, 07/09/11, 13/09/11, 10/11/11, 13/12/11, 03/01/12, 18/01/12, 23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13

Name*	B.K.Pratley
Post	Environmental Manager
Signature	<i>B. K. Pratley</i>
Date	21 st June 2013

* authorised to sign on behalf of Knauf Insulation Ltd

	INITIALS	DATE
OK FOR PUBLIC REGISTER	JS	2/7/13
COPIED TO PUBLIC REGISTER	JB	EORM

Bradford, Julie

From: Pratley, Keith [keith.pratley@knaufinsulation.com]
Sent: 08 April 2013 15:16
To: North-wales-ppc; Soper, Alison
Cc: Lewis, Mark; Bowser, Corinne; Griffiths, Stuart; Heyes, Nigel; Hensley, Claire
Subject: Schedule 6 Part A Notification Permit No BR9383ID
Attachments: EP_EX 102_A_CO Burner Fail A_E Stack 07-04-13.pdf

Please find attached the Part A Notification made under condition 4.3.1 (a) of the Permit No EA/EPR/BR9383ID/V004.

This notification is for a series of events of Emergency By-Pass openings that were associated with a failure of the cupola waste gas abatement burner that occurred on the evening of 7th April 2013 and resulted in the Daily Average CO emission being in excess of the limit. The Emergency By-Pass events were notified by telephone on Saturday 6th and Sunday 7th April.

EA Reference number 1100321.

Best Regards,

Keith Pratley
Environmental Manager

KNAUFINSULATION



Tel: 01244 525565 Fax: 01244 525517 Mobile: 07790 768658

 **Before printing, please think about the environment!**

This message has been scanned and no issues discovered.